

June, 2026

Monthly Maintenance Report

Maintenance

Checking wells, checking pumps, checking sewer pumps, checking PRV's, working at the cemetery, taking water samples, checking the Little League, checking city parks, checking and servicing vehicles, doing meter turn-ons and turn-offs, checking on plugged sewers, and other customer concerns, checking on the chlorine system.

Projects:

Continued Clearing trees in ditch behind the shop

PRV on Joan St. was exercised- manually switching from the high flow to low flow once a month to exercise each valve

Started new water and sewer line mapping.

Continue to grade alleys with the Kubota

Had a meeting with Martha and Stephen about the loss control safety site visit. Came up with solutions on their findings and suggestions.

Normal Park maintenance and trash pick-up around them.

Continued weed control around city.

Water and Sewer:

Sent monthly chlorine tests to be analyzed, all came back good.

Chlorine Analyzer monthly PM

Repaired 7 water leaks

6 sewer call outs

3 Sewer preventive maintenance- Routing and jetting man holes throughout the city.

Training/Classes/Special Events:

Continuing Cross training with wastewater department