City of Bayard Wastewater Treatment Plant

July 2021

07-06-2021: Turned the #1, #2, and #3 drying beds, Dewatered the #1 digester.

07-07-2021: Plant staff washed the reclamation plant floor.

07-08-2021: Shut down reclamation plant after chlorine injector snapped in half.

07-09-2021: plant staff went to Keenan to try and track down a chlorine injector.

07-13-2021: Turned the #1, #2, and #3 drying beds.

07-14-2021: Joe Trumm came down to plant, Dewatered the #3 digester.

07-15-2021: Joe Trumm came down to the plant. Finished dewatering the #3 digester. Turned the #1, #2, and #3 drying beds.

07-19-2021: Plant staff started to work on repairing the turbidity meter in the reclamation plant.

07-20-2021: Plant staff worked on repairing the turbidity meter in the reclamation plant.

07-21-2021: Plant staff worked on the weeds around the plant, Turned the #1, #2, and #3 drying beds.

07-22-2021: Plant staff pulled the sludge out of the #1 drying bed.

07-23-2021: Plant staff finished repairing the turbidity meter and installed the chlorine injector at the reclamation plant. Started to run water to the reclamation plant to fill up the storage tank so that a chlorine residual could be obtained and the water tested for E-coli.

07-26-2021: Plant staff rebuilt the #1 drying bed and turned the #1, #2, and #3 drying beds.

07-27-2021: Sent water to the cemetery, Dropped the #2 digester to the #1 drying bed.

07-28-2021: Hauled sludge to the Silver City landfill, Worked on leak on polymer system.

07-29-2021: Hauled sludge to the Silver City landfill, Plant staff worked on leak on polymer system, changed out the flow meter found old unit to be cracked.