

City of Bayard Wastewater Treatment Plant

Report for May 2023

5-01-2023: Turned All drying beds, check N Hurley Lift Station
And go to Silver to pick up parts for Rec Plant, go to Keenan
Supply and pick up Acid pump for UV and Fix two leaks at the
Rec Plant

5-02-2023: Work on A/C at Rec Plant and go to Ace Hardware
To buy two Floats and grease all pumps & motors at Rec Plant
And Haul two load of Sludge to Sliver landfill

5-03-2023: Collect all Water Samples and take to Silver UPS and
Change out barrel in the Ras Room and Clean up Blower Area

5-04-2023: Turned All drying beds, Check N Hurley Lift Station
And Haul two load of sludge to silver land fill, turn sludge
Storage pile and Clean up Lab Building

5-08-2023: Turn one and two Drying Beds and turn Sludge pile
And pullout sludge from number Three drying bed and clean
wash water room and check N Hurley Lift Station

5-09-2023: Haul two loads of Sludge to Silver landfill and
change out two-level switch for chlorine at Rec Plant and
Rebuild center drain on number three bed, change out screens
on all four corners of #3 Drying Beds

5-10-2023: Check N Hurley Lift Station, collect all Water Samples and take to Silver UPS and cut weeds around plant

5-11-2023: Turned All drying beds, Check N Hurley Lift Station Sweep and Mop Lab Building and wash TSS filters

5-15-2023: Turned All drying beds, turn Sludge pile and pickup Trash to take to dump and Check N Hurley Lift Station

5-16-2023: Received Polymer barrels and put in screw press And take Trash to land fill and Clean Lab, scrub arms on Clarifiers

5-17-2023: Collect Water Samples and take to Silver UPS and Took pictures of the Headworks Construction Site and send to City Clerk Jump fuel truck and fill up Bobcat

5-18-2023: Turned All drying beds, check N Hurley Lift Station Sweep and Mop Lab Building and wash TSS filters

5-22-2023: Turned two, three drying beds, check N Hurley Lift Station and pullout sludge from number one drying bed and try to exercise valve to the west clarifier

5-23-2023: Check N Hurley Lift Station and Put New Rope on the Dump Truck and Exercise valves. Work on Chlorine at Rec Plant

5-24-2023: Rebuild #2 UV chamber and draining number two digester into #1 Drying bed

5-25-2023: Turned All drying beds, check N Hurley Lift Station Sweep and Mop Lab Building and wash TSS filters

5-30-2023: Turned All drying beds, Check N Hurley Lift Station and change out #3 bulb on #2 UV chamber

5-31-2023: Collect Water Samples and take to Silver UPS and check for a part in Silver at the hardware store and auto parts for UV system