

City of Bayard Wastewater Treatment Plant

Report for January 2023

1-02-2023: Change out 3 fans in #2 UV Electrical panel

1-03-2023: Turned the #1, and #3 drying beds.

1-04-2021: Collect all Water Samples and took to Silver City

1-05-2023: Turned the #1, and #3 drying beds, check N Hurley Lift Station, Hauled 2 loads of sludge to the Silver City landfill

1-09-2023: Turned the #1, and #3 drying beds, check N Hurley Lift Station

1-10-2023: Pick up all trash cans and take to Transfer Station

1-11-2023: Collect all Water Samples and took to Silver City, check N Hurley Lift Station, Hauled 2 loads of sludge to the Silver City landfill

1-12-2023: Hauled 3 loads of sludge to the Silver City landfill

1-16-2023: Turned the #1, and #3 drying beds, Staff filled up Chlorine tank in wash water building

1-17-2023: Sprayed and lubed bar screen, Dewatered the #2 digester.

1-18-2023: Collect all Water Samples and took to Silver City, check N Hurley Lift Station

1-19-2023: Alba Electric came out to Troubleshoot outlets on digesters

1-23-2023: Plant staff filled the acid tank for the #2 uv.

1-24-2023: Turned the #1, and #3 drying beds. Started to dewater the #3 digester.

1-25-2023: Dumped the #2, and #3 digesters to the #2 drying bed.

1-26-2023: Hauled 2 loads of sludge to the Silver City landfill

1-30-2023: Turned the #1, and #2 drying beds.

1-31-2023: Change out 4 fans in #1 UV Electrical panel