

## City of Bayard Wastewater Treatment Plant

### March 2022

03-01-2022: Plant staff cleaned the wash water screens in the washwater pump room.

03-02-2022: Plant staff checked all the fire extinguishers, filled the chlorine barrel in washwater pump room. Sprayed and lubed the influent headworks barscreen.

03-03-2022: Turned the #1, #2, and #3 drying beds.

03-07-2022: Plant staff rebuilt the #2 UV unit replacing the lamps and the sleeves.

03-08-2022: Turned the #1, #2, and #3 drying beds. Plant staff had to unclog and repair the screen on the shredder pump in the #1 digester. #1 digester had been down for 3 days trying to dewater it. The digester didn't dewater so it was brought back on line.

03-09-2022: Plant staff worked on repairing an acid leak in the UV room.

03-10-2022: Turned the #1, #2, and #3 drying beds. Plant staff worked on the sprayer system on the West side clarifier.

03-11-2022: Dement Alarms came down to the plant and replaced the front gate sensors.

03-14-2022: Pulled the sludge out of the #2 drying bed and added it to the sludge stockpile and turned the #1, and #3 drying beds.

03-15-2022: Plant Staff repaired sprayers on the West side clarifier. The North Hurley lift station had a high level alarm when plant staff went out to make the rounds at the lift station.

03-28-2022: Plant staff replaced the sampling hose on the sampling unit in the UV room.

03-29-2022: Turned the #1, #2, and #3 drying beds. Dement Electric came out to the plant and started to gut out the #4 aeration blower control cabinet.

03-30-2022: Dement Electric worked on the #4 aeration blower control cabinet.

03-31-2022: Dement Electric worked on the #4 aeration blower control cabinet. Turned the #1, #2, and #3 drying beds.