City of Bayard Wastewater Treatment Plant

November 2020

11-02-2020: Plant staff turned the #1 drying bed.

11-03-2020: Plant staff rebuilt the #1 UV chamber< the #4 aeration blower was picked up to be rebuilt.

11-04-2020: One of the plant staff was sent in for a Covid-19 test, rest of plant staff disinfected the lab, office and lunch room.

11-05-2020: Plant staff rebuilt the #3 drying bed, moved a polymer barrel to the ras/was room and started to dewater the #3 digester.

11-06-2020: Dumped the #1 digester to the #3 drying bed.

11-09-2020: Pulled sludge out of the #1 drying bed and added it to the stockpile, turned the #3 drying bed.

11-10-2020: Rebuilt the #2 drying bed.

11-12-2020: Leak on pipeline going out to Chino on mine side, called all contacts and informed them of the leak.

11-13-2020: Plant staff changed out the Greasezilla barrel at the North Hurley lift station.

11-16-2020: Rebuilt the #1 drying bed, turned the #3 drying bed.

11-17-2020: Plant staff made a trash run to the transfer station, set up the water sampler to make a test run for the upcoming 24-hour composite test.

11-18-2020: Plant staff lubricated the valve stems on the digester buckets.

11-19-2020: Plant staff Hauled dry sludge to the Silver City landfill.

11-23-2020: Turned the #1 and #2 drying beds.

11-24-2020: Plant staff tried to get the heater working in the effluent pump room but were unable to get it to come on.

11-30-2020: Plant staff turned the #1 and #2 drying beds, grease all electrical motors.