City of Bayard Wastewater Treatment Plant

November2021

11-01-2021: Plant staff turned the #2 and #3 drying beds and checked the pressure readings for the pressure test on the new dewatering building for the engineer.

11-02-2021: Started to dewater the #1 digester.

11-03-2021: Plant staff worked on a chlorine leak in the reclamation plant. #1 digester dewatered.

11-04-2021: Plant staff turned the #2 and #3 drying beds and repaired a light on the west side of the lab building.

11-05-2021: Plant staff changed out the De-sulphanator barrel at the North Hurley lift station.

11-08-2021: Cleaned out turbidity meter in the reclamation plant. Plant staff made a road for the engineer to get equipment in to do pot holing for the influent line project.

11-09-2021: Plant staff dug holes for the engineer for the influent line project.

11-10-2021: Plant staff changed out the drive belts for the #1 aeration blower. Chino Mines cane out and collected effluent samples.

11-15-2021: Plant staff turned the #1, #2, and #3 drying beds.

11-16-2021: Plant staff sprayed and lubed the headworks barscreen.

11-18-2021: Plant staff turned the #1, #2, and #3 drying beds.

11-20-2021: Plant staff turned the #1, #2, and #3 drying beds.

11-21-2021: Pulled out the #2 drying bed and dewatered the #3 digester.

11-22-2021: Dumped the #2 digester to the #2 drying bed. Finished dewatering the #3 digester. The #1 aeration blower started to kick itself off, plant staff had to force it to run on hand.
11-29-2021: Plant staff turned the #1, #2, and #3 drying beds.
11-30-2021: Plant staff installed #2 aeration blower and tried to bring it up on line but blower kicks itself out.