



CITY OF BAY CITY
1901 FIFTH STREET
BAY CITY, TEXAS 77414
(979) 245-2137
FAX: (979) 323-1626

AGENDA ITEM SUBMISSION FORM

Any item(s) to be considered for action by the City Council must be included on this form and be submitted along with any supporting documentation. Completed Agenda Item Submission forms must be submitted to the City Secretary's Office no later than 4:00 p.m. on the Monday of the week prior to the Regular Council meeting.

Requestor Name: Blomquist, Herbert **Date Submitted:** 1/3/2024
Last, First *MM/DD/YYYY*

Requestor Type: City Staff **Meeting Date:** 1/9/2024
Citizen/City Staff/Council Member *MM/DD/YYYY*

Position Title Director of Public Works
For City Staff Only

Agenda Location: Discussion Item
(e.g.: Consent Agenda/ Discussion Item/ Public Hearing/ Executive Session/ Presentation)

Agenda Content:

Discuss, consider, and/or approve the Contract Work Order No. 10 with Garver, LLC for Arsenic Treatment and Facility Rehabilitation detailed design and bidding phase services for the 6th Street and I Avenue Water Treatment Plant.

Executive Summary of Item:

The Drinking Water State Revolving Fund, authorized by the Safe Water Drinking Act, provides low-cost financial assistance for planning, acquisition, design, and construction of water infrastructure. Eligible applicants for the DWSRF include publicly and privately-owned community water systems, including nonprofit water supply corporations and non-profit non-community public water systems.

The City of Bay City is eligible for up to \$15,000,000 (Council authorized \$12 million) in funding from the Texas Water Development Board (TWDB) to make critical improvements to the City's water systems. These improvements will include upgrades to our existing water plants and to the water distribution system.

This agenda item is to approve a contract between the City of Bay City and Garver, LLC in the amount of \$985,016.00 to assist the City with design and bidding phase services for the 6th Street and I Avenue Water Plant project. The work includes an arsenic treatment system, improvements to the booster pump electrical system, upgraded instrumentation and controls, and disinfection conversion from the existing chlorine gas system to sodium hypochlorite treatment.

It is the staff's recommendation to approve Contract Work Order No.10 with Garver, LLC so the City can move forward with the 6th Street and I Avenue Water Plant arsenic treatment and facility rehabilitation project.