



Nancy Hoelzel <nancyh@chlniche.com>

Base elbow replacments

2 messages

Ned Benvenutti <ned@baymotorwinding.com>

Tue, Oct 21, 2025 at 2:20 PM

To: Nancy Hoelzel <nancyh@chlniche.com>, Tyler Kirby <tyler@chlniche.com>, Jason Chlniche <jason@chlniche.com>

Cc: Ronnie Vanney <rvanney@baystlouis-ms.gov>, Ned Benvenutti <ned@baymotorwinding.com>

Lift station that need base elbow replacement. Lift station 35,33,34. We cannot perform drawdowns or properly test the pump. These stations have all of the pumps installed but we can only run one. The damaged base elbows are causing the second pump to overload se we had to turn it to the off position.

Scope of work: Bypass station for duration of work. Remove pumps. Remove existing base elbows and attached vertical pipe. Provide and install new base elbow, guide claw, vertical pipe and full circle repair clamp. Re-use existing guide rails and guide bracket. Install pumps and test for proper operation.

Price per station.

Material:	\$12,650
By-pass	\$5200
<u>Labor</u>	<u>\$9500</u>
total	\$27,350

Thank you for your business,

Ned M. Benvenuto

Ned M. Benvenuto
P.O. Box 411
Long Beach, MS 39560
Office: 228-863-0677
Cell: 228-596-1677



Nancy Hoelzel <nancyh@chlnlche.com> Tue, Oct 21, 2025 at 2:53 PM
To: Ned Benvenuto <ned@baymotorwinding.com>
Cc: Tyler Kirby <tyler@chlnlche.com>, Jason Chinlche <jason@chlnlche.com>, Ronnie Vanney <rvanney@baystlouis-
ms.gov>, Ned Benvenuto <ned@baymotorwinding.com>

Good Afternoon,

Looks good for Change Order 1 - Elbows.

I will get it to you for signature soon. I will submit to the Council for approval at the November 4th meeting.

Sincerely,
Nancy Hoelzel
Project Manager



407 Hwy 90
Bay St. Louis, MS 39520
(228) 467-6755 Office
(228) 304-3771 Cell

[Quoted text hidden]