

1. **GENERAL.**
THE CONTRACTOR SHALL REMOVE ALL INFRASTRUCTURE AND VEGETATION FROM THE AREA TO BE EXCAVATED, FILLED, OR GRADED
ALL IMPROVEMENTS AND ADDITIONS TO THE WATER AND SANITARY SEWER SYSTEMS SHALL BE INSTALLED IN COMPLIANCE WITH THE CITY OF BAY ST. LOUIS STANDARDS.
TOPOGRAPHIC SURVEY INFORMATION TAKEN FROM A SURVEY PREPARED BY BAIRD ENGINEERING, INC.
2. **CLEARING.**
PRIOR TO CUT AND REPLACEMENT OF FILL ON SITE, APPROXIMATELY 6 INCHES OF TOP-SOIL SHOULD BE REMOVED WHERE ENCOUNTERED
REMOVE BRUSH, ROOTS, LARGE GRASS, ROCKS, AND WEEDS BEFORE STRIPPING
REMOVE TOPSOIL TO A MINIMUM DEPTH OF 6 INCHES IN ALL AREAS INDICATED ON THE PLANS TO BE UNDER BUILDING, DRIVES, PARKING, SIDEWALKS, AND OTHER PAVING.
STORE TOPSOIL APPROVED FOR FILL IN GENERAL LANDSCAPE AREAS AT DESIGNATED LOCATIONS ON SITE
3. **GRUBBING.**
REMOVE ASPHALT, CONCRETE CURBS, LIGHTING POLES AND FOUNDATIONS, TRASH, STUMPS, OLD LARGE STRUCTURES, ETC. FROM THE NEW SURFACE, OR BELOW THE GROUND WHICH MAY INTERFERE WITH THE NEW CONSTRUCTION.
4. **CLEAN-UP.**
UPON COMPLETION OF WORK OF THIS SECTION, REMOVE FROM PREMISES, AND DISPOSE OF ALL RELAND DEBRIS. IMPLEMENT EROSION CONTROL PLAN.

5. **SITE GRADING.**
PROFILING WITH A LOADED TRUCK OR SCRAPER SHOULD BE PERFORMED TO LOCATE EXISTING GRADE. ALL EXISTING GRADE SHOULD BE REMOVED AND REPLACED WITH SELECTED STABLE SANDY CLAY (CL). THE TOP 6 INCHES OF NATURAL GROUND SHOULD BE SCARIFIED AND COMPACTED TO 98 % ASTM D698 PRIOR TO FILL PLACEMENT.
CUT OR FILL AND MACHINE GRADE SITE AS SHOWN ON THE DRAWINGS TO DRAIN AS INDICATED, ALLOWING FOR THE THICKNESS OF PAVING SUBGRADE AND THE PAVING ITSELF. WHERE FILL IS REQUIRED, USE PER GEOTECHNICAL REPORT.
ALL EARTHWORK SHALL BE IN ACCORDANCE WITH THE GEOTECHNICAL INVESTIGATION REPORT.
ALL FILL MATERIALS DESCRIBED IN GEOTECHNICAL REPORT MUST BE REMOVED AND REPLACED WITH ACCEPTABLE FILL MATERIAL.
6. **FILLING AND BACKFILLING MATERIALS.**
IMPORTED FILL MATERIAL WILL HAVE PROPERTIES TO ALLOW COMPACTION BY ROLLING AND TAMPING TO A DENSITY EQUAL TO 95% OF MAXIMUM DENSITY WITH 42% OF OPTIMUM MOISTURE CONTENT AS DETERMINED BY TEST METHODS DESCRIBED IN ASTM D698, LATEST EDITION. "MOISTURE DENSITY RELATIONSHIP OF SOILS". IF EXCAVATED MATERIAL IS SUBMITTED FOR COMPACTION AS DETERMINED BY THE SOILS TESTING LABORATORY, IT SHALL BE PROVED TO THE CITY OF BAY ST. LOUIS STANDARDS. ALL EXCAVATED FILL AND BACKFILL MATERIALS SHALL BE OF LOW EXPANSIVITY, UNIFORM IN GRADE, FREE FROM ORGANIC MATERIAL, AND CONSIST OF SILTY CLAY (CL) SOIL HAVING A LIQUID LIMIT OF NOT MORE THAN 40 PERCENT AND A PLASTICITY INDEX BETWEEN 10 AND 20.



GRADING PLAN
WEBSTER STREET DRAINAGE
BAY ST. LOUIS, MISSISSIPPI

BAIRD ENGINEERING, INC.

506 Jefferson Street, Clinton, MS 39056
Phone: (601) 925 - 5015

No.	Revisions:	By:	Date:

Project No.:
5181
Date:
07/15/2026
Scale:
1" = 20'
Designed By:
CLB
Reviewed By:
CLB

C 2.0