

## STEPHENS MECHANICAL ENGINEERING, LLC Mechanical Engineering HVAC, Plumbing, Fire Protection

925 Tommy Munro Dr., Ste B Biloxi, MS 39532 Phone: (228) 207 3322 fax: (228) 207 3346 les@stephensmecheng.com

## Field Report

To: City of Bay St. Louis Location: Bay St. Louis, Ms

Address: Bay St. Louis, Mississippi Contractor: D.N.P., Inc.

39520 **Weather:** Clear 58 F

**Present On Site:** General Contractor

Re: Add Cooling Tower at Date: 1/13/2025 Time: 1:00 pm

Central Fire House

Final Completion walk through on 1/13/2025

Project met minimum requirements See below items:

Present on Site: Ronnie Vanney, Lawrence Stephens, Patrick DNP, and myself.

- 1. All previously noted items were addressed and corrections have been made at this time.
- 2. Note that freeze protection for the tower and boiler is operational. Verified through control system.
- 3. Water pump auto rotation of the lead lag pumps set to alternate weekly by control system.
- 4. No other issues were noted or discussed at this time.

Copies to: file Field Report No. 23056 FR.002

**Tony Moran** 

Cell (228) 860-8764

tony@stephensmecheng.com