

ARTICLE II. ELECTRICAL CODE

Sec. 12-25 -Standards for material, equipment and installation.

- (a) All electrical equipment installed or used shall be reasonably safe to persons and property and in conformity with the provisions of this article, the applicable statutes of the state and any orders, rules or regulations issued by the authority thereof. Conformity with the applicable standards of the Underwriters' Laboratories, Inc., shall be prima facie evidence that such equipment is reasonably safe to persons and property.
- (b) The use of aluminum alloy wire in a feeder line is permitted: this includes both interior and exterior premise service panel to sub panel only. The ampacity of aluminum conductor must conform to the intended amperage of sub panel feeder circuit. The cable will be manufactured in the United States and adhere to industry standards that regulate product quality such as Underwriters Laboratory and the National Electric Code. Terminations will be a listed device, rated for terminations with aluminum cable.

Secs. 12-26—12-53. Reserved.