

CITY OF BEAUMONT

2021

WASTEWATER MASTER PLAN

Draft

August 2021







August 24, 2021

City of Beaumont 550 E 6th Street Beaumont, CA 92223

Attention: Jeff Hart, P.E. Public Works Director

Subject: 2021 Wastewater Master Plan – Draft Report

Dear Jeff:

We are pleased to submit the draft report for the City of Beaumont Wastewater Master Plan. The master plan documents the following:

- Existing wastewater system facilities, acceptable hydraulic performance criteria, and projected wastewater flows consistent within the City's service area.
- Development and calibration of the City's GIS-based wastewater collection system hydraulic model.
- Capacity evaluation of the existing wastewater collection system with improvements to mitigate existing deficiencies and to accommodate future growth.
- Capital Improvement Program (CIP) with an opinion of probable construction costs.

We extend our thanks to you; Jeff Hart, Public Works Director; Kristine Day, Assistant City Manager; Thaxton Van Belle, Chief Plant Operator; Kevin Lee, Wastewater Plant Supervisor; and other City staff whose courtesy and cooperation were valuable components in completing this study.

Sincerely,

AKEL ENGINEERING GROUP, INC.

Tony Akel, P.E. Senior Principal Enclosure: Report



Acknowledgements

City Council

Mike Lara, Mayor Lloyd White, Mayor Pro Tempore David Fenn Julio Martinez Rey Santos

Management Personnel

Todd Parton, City Manager Kristine Day, Assistant City Manager Jeff Hart, Public Works Director Thaxton Van Belle, Chief Plant Operator Kevin Lee, Wastewater Plant Supervisor Other City Engineering, Planning, and Operations Staff

TABLE OF CONTENTS

PAGE NO.

IVE SUMMARY	
SYSTEM PERFORMANCE AND DESIGN CRITERIA	ES-3
EXISTING WASTEWATER COLLECTION SYSTEM OVERVIEW	ES-6
ACKNOWLEDGEMENTS	1-4
GEOGRAPHIC INFORMATION SYSTEMS	1-7
	2.1
	····· ∠- I 2 1
R 3 - SYSTEM PERFORMANCE AND DESIGN CRITERIA	3-1
HYDRAULIC CAPACITY CRITERIA	3-1
3.1.1 Gravity Mains	3-1
3.1.2 Force Mains and Lift Stations	3-5
DRY WEATHER FLOW CRITERIA	3-5
3.2.1 Unit Flow Factors Methodology	3-6
3.2.3 Peaking Factors	
WET WEATHER FLOW CRITERIA	3-9
5	
- , -	
4.2.9 Pennsylvania Collection Basin	4-6
	STUDY OBJECTIVES

TABLE OF CONTENTS

PAGE NO.

	4.2.10 Highland Springs Collection Basin	
	4.2.11 Seneca Springs Collection Basin	
4.3	4.2.12 Four Seasons Collection Basin	
4.3 4.4	BEAUMONT WASTEWATER TREATMENT PLANT	
		-
CHAPT	ER 5 –WASTEWATER FLOWS	5-1
5.1	FLOWS AT THE BEAUMONT WWTP	
5.2	BUILDOUT WASTEWATER FLOWS	
5.3	WASTEWATER COLLECTION SYSTEM DESIGN FLOWS	5-4
CHAPT	ER 6 - HYDRAULIC MODEL DEVELOPMENT	6-1
6.1	HYDRAULIC MODEL SOFTWARE SELECTION	
6.2	HYDRAULIC MODEL DEVELOPMENT	
-	6.2.1 Skeletonization	
	6.2.2 Digitizing and Quality Control	
	6.2.3 Pipes and Manholes	
	6.2.4 Load Allocation	
6.3	MODEL CALIBRATION	6-5
	6.3.1 Calibration Plan	
	6.3.2 2020 V&A Temporary Flow Monitoring Program	6-5
	6.3.3 Dynamic Model Calibration	
	6.3.4 Use of the Calibrated Model	6-9
CHAPT	ER 7 - EVALUATION AND PROPOSED IMPROVEMENTS	7-1
7.1	OVERVIEW	
7.2	EXISTING SYSTEM CAPACITY EVALUATION	
	7.2.1 Existing Peak Dry Weather Flows Capacity Evaluation	
	7.2.2 Existing Peak Wet Weather Flows Capacity Evaluation	
7.3	BEAUMONT MESA LIFT STATION SPECIAL STUDIES	
	7.3.1 Lift Station As-Built Preparation	7-4
	7.3.2 Offline Force Main Exploration	7-4
	7.3.3 Wet Well Capacity Expansion	
7.4	BEAUMONT MESA LIFT STATION OPERATION	
7.5	OTHER SPECIAL STUDIES	
	7.5.1 Fairway Canyon Preliminary Design Report (PDR) Review	
	7.5.2 Wastewater Hydraulic Analysis for McClure Industrial Building	
7.6	LIFT STATION ASSESSMENT.	
	7.6.1 Fairway Canyon Lift Station	
	7.6.2 Lower Oak Valley Lift Station	
	7.6.3 Upper Oak Valley Lift Station	
	7.6.4 Olivewood Lift Station	
	7.6.5 Beaumont Mesa Lift Station	
	7.6.6 Noble Creek Lift Station	
	7.6.7 Marshall Creek Lift Station	
	7.6.8 Industrial Park Lift Station	
	7.6.9 Seneca Springs Lift Station	
	7.6.10 Four Seasons Lift Station	1-15

TABLE OF CONTENTS

PAGE NO.

7.7	ULTIMA	ATE BUILD	OUT CAPACITY IMPROVEMENTS	7-16
	7.7.1	Lift Statio	n Capacity Improvements	7-16
	7.7.2		in Improvements	
	7.7.3		ain Improvements	
		7.7.3.1	Lower Oak Valley	
		7.7.3.2	Upper Oak Valley	7-25
		7.7.3.3	Olivewood	7-26
		7.7.3.4	Brookside Avenue	7-26
		7.7.3.5	Beaumont Mesa	7-26
		7.7.3.6	Beaumont Crossroads	7-26
		7.7.3.7	Industrial Park	7-27
		7.7.3.8	Beaumont Avenue South	
		7.7.3.9	Wastewater Treatment Plant	7-27
		7.7.3.10	Four Seasons	7-29
СНАРТЕ	R 8 - CA	PITAL IMP	ROVEMENT PROGRAM	8-1
8.1			ACCURACY	
8.2			METHODOLOGY	
	8.2.1		5	
	8.2.2		ion Cost Index	
	8.2.3	Land Acq	uisition	8-2
	8.2.4	Construct	ion Contingency Allowance	8-2
	8.2.5		elated Costs	
8.3	LIFT ST	TATION CO	NDITION ASSESSMENT COSTS	8-4
8.4	CAPITA	AL IMPROV	EMENT PROGRAM	8-4
	8.4.1	Capital Im	provement Costs	8-4
	8.4.2	Pipelines.		8-4
	8.4.3	Improvem	ent Service Location	8-13
	8.4.4		ion Triggers	
8.5	10-YEA	R IMPROV	EMENT PHASING	8-15

TABLE OF CONTENTS

PAGE NO.

FIGURES

Figure ES.1	Regional Location Map	ES-2
Figure ES.2	Service Area	ES-4
Figure ES.3	Sewer Collection Basins	ES-7
Figure ES.4	Capital Improvement Program	ES-10
Figure 1.1	Regional Location Map	. 1-2
Figure 2.1	Service Area	2-2
Figure 2.2	Existing Land Use	2-3
Figure 2.3	General Plan Land Use	.2-6
Figure 2.4	Specific Plans and Other Developments	2-7
Figure 3.1	Hydraulic Model Diurnals	. 3-10
Figure 3.2	Hydraulic Model Diurnals	. 3-11
Figure 3.3	Hydraulic Model Diurnals	. 3-12
Figure 3.4	Hydraulic Model Diurnals	. 3-13
Figure 3.5	Infiltration and Inflow Sources	. 3-14
Figure 3.6	Flow Monitoring Locations	
Figure 3.7	10-Year 24-Hour Storm (Design vs. Historical Storms)	3-20
Figure 4.1	Existing Wastewater Collection System	4-2
Figure 4.2	Sewer Collection Basins	
Figure 4.3	Lift Station Connectivity Schematic	. 4-8
Figure 5.1	2019 WWTP Flows	5-2
Figure 5.2	Future Development Flow Allocation	5-5
Figure 6.1	Existing Modeled Sanitary Sewer System	6-3
Figure 6.2	Flow Monitor Locations	6-6
Figure 6.3	Site-3 Calibration	6-10
Figure 6.3	Site-7 Calibration	
Figure 7.1	Existing Modeled System Analysis for PDWF	.7-2
Figure 7.2	Existing Modeled System Analysis for PWWF	.7-3
Figure 7.3	Potential Wet Well Expansion	.7-6
Figure 7.4	Recommended Improvements	.7-17
Figure 7.5	Future Modeled System Analysis for PDWF	.7-18
Figure 7.6	Future Modeled System Analysis for PWWF	.7-19
Figure 8.1	Capital Improvement Program	. 8-5

TABLE OF CONTENTS

PAGE NO.

TABLES

Table ES.1	Wastewater System Performance and Design Criteria	ES-5
Table ES.2	Unit Costs	
Table ES.3	Capital Improvement Program	ES-12
Table 1.1	Unit Conversions	1-5
Table 1.2	Abbreviations and Acronyms	1-6
Table 2.1	Existing and Future Land Use	2-4
Table 2.2	Specific Plans and Other Developments, total Development Area	2-8
Table 2.3	Specific Plans and Other Developments, Remaining Development Area	2-9
Table 2.4	Specific Plans and Other Developments, Remaining Development Flows	2-10
Table 2.5	Historical and Projected Population	
Table 3.1	Wastewater System Performance and Design Criteria	3-4
Table 3.2	Existing Wastewater Flows by Land Use Classification	
Table 3.3	Wastewater Unit Flows for Projecting Future Flows	3-7
Table 3.4	Precipitation Depth-Duration-Frequency	3-17
Table 3.5	Storm Events Analysis	3-18
Table 4.1	Existing Wastewater Pipe Inventory	4-4
Table 4.2	Lift Station Inventory	
Table 5.1	Wastewater Treatment Plant – Historical Flow Data and Peaking Factors	5-3
Table 5.2	Future Wastewater Flow Summary	5-6
Table 5.3	Design Flows	5-8
Table 6.1	Existing Modeled Pipe Inventory	6-4
Table 6.2	Flow Monitor Locations	6-7
Table 6.3	Calibration Results Summary	6-8
Table 7.1	Beaumont Mesa LS – Estimated Time to Spill	7-7
Table 7.2	Potential Beaumont Mesa Wet Well Expansion	
Table 7.3	Lift Station Capacity Analysis	7-10
Table 7.4	Force Main Capacity Analysis	7-11
Table 7.5	Schedule of Improvements	7-20
Table 8.1	Unit Costs	
Table 8.2	Lift Station Condition Assessment Improvements	8-6
Table 8.3	Capital Improvement Program	8-8
Table 8.4	10-Year Improvement Phasing	8-14

APPENDICES

Sewer Flow Monitoring and Inflow/Infiltration Study, 2020 (V&A)
Hydraulic Model Calibration Exhibits
Beaumont Mesa Lift Station Dry Well Grading Plan – Prepared by Cannon
Beaumont Mesa Force Main Pothole Report – Prepared by C-Below
Fairway Canyon Preliminary Design Report (PDR) Review Memorandum
Wastewater Hydraulic Analysis for McClure Industrial Building
Lift Station Condition Assessment – Prepared by V&A
Capital Improvement Program Project Sheets



EXECUTIVE SUMMARY

This executive summary provides a brief background of the City of Beaumont's (City) wastewater collection system, the planning area characteristics, the planning and design criteria, and the hydraulic model development.

The hydraulic model was used to evaluate the capacity adequacy of the existing wastewater collection system and for recommending improvements to mitigate existing deficiencies and for servicing future growth. The prioritized capital improvement program accounts for growth through the Beaumont Planning Area.

ES.1 STUDY OBJECTIVES


Recognizing the importance of planning, developing, and financing system facilities to provide reliable wastewater service to existing customers and for servicing anticipated growth within the sphere of influence, the City initiated the development of the 2021 Wastewater Master Plan.

This master plan includes the following tasks:

- Summarize the City's existing wastewater collection system facilities.
- Document growth planning assumptions and known future developments.
- Summarize the wastewater system performance criteria and design storm event.
- Project future wastewater flows.
- Develop and calibrate the physical characteristics of the hydraulic model (gravity mains, force mains, and lift stations).
- Evaluate the adequacy of capacity for the wastewater collection system facilities to meet existing and projected peak dry weather flows and peak wet weather flows.
- Recommend a capital improvement program (CIP) with an opinion of probable construction costs.
- Develop a 2021 Wastewater Master Plan Report.

ES.2 STUDY AREA DESCRIPTION

The City of Beaumont is located in Riverside County on the southern portion of California, east of the City of Banning. The City is located approximately 11 miles north of the City of Hemet, 5 miles east of the City of Banning, 12 miles east of City of Monero Valley, and 7 miles southeast of the City of Yucaipa. The City currently encompasses an area greater than 26,000 acres, with an approximate population of 50,000 residents. Figure ES.1 displays the City's location.



The City's service area is generally bound to the north by Brookside Avenue, to the east by Highlands Springs Avenue, and to the southwest of Monero Valley Freeway. The topography is generally steep, with slopes increasing from north to south toward the Interstate 10. Figure ES.2 displays the City's existing service area and the general plan boundary.

The City operates and maintains a wastewater collection system that covers the majority of the developable area within Planning Boundary. Currently, the wastewater flows are conveyed to the City of Beaumont Wastewater Treatment Plant (WWTP).

ES.3 SYSTEM PERFORMANCE AND DESIGN CRITERIA

Gravity main capacities depend on several factors including: material and roughness of the pipe, the limiting velocity and slope, and the maximum allowable depth of flow. The hydraulic modeling software used for evaluating the capacity adequacy of the City's wastewater collection system, InfoSWMM by Innovyze Inc., utilizes the fully dynamic St. Venant's equation which has a more accurate engine for simulating backwater and surcharge, in addition to manifolded force mains. The software also incorporates the use of the Manning Equation in other calculations including upstream pipe flow conditions.

Partial Flow Criteria (d/D)

Partial flow in gravity sewers is expressed as a depth of flow to pipe diameter ratio (d/D). For circular gravity conduits, the highest capacity is generally reached at 92 percent of the full height of the pipe (d/D ratio of 0.92). This is due to the additional wetted perimeter and increased friction of a gravity pipe.

When designing wastewater pipelines, it is common practice to use variable flow depth criteria that allow higher safety factors in larger sizes. Thus, design d/D ratios may range between 0.5 and 0.92, with the lower values used for smaller pipes. The smaller pipes may experience flow peaks greater than planned or may experience blockages from debris. The City's design standards pertaining to the d/D criteria are summarized in Table ES.1.

During peak dry weather flows (PDWF), the maximum allowable d/D ratio for gravity pipelines are summarized as follows:

- 12-inch diameter and smaller: 0.50
- 15-inch diameter and larger: 0.70

During peak wet weather flows (PWWF), the maximum allowable d/D ratio for proposed pipes (all diameters) is 0.75. The maximum allowable d/D ratio for all existing pipes (all diameters) is 1.00. The criterion for existing pipes is relaxed in order to maximize the use of the existing pipes before costly pipes improvements are required. This condition is evaluated using the dynamic hydraulic model and the criteria listed on Table ES.1.




Table ES.1 Wastewater System Performance and Design Criteria Wastewater Master Plan **City of Beaumont**

	PRELIMINARY									
Dry Wea	ther Flow Criteria									
Sewer Trunk	d/D									
Diameter < 15 inches	0.50									
Diameter ≥ 15 inches	0.70									
Wet Wea	ather Flow Criteria									
Sewer Trunk	d/D									
Existing System	1.00									
Future System	0.75									
Pipe Slope Criteria										
Pipe Size	Minimum Slope (ft/ft)									
8"	0.004									
10"	0.0032									
12"	0.0024									
15"	0.0016									
18"	0.0014									
21"	0.0012									
24" and Up	0.001									
Pipe \	/elocity Criteria									
Ріре Туре	Minimum / Maximum Velocity (fps)									
Gravity Sewer	Minimum 2 / Maximum 10									
Force Main	Desired 2 to 6.5 / Maximum 10									
ENGINEERING GROUP, INC.	3/2/2021									

Notes:

1. Source: Eastern Municipal Water District Wastewater Collection System Master Plan

2. Wastewater Collection System performance criteria shall be in accordance with EMWD WCSMP.

ES.4 EXISTING WASTEWATER COLLECTION SYSTEM OVERVIEW

The City provides wastewater collection services to approximately 15,671 residential, commercial, public facilities and institutional accounts. rThe City's existing wastewater collection system consists of approximately 196 miles of gravity mains and force mains, and 10 lift stations that convey flows to the City's WWTP.

The City's existing wastewater collection system is shown in **Figure ES.3**, which displays the existing system by pipe size. This figure provides a general color coding for the collection mains, as well as labeling the existing lift stations.

ES.5 WASTEWATER FLOWS

The wastewater flows collected and treated at the City of Beaumont WWTP vary monthly, daily, and hourly. While the dry weather flows are influenced by customer uses, the wet weather flows are influenced by severity of storm events and the condition of the system.

Flow data influent to the City of Beaumont WWTP was obtained from City operation staff. The flow data covered a period from 2012 to 2019. From this data monthly, daily, and peak daily flows, were determined.


The land use methodology was used to estimate the buildout wastewater flows from City's Planning Area and to be consistent with the General Plan. The undeveloped lands were multiplied by the corresponding unit flow factor to estimate the wastewater flows. The buildout average daily flows were calculated at 17.8 mgd.

ES.6 HYDRAULIC MODEL DEVELOPMENT AND CALIBRATION

The City's hydraulic model combines information on the physical characteristics of the wastewater collection system (pipelines, manholes, and lift stations) and operational characteristics (how they operate). The hydraulic model then performs calculations and solves series of equations to simulate flows in pipes, including backwater calculations for surcharged conditions.

There are several network analysis software products released by different manufacturers that can equally perform the hydraulic analysis satisfactorily. The selection of a particular software depends on user preferences, the wastewater collection system's unique requirements, and the costs for purchasing and maintaining the software.

The hydraulic modeling software used for evaluating the capacity adequacy of the City's wastewater collection system, InfoSWMM by Innovyze Inc., utilizes the fully dynamic St. Venant's equation which has a more accurate engine for simulating backwater and surcharge conditions, in addition to having the capability for simulating manifolded force mains. The software also incorporates the use of the Manning Equation in other calculations including upstream pipe flow conditions. The St Venant's and Manning's equations are discussed in the System Performance and Design Criteria chapter.



Model Development

The hydraulic model for the City of Beaumont was skeletonized to include the pipelines essential to the hydraulic analysis. By comparison, skeletonizing was necessary to reduce the model from 4,300 pipes extracted from GIS to 800 pipes; the total system includes approximately 196 miles of pipe, whereas the hydraulic model includes approximately 56 miles of pipelines. Skeletonizing the model is useful in creating a system that accurately reflects the hydraulics of the pipes within the system while reducing the complexities of large models. This process reduces the time of analysis while maintaining accuracy, but will also comply with the limitations imposed by the computer program. The modeled pipes included pipes 8-inches in a diameter and larger, in addition to some critical smaller gravity wastewater pipes. The inventory pipelines included in the hydraulic model is approximately 28 percent of the overall system.

Model Calibration

Calibration can be performed for steady state conditions, which model the peak hour flows, or for dynamic conditions (24 hours or more). Dynamic calibration consists of comparing the model predictions to diurnal operational changes in the wastewater flows. The City's hydraulic model was calibrated for dynamic conditions.

In wastewater collection systems, and when using dynamic hydraulic modeling to evaluate the impact of wet weather flows, it is common practice to calibrate the model to the following three conditions:

- Peak dry weather flows.
- Peak wet weather flows from storm rainfall Event No. 1(12 March 2020 -13 March 2020)
- Peak wet weather flows from storm rainfall Event No. 2(9 March 2020 10 March 2020)

After the model is calibrated to these conditions, it is benchmarked and used for evaluating the capacity adequacy of the wastewater collection system, under dry and wet weather conditions. The model was also used to identify improvements necessary for mitigating existing system deficiencies and for accommodating future growth.

The hydraulic model is a valuable investment that will continue to prove its worth to the City as future planning issues or other operational conditions surface. It is recommended that the model be maintained and updated with new construction projects to preserve its integrity.

ES.7 CAPACITY EVALUATION

The system performance and design criteria were used as a basis to judge the adequacy of capacity for the existing wastewater collection system. The design flows simulated in the hydraulic model for existing conditions and are listed as follows:

- Existing PDWF = 9.3 mgd
- Existing PWWF = 9.8 mgd

During the peak dry weather simulations, the maximum allowable pipe d/D criteria for gravity pipelines (0.50 for wastewater mains less than or equal to 12-inch or, 0.70 for wastewater mains greater than 12-inch) was used. During the peak wet weather simulations, the existing wastewater mains are allow to reach the full capacity of 1.0 while the future wastewater mains are allow to 75 percent full.

In general, the hydraulic model indicated that the wastewater collection system exhibited acceptable performance to service the existing customers during both peak dry weather flows and peak wet weather flows. Future flows were then added to the hydraulic model and the existing system was expanded in order to serve these future customers. The proposed improvements for the future system are shown with pipe sizes on an overall exhibit on Figure ES.4.

ES.8 CAPITAL IMPROVEMENT PROGRAM

The Capital Improvement Program includes pipeline and lift station improvements recommended in this master plan (Table ES.3). Each improvement was assigned a uniquely coded identifier associated with its tributary area. The baseline costs for pipelines and lift stations are shown in Table ES.2. Improvements are shown in Figure ES.4.

The estimated costs include the baseline costs plus **20 percent** contingency allowance to account for unforeseen events and unknown field conditions. Capital improvement costs include the estimated construction costs plus **30 percent** project related costs (engineering design, project administration, construction management and inspection, and legal costs).

The costs in this Wastewater Master Plan were benchmarked using a 20-City national average ENR CCI of 11,849, reflecting a date of April 2021. In total, the CIP includes approximately 23 miles of gravity mains and force mains, on-going CCTV Program, lift station condition assessment, as well as wastewater treatment plant improvements with a cost totaling over \$99 million dollars.




Table ES.2 Unit Costs

Wastewater Master Plan City of Beaumont

PRELIMINARY

Pipeline	PRELIMINARY
Gravity Main ¹	
Pipe Size	Cost ¹
(in)	(\$/lineal foot)
8	\$191
10	\$200
12	\$208
15	\$230
18	\$247
21	\$331
24	\$396
27	\$468
30	\$526
36	\$670
Force Main ¹	
6	\$216
8	\$264
10	\$278
16	\$376
Operational and Maintenance ²	
Sewer Pipeline CCTV	\$2.10
Sewer Pipeline Cleaning	\$1.80
Lift Station ³	
Estimated Lift Station Project Cost 314,097*Q + 365,718, where C	
ENGINEERING GROUP, INC.	5/21/2021

Notes :

- 1. Unit costs indexed using the Engineering News Record (ENR) Construction Cost Index of 11,849 for April 2021.
- 2. Sewer pipeline operational and maintenance costs based on Akel Engineering Group experience on similar projects.
- 3. Lift Station costs based on Akel Engineering Group experience on similar projects and escalated using the Engineering News Record (ENR) Construction Cost Index of 11,849 for April 2021.

Wastewater Master Plan

City of Beaumont

	City of Beaumor							1		1				PRELIMINARY
Type of					Improvements Details				cture Costs	Pacalina Constr	Estimated Const.	Capital Impro.	Future Flow	
Improv. No.	Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Cost	Cost ¹	Cost ^{2,3}	Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Lower Oak	Valley Lift Statio	n Tributary Area												
Gravity Mair	Improvements							1		I.			1	
LOV-P1	Future Capacity Increase	Irwin St	From Floyd Cir to Palmer Ave	15	Replace	18	525	247	129,621	129,700	155,700	202,500	Within City Limit	Approximately 200 EDUs
Lift Station I	nprovements													
LOV-LS	Lift Station Replacement	Lower Oak Valley Lift St	ation	-	Replace	3 @ 62	25 gpm	-	1,284,238	1,284,300	1,541,200	2,003,600	Within City Limit	Approximately 260 EDUs
				Subtot	al - Lower Oal	k Valley Lift S	tation Tribu	utary Area Im	provements	1,414,000	1,696,900	2,206,100		
Tukwet Car	iyon (New) Lift S	tation Tributary Area												
Force Main I	mprovements													
TC-FM1	New Force Main	Sorenstam Dr/Price St	From Tukwet Canyon lift station to approx. 1,000' n/o Upper Oak Valley lift station	-	New	8	6,250	264	1,652,656	1,652,700	1,983,300	2,578,300	Within City Limit	As Development Occurs
TC-FM2	New Force Main	Sorenstam Dr/Price St	From Tukwet Canyon lift station to approx. 1,000' n/o Upper Oak Valley	-	New	8	6,250	264	1,652,656	1,652,700	1,983,300	2,578,300	Within City Limit	As Development Occurs
Lift Station I	nprovements		lift station										1	
TC-LS		Tukwet Canyon Lift Stat	ion	-	New	3@37	′5 gpm	-	899,920	900,000	1,080,000	1,404,000	Within City Limit	As Development Occurs
				Subtotal - T	ukwet Canyoi	n (New) Lift S	tation Tribu	utary Area Im	provements	4,205,400	5,046,600	6,560,600		
Upper Oak	Valley Lift Statio	n Tributary Area								I				
Gravity Mair	Improvements													
UOV-P1	Future Capacity Increase	Straightaway Dr	From Balata St to 350' sw/o Balata St	8	Replace	10	350	200	69,910	70,000	84,000	109,200	Within City Limit	Approximately 70 EDUs
UOV-P2	Existing Capacity Deficiency	Apron Ln	From Stableford Ct to Oak Valley Pkwy	8	Replace	12	300	208	62,342	62,400	74,900	97,400	Within City Limit	FY 2023/24
UOV-P3	Future Capacity Increase	Oak Valley Pkwy	From Apron Ln to 2,450' w/o Apron Ln	12	Replace	15	2,500	230	575,740	575,800	691,000	898,300	Within City Limit	Approximately 1,360 EDUs
Lift Station I	mprovements							1		1				
UOV-LS	Lift Station Replacement	Upper Oak Valley Lift St	ation	-	Replace	3 @ 1,8	50 gpm	-	3,493,305	3,493,400	4,192,100	5,449,800	Within City Limit	Approxiamtely 2,360 EDUs
	·			Subtot	al - Upper Oal	k Valley Lift S	tation Tribu	utary Area Im	provements	4,201,600	5,042,000	6,554,700		
Olivewood	Lift Station Tribu	itary Area												
Gravity Mair	Improvements													
O-P1	Future Capacity Increase	ROW	From Artisan Pl to approx. 500' n/o Artisan Pl	10	Replace	12	525	208	109,099	109,100	131,000	170,300	Within City Limit	Approximately 750 EDUs
Lift Station I	mprovements							1					1	
O-LS	Lift Station Replacement	Olivewood Lift Station		-	Replace	2@65	50 gpm	-	987,577	987,600	1,185,200	1,540,800	Within City Limit	Approximately 710 EDUs
				:	Subtotal - Oliv	vewood Lift S	tation Tribu	utary Area Im	provements	1,096,700	1,316,200	1,711,100		

Wastewater Master Plan

City of Beaumont

	City of Beaumor	IT												PRELIMINARY
			Improvements Details				Infrastruc	ture Costs		Fatimated Const	Conital Image			
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Capital Impro. Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
		t Station Tributary Are	28											
Gravity Mai	n Improvements		From 480' w/o Deodar Dr to					1						
BR-P1	New Capacity	Brookside Ave	Brookside Ave lift station	-	New	8	2,200	191	420,656	420,700	504,900	656,400	Within City Limit	As Development Occurs
Force Main	Improvements							1					1	
BR-FM1	New Force Main	Brookside Ave	From Brookside Ave lift station to Deodar Dr	-	New	6	2,825	216	609,832	609,900	731,900	951,500	Within City Limit	As Development Occurs
Lift Station I	Improvements							1						
BR-LS	New Lift Station	Brookside Ave Lift Stati	ion	-	New	2 @ 30	0 gpm	-	644,313	644,400	773,300	1,005,300	Within City Limit	As Development Occurs
			S	ubtotal - Broo	okside Avenu	e (New) Lift St	ation Tribu	itary Area Im	provements	1,675,000	2,010,100	2,613,200		
Beaumont	Mesa Lift Station	Tributary Area						1		I			1	
Gravity Mai	n Improvements													
BM-P1	New Capacity	ROW	From 800' n/o Monero Valley Fwy to 2,600' e/o Potrero Blvd	-	New	8	2,575	191	492,359	492,400	590,900	768,200	Within City Limit	As Development Occurs
BM-P2	New Capacity	ROW	From 2,600' e/o Potrero Blvd to 1,400' s/o Oak Valley Pkwy	-	New	10	1,600	200	319,588	319,600	383,600	498,700	Within City Limit	As Development Occurs
BM-P3	New Capacity	ROW	From 1,400' s/o Oak Valley Pkwy to Beaumont Mesa lift station	-	New	15	2,350	230	541,196	541,200	649,500	844,400	Within City Limit	As Development Occurs
Force Main	Improvements ⁵							1		I			1	
BM-FM1	Force Main Desi	gn and Pump Design		-	New			-	-	-	-	450,000	Within City Limit	FY 2021/22
BM-FM1	New Force Main	Potrero Blvd/Western Knolls Ave	From Beaumont Mesa lift station to 1,300' w/o Western Knolls Ave	-	New	16	6,500	-	-	-	-	4,000,000	Within City Limit	FY 2022/23
Lift Station I	Improvements ⁵							1						
BM-LS	Pump Replacem	ent/Addition Constructio	on	-	New	2 @ 3,50 2 @ 1,50		-	-	-	-	750,000	Within City Limit	FY 2022/23
BM-WW	Wet Well Design	I		-	New			-	-	-	-	400,000	Within City Limit	FY 2021/22
BM-WW	New Wet Well			-	New			-	-	-	-	4,000,000	Within City Limit	FY 2024/25
				Subto	tal - Beaumoi	nt Mesa Lift St	ation Tribu	itary Area Im	provements	1,353,200	1,624,000	11,711,300		
Beaumont	Crossroads (New) Lift Station Tributary	/ Area											
Gravity Mai	n Improvements													
BC-P1	New Capacity	W 4th St	From 1,875' s/o Moreno Valley Fwy to Beaumont Crossroads lift station	-	New	15	3,125	230	719,676	719,700	863,700	1,122,900	Within City Limit	As Development Occurs
BC-P2	New Capacity	W 4th St	From 275' w/o of Prosperity Way to 400' e/o Potrero Blvd	-	New	12	2,100	208	436,397	436,400	523,700	680,900	With Annexation	As Development Occurs
BC-P3	New Capacity	W 4th St	From 400' e/o Potrero Blvd to Potrero Blvd	-	New	15	375	230	86,361	86,400	103,700	134,900	With Annexation	As Development Occurs
BC-P4	New Capacity	W 4th St	From Potrero Blvd to 1,350' w/o Potrero Blvd	-	New	18	1,450	247	358,001	358,100	429,800	558,800	With Annexation	As Development Occurs
BC-P5	New Capacity	W 4th St	From 1,350' w/o Potrero Blvd to Beaumont Crossroads lift station	-	New	21	800	331	264,625	264,700	317,700	413,100	With Annexation	As Development Occurs

Wastewater Master Plan

City of Beaumont

	City of Beaumor							1						PRELIMINAR
Turn of			Improvements Details				Infrastruc	ture Costs		Estimated Const	Conital Impro			
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Force Main	Improvements			1				1					1	
BC-FM1	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	16	9,175	376	3,447,614	3,447,700	4,137,300	5,378,500	With Annexation	As Development Occurs
BC-FM2	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	6	9,175	216	1,980,605	1,980,700	2,376,900	3,090,000	With Annexation	As Development Occurs
Lift Station	Improvements			1				1					1	
BC-LS	New Lift Station	Beaumont Crossroads	s Lift Station	-	New	3 @ 2,3	50 gpm	-	4,550,536	4,550,600	5,460,800	7,099,100	With Annexation	As Development Occurs
			Subt	otal - Beaumo	ont Crossroad	s (New) Lift S	tation Tribu	utary Area Im	provements	11,844,300	14,213,600	18,478,200		
Marshall C	reek Lift Station	Fributary Area												
Lift Station	Improvements													
MC-LS	Lift Station Replacement	Marshall Creek Lift St	ation	-	Replace	2 @ 1,7	00 gpm	-	2,135,215	2,135,300	2,562,400	3,331,200	Within City Limit	Approximately 1,200 EDUs
				Subt	otal - Marsha	ll Creek Lift S	tation Tribu	utary Area Im	provements	2,135,300	2,562,400	3,331,200		
Industrial F	Park Lift Station 1	ributary Area												
Gravity Mai	n Improvements													
IP-P1	Future Capacity Increase	Risco Cir	From W 4th St to 425' s/o W 4th St	8	Replace	10	475	200	94,878	94,900	113,900	148,100	Within City Limit	Approximately 190 EDUs
Lift Station	Improvements			1				1						
IP-LS	Lift Station Replacement	Industrial Park Lift Sta	ation	-	Replace	2@30)0 gpm	-	644,313	644,400	773,300	1,005,300	Within City Limit	Approximately 20 EDUs
				Sub	total - Industr	ial Park Lift S	tation Tribu	utary Area Im	provements	739,300	887,200	1,153,400		
Beaumont	Avenue South (N	lew) Lift Station Trib	utary Area											
Gravity Mai	n Improvements													
BAS-P1	New Capacity	Beaumont Ave	From 1,200' n/o Laird Rd to 2,775' sw/o Laird Rd	-	New	12	4,125	208	857,209	857,300	1,028,800	1,337,500	With Annexation	As Development Occurs
BAS-P2	New Capacity	Beaumont Ave	From 2,775' sw/o Laird Rd to Beaumont Avenue lift station	-	New	15	875	230	201,509	201,600	242,000	314,600	With Annexation	As Development Occurs
Force Main	Improvements			1				1						
BAS-FM1	New Force Main	Beaumont Ave	From Beaumont Avenue lift station to 2,450' s/o E 1st St	-	New	10	5,025	278	1,398,669	1,398,700	1,678,500	2,182,100	With Annexation	As Development Occurs
Lift Station	Improvements			1				1						
BAS-LS	New Lift Station	Beaumont Avenue So	outh Lift Station	-	New	3 @ 90	00 gpm	-	1,733,029	1,733,100	2,079,800	2,703,800	With Annexation	As Development Occurs
			Subtota	l - Beaumont	Avenue Sout	n (New) Lift S	tation Tribu	utary Area Im	provements	4,190,700	5,029,100	6,538,000		
Wastewate	er Treatment Pla	nt Tributary Area												
Gravity Mai	n Improvements													
WWTP-P1	Future Capacity Increase	Oak Valley Pkwy	From 550' w/o San Miguel Dr to 150' w/o San Miguel Dr	12	Replace	12	425	208	88,319	88,400	106,100	138,000	Within City Limit	Approximately 370 EDUs

Wastewater Master Plan

City of Beaumont

			Limits	Improvements Details				Infrastruc	ture Costs					PRELIMINARY
Improv. No.	Type of Improvement	Alignment		Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Capital Impro. Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
WWTP-P2	Existing Capacity Deficiency	Edgar Ave	From Oak Valley Pkwy to 575' s/o Oak Valley Pkwy	12	Replace	15	575	230	132,420	132,500	159,000	206,700	Within City Limit	FY 2022/23
WWTP-P3	Future Capacity Increase	Luis Estrada Rd	From 400' se/o Veile Ave to Veile Ave	12	Replace	12	425	208	88,319	88,400	106,100	138,000	Within City Limit	Approximately 3,830 EDUs
WWTP-P4	Future Capacity Increase	Minnesota Ave/W 4th St	From 525' n/o W 4th St to 600' w/o Minnesota Ave	24	Replace	30	1,125	526	592,178	592,200	710,700	924,000	Within City Limit	Approximately 5,890 EDUs
WWTP-P5	Future Capacity Increase	ROW	From 4th St to 1,100' w/o Minnesota Ave	30	Replace	36	950	670	636,064	636,100	763,400	992,500	Within City Limit	Approximately 8,820 EDUs
WWTP-P6	New Capacity	ROW	From 2,300 ne/o Highland Springs Ave to 1,300 e/o Highland Springs Ave	-	New	12	3,875	208	805,257	805,300	966,400	1,256,400	With Annexation	As Development Occurs
WWTP-P7	New Capacity	ROW	From 1,300' e/o Highland Springs Ave to Highland Springs Ave	-	New	15	1,300	230	299,385	299,400	359,300	467,100	With Annexation	As Development Occurs
WWTP-P8	Future Capacity Increase	Brookside Ave	From Highland Springs Ave to Orchard Heights Ave	8	Replace	15	2,650	230	610,285	610,300	732,400	952,200	With Annexation	As Development Occurs
WWTP-P9	Future Capacity Increase	Brookside Ave	From Orchard Heights Ave to Cherry Ave	8	Replace	15	2,700	230	621,800	621,800	746,200	970,100	Within City Limit With Annexation	Approximately 320 EDUs
WWTP-P10	Future Capacity Increase	Cherry Ave	From Brookside Ave to Cougar Way	8	Replace	15	2,650	230	610,285	610,300	732,400	952,200	Within City Limit With Annexation	Approximately 300 EDUs
WWTP-P11	Future Capacity Increase	Cherry Ave	From Cougar Way to Oak Valley Pkwy	8	Replace	15	2,675	230	616,042	616,100	739,400	961,300	Within City Limit With Annexation	Approximately 210 EDUs
WWTP-P12	Future Capacity Increase	Cherry Ave	From oak Valley Pkwy to Antonell Ct	10	Replace	15	1,700	230	391,504	391,600	470,000	611,000	Within City Limit With Annexation	Approximately 1,170 EDUs
WWTP-P13	Future Capacity Increase	Cherry Ave	From Antonell Ct to E 8th St	12	Replace	15	3,675	230	846,338	846,400	1,015,700	1,320,500	Within City Limit With Annexation	Approximately 2,430 EDUs
WWTP-P14	Future Capacity Increase	Illinois Ave	From E 8th St to E 6th St	12	Replace	15	1,175	230	270,598	270,600	324,800	422,300	Within City Limit With Annexation	Approximately 2,300 EDUs
WWTP-P15	Future Capacity Increase	E 6th St	From Illinois Ave to Pennsylvania Ave	15	Replace	18	700	247	172,828	172,900	207,500	269,800	Within City Limit With Annexation	Approximately 4,070 EDUs
WWTP-P16	Future Capacity Increase	Pennsylvania Ave	From E 6th St to 175' s/o Interstate 10	18	Replace	24	975	396	385,811	385,900	463,100	602,100	Within City Limit With Annexation	Approximately 1,940 EDUs
WWTP-P17	Future Capacity Increase	ROW	From Pennsylvania Ave to 75' w/o Beaumont Ave	18	Replace	30	3,800	526	2,000,246	2,000,300	2,400,400	3,120,600	Within City Limit With Annexation	Approximately 380 EDUs
WWTP-P18	Future Capacity Increase	ROW	From 125' n/o 3rd St to 400' e/o Beaumont Ave	10	Replace	10	125	200	24,968	25,000	30,000	39,000	Within City Limit	Approximately 2,680 EDUs
WWTP-P19	Future Capacity Increase	ROW	From 3rd St to 400' e/o Beaumont Ave	10	Replace	10	175	200	34,955	35,000	42,000	54,600	Within City Limit	Approximately 1,760 EDUs
WWTP-P20	Future Capacity Increase	ROW	From Rover Ln to 350' w/o Houstonia Ln	12	Replace	15	2,550	230	587,255	587,300	704,800	916,300	Within City Limit	Approximately 2,070 EDUs
WWTP-P21	Future Capacity Increase	E 1st St	From Palm Ave to Beaumont Ave	24	Replace	30	1,600	526	842,209	842,300	1,010,800	1,314,100	Within City Limit	Approximately 6,350 EDUs
WWTP-P22	Future Capacity Increase	E 1st st	From California Ave to Minnesota Ave	30	Replace	36	2,125	670	1,422,776	1,422,800	1,707,400	2,219,700	Within City Limit With Annexation	Approximately 15,780 EDUs
WWTP-P23	Future Capacity Increase	Minnesota Ave	From E 1st St to 575' n/o E 1st St	30	Replace	36	575	670	384,986	385,000	462,000	600,600	Within City Limit With Annexation	Approximately 23,390 EDUs
WWTP-P24	Future Capacity Increase	ROW	From 575' n/o E 1st St to 1,025' w/o Minnesota Ave	30	Replace	36	1,100	670	736,496	736,500	883,800	1,149,000	Within City Limit With Annexation	Approximately 2,500 EDUs
WWTP-P25	New Capacity	Beaumont Ave	From E 1st St to 1,275' n/o Laird Rd	-	New	21	2,475	331	818,683	818,700	982,500	1,277,300	With Annexation	As Development Occurs
				Subtota	l - Wastewate	r Treatment I	Plant Tribu	itary Area Im	provements	14,021,100	16,826,200	21,875,400		

PRELIMINARY

Wastewater Master Plan

City of Beaumont

		Alignment	Limits	Improvements Details Infrastructure Costs					ture Costs					PRELIMIN
prov. No.	Type of Improvement			Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Capital Impro. Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
our Seasoi	ns Lift Station Trik	outary Area												
iravity Mair	n Improvements													
FS-P1	Future Capacity Increase	Highland Springs Ave	From E 6th St to 450' w/o Highland Springs Ave	10	Replace	12	1,225	208	254,565	254,600	305,600	397,300	Within City Limit	Approximately 640 ED
FS-P2	Future Capacity Increase	Highland Springs Ave	From 550' n/o E 1st St to 100' s/o E 1st St	10	Replace	12	650	208	135,075	135,100	162,200	210,900	Within City Limit	Approximately 690 ED
FS-P3	Future Capacity Increase	Highland Springs Ave	From 800' n/o Potrero Blvd to 50' s/o Potrero Blvd	12	Replace	15	850	230	195,752	195,800	235,000	305,500	Within City Limit	Approximately 1,340 E
FS-P4	Pipe Slope Reconstruction	Highland Springs Ave	From 100' n/o Crooked Creek to Crooked Creek	12	Replace	12	100	208	20,781	20,800	25,000	32,500	Within City Limit	Approximately 1,470 EI
FS-P5	Future Capacity Increase	Highland Springs Ave	From 350' s/o Crooked Creek to 375' s/o Breckenridge Ave	15	Replace	18	1,525	247	376,518	376,600	452,000	587,600	Within City Limit	Approximately 1,840 El
FS-P6	Future Capacity Increase	Breckenridge Ave	From 75' w/o Highland Springs Ave to Highland Springs Ave	10	Replace	10	75	200	14,981	15,000	18,000	23,400	Within City Limit	Approximately 1,830 E
ift Station I	mprovements			1				1		1				
FS-LS	Lift Station Replacement	Four Seasons Lift Statio	n	-	Replace	3 @ 1,3	50 gpm	-	2,526,260	2,526,300	3,031,600	3,941,100	Within City Limit	Approximately 3,810 E
				Su	btotal - Four S	Seasons Lift St	tation Tribu	utary Area Im	provements	3,524,200	4,229,400	5,498,300		
ther Wast	ewater System In	nprovements ⁶												
	Lift Station Condi	tion Assessment						-	-	-	-	3,600,000	Within City Limit	FY 2022/23 - FY 2030
	CCTV Program							-	-	-	-	300,000	Within City Limit	FY 2023/24 FY 2029/30
	On-going Pipeline	e Replacement Program						-	-	-	-	4,800,000	Within City Limit	FY 2023/24 - FY 2030
	Wastewater Trea	tment Plant Improveme	nts					-	-	-	-	2,000,000	Within City Limit	FY 2021/22 - FY 2024/ FY 2028/29 - FY 2030/
					Su	btotal - Other	Wastewat	er System Im	provements	-	-	10,700,000		
otal Costs														
							Gra	avity Main Im	provements	20,759,000	24,912,800	32,388,800		
				Force Main Im				provements	10,742,400	12,891,200	21,208,700			
								ift Station Im		18,899,400	22,679,700	34,634,000		
						Other	Wastewat	er System Im	provements	-	-	10,700,000		
	E L							Total Improv	vement Cost	50,400,800	60,483,700	98,931,500		

Notes:

1. Estimated Construction costs include 20 percent of baseline construction costs to account for unforeseen events and unknown field conditions.

2. Unless noted otherwise, Capital Improvement Costs also include an additional 30 percent of the estimated construction costs to account for administration, construction management, and legal costs.

3. Cost allocation for development related improvements to be reviewed as construction triggers are reached.

4. EDU triggers based on remaining pipeline and lift station capacity and assumes 235 gpd/EDUs, consistent with EMWD Wastewater Master Plan Criteria.

5. Beaumont Mesa force main and wet well expansion reflects City staff budgetary planning estimate provided by City staff June 1, 2021.

6. Other wastewater system improvements reflects City staff budgetary planning estimate provided by City staff June 1, 2021.



CHAPTER 1 - INTRODUCTION

This chapter provides a brief background of the City of Beaumont's (City) wastewater collection system, the need for this master plan, and the objectives of the study. Abbreviations and definitions are also provided in this chapter.

1.1 BACKGROUND

The City of Beaumont (City) is located approximately 11 miles north of the City of Hemet, 12 miles east of the City of Monero Valley, and 7 miles southeast of the City of Yucaipa (Figure 1.1). The City provides wastewater collection service to approximately 50,000 residents, as well as a myriad of commercial, industrial, and institutional establishments. The City owns, operates, and maintains the wastewater collection system, which consists of more than 196 miles of gravity trunks and force mains up to 48-inches in diameter, which ultimately convey flows to the City's Wastewater Treatment Plant.

Recognizing the importance of planning, developing, and financing system facilities to provide reliable wastewater service to existing customers and for servicing anticipated growth within the sphere of influence, the City initiated the development of the 2021 Wastewater Master Plan.


1.2 SCOPE OF WORK

City of Beaumont approved Akel Engineering Group Inc. to prepare this master plan in November of 2019. This 2021 Wastewater Master Plan (WWMP) is intended to serve as a tool for planning and phasing the construction of future wastewater system facilities for the projected buildout of the City of Beaumont. The 2021 WWMP evaluates the City's wastewater collection system and recommends capacity improvements necessary to service the needs of existing users and for servicing the future growth of the City.

Should planning conditions change, and depending on their magnitude, adjustments to the master plan recommendations might be necessary.

This master plan includes the following tasks:

- Summarize the City's existing wastewater collection system facilities.
- Document growth planning assumptions and known future developments.
- Summarize the wastewater system performance criteria and design storm event.
- Project future wastewater flows.
- Develop and calibrate the physical characteristics of the hydraulic model (gravity mains, force mains, and lift stations).



Legend

- Major Highways
- City of Beaumont
 - Urbanized Area
 - Protected Open Space

PRELIMINARY

Figure 1.1 Regional Location Map

Wastewater Master Plan City of Beaumont



- Evaluate the adequacy of capacity for the sewer system facilities to meet existing and projected peak dry weather flows and peak wet weather flows.
- Recommend a capital improvement program (CIP) with an opinion of probable construction costs.
- Develop a 2021 Wastewater Master Plan Report.

1.3 REPORT ORGANIZATION

The Wastewater Master Plan report contains the following chapters:

Chapter 1 – Introduction. This chapter provides a brief background of the City of Beaumont's (City) wastewater collection system, the need for this master plan, and the objectives of the study. Abbreviations and definitions are also provided in this chapter.

Chapter 2 – Planning Area Characteristics. This chapter presents a discussion of the planning area characteristics for this master plan and includes a study area description, service area land use, and population for the City of Beaumont.

Chapter 3 – System Performance and Design Criteria. This chapter presents the City's performance and design criteria, which were used in this master plan for evaluating the adequacy of capacity for the existing wastewater system and for sizing improvements required to mitigate deficiencies and to accommodate future growth. The design criteria includes: capacity requirements for the wastewater collection facilities, flow calculation methodologies for future users, flow peaking factors, and accounting for infiltration and inflows.

Chapter 4 – Existing Wastewater Collection Facilities. This chapter provides a description of the City's existing wastewater collection system facilities including gravity trunks, force mains, lift stations, and wastewater collection basins. The chapter also includes a brief description of the City's WWTP, which treats and disposes of the wastewater for the City.

Chapter 5 –Wastewater Flows. This chapter summarizes historical wastewater flows experienced at the City's WWTP and defines flow terminologies relevant to this evaluation. This chapter discusses the wastewater flow distribution within the collection basins and identifies the design flows used in the hydraulic modeling effort and capacity evaluation. The design flows include the flows due to existing conditions and buildout development conditions.

Chapter 6 – Hydraulic Model Development. This chapter describes the development and calibration of the City's wastewater collection system hydraulic model. Hydraulic network analysis has become an effectively powerful tool in all aspects of wastewater collection system planning, design, operation, management, and system reliability analysis. The City's hydraulic model was used to evaluate the capacity adequacy of the existing system and to plan its expansion to service anticipated future growth.

Chapter 7 – Evaluation and Proposed Improvements. This chapter presents a summary of the wastewater collection system capacity evaluation during peak dry weather flows and peak wet weather flows for the existing and buildout development conditions. This chapter summarizes the lift station condition assessment performed by V&A. The recommended sewer system improvements needed to mitigate capacity deficiencies are also discussed in this chapter.

Chapter 8 – Capital Improvement Program. This chapter provides a summary of the recommended Capital Improvement Program (CIP) for the City's wastewater collection system. The program is based on the evaluation of the City's wastewater collection system and on the recommended projects described in the previous chapters. The CIP has been prepared to assist the City in planning and constructing the collection system improvements through the ultimate buildout scenario. This chapter also presents the cost criteria and methodologies for developing the capacity improvement costs.

1.4 ACKNOWLEDGEMENTS

Obtaining the necessary information to successfully complete the analysis presented in this report, and developing the long-term strategy for mitigating the existing system deficiencies and for accommodating future growth, was accomplished with the strong commitment and very active input from dedicated team members including:

- Kristine Day, Assistant City Manager
- Jeff Hart, Public Works Director
- Thaxton Van Belle, Chief Plant Operator
- Kevin Lee, Wastewater Plant Supervisor

1.5 UNIT CONVERSIONS AND ABBREVIATIONS

Engineering units were used in reporting flow rates and volumes pertaining to the design and operation of various components of the wastewater collection system. In some cases, different sets of units were used to describe the same parameter where it was necessary to report values in smaller or larger quantities. Values reported in one set of units can be converted to another set of units by applying a multiplication factor. A list of multiplication factors for units used in this report are shown on Table 1.1.

Various abbreviations and acronyms were also used in this report to represent relevant wastewater collective system terminologies and engineering units. A list of abbreviations and acronyms is included in Table 1.2.

Table 1.1 Unit Conversions

Wastewater Master Plan City of Beaumont

		PRELIMINARY
١	/olume Unit Calculations	
To Convert From:	То:	Multiply by:
acre feet	gallons	325,857
acre feet	cubic feet	43,560
acre feet	million gallons	0.3259
cubic feet	gallons	7.481
cubic feet	acre feet	2.296 x 10 ⁻⁵
cubic feet	million gallons	7.481 x 10 ⁻⁶
gallons	cubic feet	0.1337
gallons	acre feet	3.069 x 10 ⁻⁶
gallons	million gallons	1 x 10 ⁻⁶
million gallons	gallons	1,000,000
million gallons	cubic feet	133,672
million gallons	acre feet	3.069
	Flow Rate Calculations	
To Convert From:	То:	Multiply By:
ac-ft/yr	mgd	8.93 x 10 ⁻⁴
ac-ft/yr	cfs	1.381 x 10 ⁻³
ac-ft/yr	gpm	0.621
ac-ft/yr	gpd	892.7
cfs	mgd	0.646
cfs	gpm	448.8
cfs	ac-ft/yr	724
cfs	gpd	646300
gpd	mgd	1 x 10 ⁻⁶
gpd	cfs	1.547 x 10 ⁻⁶
gpd	gpm	6.944 x 10 ⁻⁴
gpd	ac-ft/yr	1.12 x 10 ⁻³
gpm	mgd	1.44 x 10 ⁻³
gpm	cfs	2.228 x 10 ⁻³
gpm	ac-ft/yr	1.61
gpm	gpd	1,440
mgd	cfs	1.547
mgd	gpm	694.4
mgd	ac-ft/yr	1,120
mgd	gpd	1,000,000
ENGINEERING GROUP, INC.		1/9/2020

Table 1.2 Abbreviations and Acronyms

Wastewater Master Plan City of Beaumont

PRELIMINARY

Abbreviation	Expansion	Abbreviation	Expansion
10yr-24hr	10-Year 24-Hour	gpm	Gallons per Minute
AACE	Association for the Advancement of Cost Engineering	HE	Household equivalent
ADWF	Average Dry Weather Flow	HGL	Hydraulic Grade Line
AAF	Annual Average Flow	in/hr	Inch per Hour
Akel	Akel Engineering Group, Inc.	1&1	Infiltration and Inflow
AWWF	Average Wet Weather Flow	LF	Linear Feet
ССІ	Construct Cost Index	LS	Lift Station
CIP	Capital Improvement Program	MDDWF	Maximum Day Dry Weather Flow
CIPP	Cured in Place Pipe	MDWWF	Maximum Day Wet Weather Flow
DDF	Depth Duration Frequency	MGD	Million Gallons per Day
d/D	depth of flow to pipe diameter	MMDWF	Maximum Month Dry Weather Flow
City	City of Beaumont	MMWWF	Maximum Month Wet Weather Flow
ENR	Engineering News Record	NASSCO	National Association of Sewer Service Companies
ft	Feet	NOAA	National Oceanic and Atmospheric Administration
fps	Feet per Second	PDWF	Peak Dry Weather Flow
FY	Fiscal Year	PWWF	Peak Wet Weather Flow
GIS	Geographic Information Systems	ROW	Right of Way
gpdc	Gallons per day per capita	UWMP	Urban Water Management Plan
gpd	Gallons per Day	WWTP	Wastewater Treatment Plant

-AKEL-

1/9/2020

1.6 GEOGRAPHIC INFORMATION SYSTEMS

This master planning effort made extensive use of Geographic Information Systems (GIS) technology, for efficiently completing the following tasks:

- Developing the physical characteristics of the hydraulic model (gravity mains, force mains, and lift stations).
- Allocating existing wastewater loads, as calculated using the developed wastewater unit factors.
- Calculating and allocating future wastewater loads, based on the future developments land use.
- Extracting ground elevations along the gravity and force mains from available contour maps.
- Generating maps and exhibits used in this master plan.

City of Beaumont

CHAPTER 2 - PLANNING AREA CHARACTERISTICS

This chapter presents a discussion of the planning area characteristics for this master plan and includes a study area description, service area land use, and population for the City of Beaumont.

2.1 STUDY AREA DESCRIPTION

The City of Beaumont is located in Riverside County on the southern portion of California, east of the City of Banning. The City is located approximately 11 miles north of the City of Hemet, 5 miles east of the City of Banning, 12 miles east of City of Monero Valley, and 7 miles southeast of the City of Yucaipa. The City currently encompasses an area greater than 26,000 acres., with an approximate population of 50,000 residents.

The City's service area is generally bound to the north by Brookside Avenue, to the east by Highlands Springs Avenue, and to the southwest of Monero Valley Freeway. The topography is generally steep, with slopes increasing from north to south toward the Interstate 10. Figure 2.1 displays the City's existing service area and the general plan boundary.

The City operates and maintains a wastewater collection system that covers the majority of the developable area within Planning Boundary. Currently, the wastewater flows are conveyed to the City of Beaumont Wastewater Treatment Plant (WWTP).


2.2 WASTEWATER COLLECTION SYSTEM SERVICE AREA

The City's wastewater collection system services residential and non-residential lands within the City limits, as summarized on Table 2.1, and shown graphically on Figure 2.2. Areas within the City's potential wastewater collection service area include:

- 3,205 acres of flow generating lands including residential and non-residential areas.
- 11,405 acres of non-flow generating areas.

The existing land use statistics were based on land use information received from City staff. Plan, however for the purposes of estimating wastewater flows, these acreages were assumed to retain their existing land use, such as residential or commercial. It should be noted that Cherry Valley operate own water and wastewater facilities; these users are not serviced by City's water system but do convey wastewater flows to the Beaumont WWTP. For planning purposes, most of the acreages are Single-Family Residential and included in Table 2.1.

An ultimate development of the General Plan, the City's wastewater collection system is anticipated to service approximately 6,793 acres of residential land use, 7,013 acres of non-residential land use, and 11,433 acres of non-flow generating land use, for a total of 25,239 acres inside the planning area, and including in Table 2.1. The land use designations utilized in this






Table 2.1 Existing and Future Land Use

Wastewater Master Plan

City of Beaumont

D	D	E1	IN	ЛІ	N	٨	RY	1
		E L		/	1 1	А	D I	

		E	xisting Developme	ent	FL	iture Developme	nt	
General Plan Land Use Classification ¹	Existing Land Use Classification ²	Existing Development	Existing Lands - Redeveloping	Subtotal Existing Development - Unchanged	New Lands - Redevelopment	New development	Subtotal Future Development	Total Development
1	2	(acre) 3	(acre) 4	(acre)	(acre)	(acre) 7	(acre) 8	(acre) 9
Residential					U	,	Ū	
Single Family Residential	Single Family Residential	2,568	-178	2,389	118	588	706	3,096
	Mobile Homes and Trailer Parks							
Llich Doncity Posidontial	Mixed Residential Multi-Family Residential	134	-51	83	6	276	282	364
High Density Residential Rural Residential	Rural Residential	0	-51	0	2,446	312	282	2,758
Traditional Neighborhood	Rufai Residentia	0	0	0	2,440	499	574	574
	Subtotal - Residential	2,701	-229	2,472	2,645	1,676	4,321	6,793
Non-Residential	Subtotal Residential	2,701	225	2,472	2,045	1,070	4,021	0,755
General Commercial	Commercial and Services	389	-147	242	28	324	352	595
	General Office				_			
Neighborhood Commercial	-	0	0	0	34	11	46	46
Industrial	Industrial	280	-69	211	52	315	367	577
Public Facility	Facilities	293	-13	280	44	64	107	388
	Education							
Downtown Mixed Use	-	0	0	0	321	64	386	386
Urban Village	-	0	0	0	107	536	643	643
Employment District	-	0	0	0	0	179	179	179
Specific Plans and Other Developments	-	0	0	0	0	4,200	4,200	4,200
	Subtotal - Non-Residential	962	-229	733	586	5,693	6,280	7,013
Non-Flow Generating								
Open Space	Open Space and Recreation	8,533	-221	8,312	0	28	28	8,341
	Agriculture	0	0	0	0	0	0	0
Vacant	Vacant	2,934	0	2,934	0	0	0	2,934
Utilities	Utilities	4	0	4	0	0	0	4
ROW	ROW	155	0	155	0	0	0	155
	Subtotal - Non-Flow	11,626	-221	11,405	0	28	28	11,433
AKEL	Total Developed Area	15,289	-679	14,610	3,231	7,397	10,628	25,239


1. Source: City of Beaumont Public Draft General Plan (2020)

2. Source: Southern California Association of Governments (SCAG) 2016 Existing Land Use file extracted from City of Beaumont Planning Viewer online web application.

master plan are consistent with the Land Use Element of the City's General Plan, and as received from the City's planning division and shown on Figure 2.3.

In addition to the General Plan Land Use documented on Figure 2.3 there are multiple areas of known development, which are defined by Specific Plans or other development planning information. These known development areas provide a more refined definition of planned land uses, which is used for estimating future flows. The known development areas are summarized on Figure 2.4, with the land use information shown on Table 2.2. Based on a review of aerial imagery and existing land use information some known development areas are partially developed or completely developed. The areas or remaining development area summarized on Table 2.3. The known development areas are briefly summarized in the following sections:

- Amazon: This development includes approximately 66 acres of industrial use.
- **ASM:** This development includes approximately 49 acres of industrial use.
- **Beaumont Commercial Center:** This development includes approximately 17 acres of commercial use.
- Beaumont Crossroads II: This development includes approximately 166 acres of industrial use.
- **Curtis Development:** This development includes approximately 67 acres of single-family residential use.
- **Fairway Canyon:** This development includes approximately 703 acres, which includes 661 acres of single-family residential, 12 acres of commercial and 30 acres of public facilities.
- Four Seasons: This development includes approximately 386 acres, which includes 366 acres of single-family residential, 3 acres of multi-family residential and 17 acres of commercial.
- Hall: This development includes approximately 11 acres of industrial use.
- **Heartland/Olivewood:** This development includes approximately 279 acres, which includes 208 acres of single-family residential, 12 acres of commercial, 50 acres of industrial and 9 acres of public facilities.
- Home Depot: This development includes approximately 22 acres of commercial use.
- Jack Rabbit Trail: This development includes approximately 255 acres, which includes 30 acres of commercial and 225 acres of industrial.
- **Kirkwood Ranch:** This development includes approximately 128 acres, which inlcudes 123 acres of single-family residential and 5 acres of multi-family residential.






Table 2.2 Specific Plans and Other Developments, Total Development Area

Wastewater Master Plan

City of Beaumont

PREL	IMI.	NARY
------	------	------

	Total Development Area, by Land Use Type ¹								
Known Developments	Single Family Residential	Multi-Family Residential	Commercial	Industrial	Public Facilities	Tota			
	(acres)	(acres)	(acres)	(acres)	(acres)	(acre			
Amazon	-	-	-	65.7	-	65.			
ASM	-	-	-	49.3	-	49.3			
Beaumont Commercial Center	-	-	17.4	-	-	17.			
Beaumont Crossroads II	-	-	-	165.5	-	165			
Curtis Development	66.7	-	-	-	-	66.			
Fairway Canyon	660.9	-	12.0	-	30.0	702			
Four Seasons	365.3	3.3	17.0	-	-	385			
Hall	-	-	-	11.2	-	11.			
Heartland/Olivewood	207.6	-	11.5	50.3	9.2	278			
Home Depot	-	-	21.8	-	-	21.			
Jack Rabbit Trail	-	-	30.0	225.0	-	255			
Kirkwood Ranch	123.0	5.0	-	-	-	128			
Lassen	-	-	-	17.3	-	17.			
Legacy Highlands Residential	541.4	71.3	-	-	20.0	632			
Legacy Highlands Warehouse	-	-	14.0	92.0	-	106			
Marketplace Beaumont	-	-	17.4	-	-	17.			
Noble Creek Vistas	181.2	-	-	-	32.6	213			
Portrero Creek Estates ²	733.0	-	-	-	-	733			
Ricker	-	-	-	18.0	-	18			
San Gorgaonio	-	-	23.0	-	-	23			
Sundance	874.4	39.0	14.0	-	39.0	966			
Sunny Cal	112.1	-	-	-	-	112			
Three Rings Ranch	143.2	10.0	-	-	-	153			
Tournament Hills	305.4	-	34.4	-	10.0	349			
Walmart - Farmer Boys	-	-	22.7	-	-	22.			
Wolverine	-	-	-	60.0	-	60.			
Total	4,314	129	235	754	141	5,57			

Notes:

1. Unless noted otherwise, development information shown based on planning documents provided by City staff on November 25, 2019 and December 5, 2019.

2. Source: City of Beaumont General Plan Public Draft, August 2020

Table 2.3 Specific Plans and Other Developments, Remaining Development Area

Wastewater Master Plan

City of Beaumont

PRELIMINARY

	Remaining Development Area, by Land Use Type ¹									
Known Developments	Single Family Residential	Multi-Family Residential	Commercial	Industrial	Public Facilities	Tota				
	(acres)	(acres)	(acres)	(acres)	(acres)	(acres				
Amazon	-	-	-	65.7	-	65.7				
ASM	-	-	-	49.3	-	49.3				
Beaumont Commercial Center	-	-	-	-	-	-				
Beaumont Crossroads II	-	-	-	165.5	-	165.				
Curtis Development	-	-	-	-	-	-				
Fairway Canyon	431.9	-	-	-	-	431.				
Four Seasons	216.3	-	-	-	-	216.				
Hall	-	-	-	11.2	-	11.2				
Heartland/Olivewood	207.6	-	11.5	50.3	9.2	278.				
Home Depot	-	-	-	-	-	-				
Jack Rabbit Trail	-	-	30.0	225.0	-	255.				
Kirkwood Ranch	123.0	5.0	-	-	-	128.				
Lassen	-	-	-	17.3	-	17.3				
Legacy Highlands Residential	541.4	71.3	-	-	20.0	632.				
Legacy Highlands Warehouse	-	-	14.0	92.0	-	106.				
Marketplace Beaumont	-	-	-	-	-	-				
Noble Creek Vistas	181.2	-	-	-	32.6	213.				
Portrero Creek Estates	733.0	-	-	-	-	733.				
Ricker	-	-	-	18.0	-	18.0				
San Gorgaonio	-	-	4.3	-	-	4.3				
Sundance	550.6	10.0	-	-	11.9	572.				
Sunny Cal	112.1	-	-	-	-	112.				
Three Rings Ranch	-	-	-	-	-	-				
Tournament Hills	128.5	-	-	-	-	128.				
Walmart - Farmer Boys	-	-	-	-	-	-				
Wolverine	-	-	-	60.0	-	60.0				
Total	3,226	86	60	754	74	4,20				

Notes:

1. Remaining development area based on a combination of SCAG 2016 Existing Land Use and aerial imagery review

Table 2.4 Specific Plans and Other Developments, Remaining Development Flows

Wastewater Master Plan

City of Beaumont

		Average	Dry Weather Flo	ws, by Land Use	Type ¹	
Known Developments	Single Family Residential	Multi-Family Residential	Commercial	Industrial	Public Facilities	Total
	(1,396 gpd/acre)	(2,609 gpd/acre)	(1,175 gpd/acre)	(1,763 gpd/acre)	(1,175 gpd/acre)	
	(gpd)	(gpd)	(gpd)	(gpd)	(gpd)	(gpd)
Amazon	-	-	-	115,900	-	115,90
ASM	-	-	-	86,828	-	86,82
Beaumont Commercial Center	-	-	-	-	-	-
Beaumont Crossroads II	-	-	-	291,847	-	291,84
Curtis Development	-	-	-	-	-	-
Fairway Canyon	602,932	-	-	-	-	602,93
Four Seasons	301,955	-	-	-	-	301,95
Hall	-	-	-	19,675	-	19,67
Heartland/Olivewood	289,810	-	13,513	88,679	10,810	402,83
Home Depot	-	-	-	-	-	-
Jack Rabbit Trail	-	-	35,250	396,675	-	431,92
Kirkwood Ranch	171,708	13,045	-	-	-	184,75
Lassen	-	-	-	30,570	-	30,57
Legacy Highlands Residential	755,794	186,022	-	-	23,500	965,32
Legacy Highlands Warehouse	-	-	16,450	162,196	-	178,64
Marketplace Beaumont	-	-	-	-	-	-
Noble Creek Vistas	253,011	-	-	-	38,305	291,33
Portrero Creek Estates	1,023,268	-	-	-	-	1,023,2
Ricker	-	-	-	31,734	-	31,73
San Gorgaonio	-	-	5,100	-	-	5,100
Sundance	768,652	26,090	-		13,983	808,72
Sunny Cal	156,464	-	-	-	-	156,46
Three Rings Ranch	-	-	-	-	-	-
Tournament Hills	179,316	-	-	-	-	179,32
Walmart - Farmer Boys	-	-	-	-	-	-
Wolverine	-	-	-	105,745	-	105,74
Total	4,502,910	225,157	70,312	1,329,849	86,598	6,214,8

Note:

1. Flows shown are based on remaining area to be developed for each known development.

- Lassen: This development includes approximately 17 acres of industrial use.
- Legacy Highlands Residential: This development includes approximately 633 acres, which includes 542 acres of single-family residential, 71 acres of multi-family residential and 20 acres of public facilities.
- Legacy Highlands Warehouse: This development includes approximately 106 acres, which includes 14 acres of commercial and 92 acres of industrial.
- Marketplace Beaumont: This development includes approximately 17 acres of commercial use.
- **Noble Creek Vistas:** This development includes approximately 214 acres, which includes includes 181 acres of single-family residential and 33 acres of public facilities.
- **Potrero Creek Estates:** This development includes approximately 733 acres of single-family residential use.
- **Ricker:** This development includes approximately 18 acres of industrial use.
- San Gorgaonio: This development includes approximately 23 acres of commercial use.
- **Sundance:** This development includes approximately 966 acres, which includes 874 acres of single-family residential, 39 acres of multi-family residential, 14 acres of commercial, and 39 acres of public facilities.
- **Sunny Cal:** This development includes approximately 112 acres of single-family residential use.
- **Three Rings Ranch:** This development includes approximately 153 acres, which includes 143 acres of single-family residential and 10 acres of multi-family residential.
- **Tournament Hills:** This development includes approximately 350 acres, which includes approximately 305 acres of single-family residential, 35 acres of commercial and 10 acres of public facilities.
- Walmart Farmer Boys: This development includes approximately 23 acres of commercial use .
- Wolverine: This development includes approximately 60 acres of industrial use.

2.3 HISTORICAL AND FUTURE GROWTH

The City's historical and projected population data are provided by City staff and presented in **Table 2.5**. This table documents the historical population from 2007 to 2018 and the projected population by year to 2038. From 2009 to present the City's service area has observed an average annual growth rate of approximately 4.1 percent. Continuing with the downward growth trend projects the population of 2038 to increase from present 51,263 to 67,144 people.

Table 2.5 Historical and Projected Population

Wastewater Master Plan City of Beaumont

Ску ог веа		PRELIMINARY
Year	Population City-Wide	Percent Growth
	City-wide	(%)
Historical		
2007	28,250	10.9%
2008	31,317	10.9%
2009	32,403	5.3%
2010	36,877	5.3%
2011	38,201	5.3%
2012	39,317	5.3%
2013	40,472	5.3%
2014	41,659	3.6%
2015	43,370	3.6%
2016	44,821	3.6%
2017	46,179	3.6%
2018	48,237	3.6%
Projected		
2019	49,915	2.3%
2020	51,263	2.3%
2021	52,291	2.3%
2022	53,061	2.3%
2023	53,950	2.3%
2024	54,463	1.8%
2025	55,234	1.8%
2026	56,261	1.8%
2027	57,416	1.8%
2028	58,947	1.8%
2029	59,974	1.3%
2030	60,745	1.3%
2031	61,258	1.3%
2032	61,772	1.3%
2033	62,917	1.3%
2034	63,816	1.3%
2035	64,715	1.3%
2036	65,485	1.3%
2037	66,127	1.3%
2038	67,144	1.3%
		1/28/2020

Notes:

1. Historical and Projected Population provided by City staff on December 13, 2019.



CHAPTER 3 - SYSTEM PERFORMANCE AND DESIGN CRITERIA

This chapter presents the City's performance and design criteria that were used in this master plan for evaluating the adequacy of capacity for the existing wastewater collection system and for sizing improvements required to mitigate deficiencies and to accommodate future growth. The design criteria include: capacity requirements for the wastewater collection facilities, flow calculation methodologies for future users, flow peaking factors, and accounting for infiltration and inflows. The City has adopted the Eastern Municipal Water District wastewater system performance and design criteria for wastewater collection system planning and design.

3.1 HYDRAULIC CAPACITY CRITERIA

In addition to applying the City design standards for evaluating hydraulic capacities; this master plan included dynamic hydraulic modeling. The dynamic modeling was a critical and essential element in identifying surcharge conditions resulting from downstream bottlenecks in the gravity mains.

3.1.1 Gravity Mains

Gravity main capacities depend on several factors including: material and roughness of the pipe, the limiting velocity and slope, and the maximum allowable depth of flow. The hydraulic modeling software used for evaluating the capacity adequacy of the City's wastewater collection system, InfoSWMM by Innovyze Inc., utilizes the fully dynamic St. Venant's equation which has a more accurate engine for simulating backwater and surcharge, in addition to manifolded force mains. The software also incorporates the use of the Manning Equation in other calculations including upstream pipe flow conditions.

Manning's Equation for Pipe Capacity

The Continuity equation and the Manning equation for steady-state flow are used for calculating pipe capacities in open channel flow. Open channel flow can consist of either open conduits or, in the case of gravity sewers, partially full closed conduits. Gravity full flow occurs when the conduit is flowing full but has not reached a pressure condition.

• Continuity Equation: Q = VA

Where: Q = peak flow, in cubic feet per second (cfs) V = velocity, in feet per second (fps) A = cross-sectional area of pipe, in square feet (sq. ft.)

• Manning Equation: $V = (1.486 R^{2/3} S^{1/2})/n$

Where: V = velocity, fps n = Manning's roughness coefficient R = hydraulic radius (area divided by wetted perimeter), ft S = slope of pipe, in feet per foot

St. Venant's Equation for Pipe Capacity

Dynamic modeling facilitates the analysis of unsteady and non-uniform flows (dynamic flows) within a sewer system. Some hydraulic modeling programs have the ability to analyze these types of flows using the St. Venant equation, which take into account unsteady and non-uniform conditions that occur over changes in time and cross-section within system pipes.

The St. Venant equation is a set of two equations, a continuity equation and a dynamic equation, that are used to analyze dynamic flows within a system. The first equation, the continuity equation, relates the continuity of flow mass within the system pipes in terms of: (A) the change in the cross-sectional area of flow at a point over time and (B) The change of flow over the distance of piping in the system. The continuity equation is provided as follows:

• Continuity Equation:
$$\frac{\partial A}{\partial t} + \frac{\partial Q}{\partial x} = 0$$
(A) (B)
Where:
t = time
x = distance along the longitudinal direction of the channel
Q = discharge flow
A = flow cross-sectional area perpendicular to the x directional axis

The second equation, the dynamic equation, relates changes in flow to fluid momentum in the system using: (A) Changes in acceleration at a point over time, (B) Changes in convective flow acceleration, (C) Changes in momentum due to fluid pressure at a given point, (D) Changes in momentum from the friction slope of the pipe and (E) Fluid momentum provided by gravitational forces. The dynamic equation is provided as follows:

• Dynamic Equation:

$$\frac{\partial Q}{\partial t} + \frac{\partial}{\partial t} \left(\beta \frac{Q^2}{A}\right) + gA \frac{\partial y}{\partial x} + gAS_f - gAS_o = 0$$
(A) (B) (C) (D) (E)

Where:

- t = time
- x = distance along the longitudinal direction of the channel

Q = discharge flow

- A = flow cross-sectional area perpendicular to the x directional axis
- y = flow depth measured from the channel bottom and normal to the x directional axis
- S_f = friction slope
- $S_o = channel slope$
- β = momentum
- g = gravitational acceleration

Use of this method of analysis provides a more accurate and precise analysis of flow conditions within the system compared to steady state flow analysis methods. It must be noted that two assumptions are made for use of St. Venant equations in the modeling software. First, flow is one dimensional. This means it is only necessary to consider velocities in the downstream direction and not in the transverse or vertical directions. Second, the flow is gradually varied. This means the vertical pressure distribution increases linearly with depth within the pipe.

Manning's Roughness Coefficient (n)

The Manning roughness coefficient 'n' is a friction coefficient that is used in the Manning formula for flow calculation in open channel flow. In wastewater collection systems, the coefficient can vary between 0.009 and 0.017 depending on pipe material, size of pipe, depth of flow, root intrusion, smoothness of joints, and other factors.

For the purpose of this evaluation, and in accordance with City standards, an "n" value of 0.013 was used for both existing and proposed gravity pipes unless directed otherwise by City staff based on pipe structural condition. This "n" value is an acceptable practice in planning studies.

Partial Flow Criteria (d/D)

Partial flow in gravity sewers is expressed as a depth of flow to pipe diameter ratio (d/D). For circular gravity conduits, the highest capacity is generally reached at 92 percent of the full height of the pipe (d/D ratio of 0.92). This is due to the additional wetted perimeter and increased friction of a gravity pipe.

When designing wastewater pipelines, it is common practice to use variable flow depth criteria that allow higher safety factors in larger sizes. Thus, design d/D ratios may range between 0.5 and 0.92, with the lower values used for smaller pipes. The smaller pipes may experience flow peaks greater than planned or may experience blockages from debris. The City's design standards pertaining to the d/D criteria are summarized in Table 3.1.

During peak dry weather flows (PDWF), the maximum allowable d/D ratio for gravity pipelines are summarized as follows:

- 12-inch diameter and smaller: 0.50
- 15-inch diameter and larger: 0.70

During peak wet weather flows (PWWF), the maximum allowable d/D ratio for proposed pipes (all diameters) is 0.75. The maximum allowable d/D ratio for all existing pipes (all diameters) is 1.00. The criterion for existing pipes is relaxed in order to maximize the use of the existing pipes before costly pipes improvements are required. This condition is evaluated using the dynamic hydraulic model and the criteria listed on Table 3.1.

Table 3.1Wastewater System Performance and Design CriteriaWastewater Master PlanCity of Beaumont

	PRELIMINARY						
Dry Wea	ther Flow Criteria						
Sewer Trunk	d/D						
Diameter < 15 inches	0.50						
Diameter ≥ 15 inches	0.70						
Wet Wea	ther Flow Criteria						
Sewer Trunk	d/D						
Existing System	1.00						
Future System	0.75						
Pipe Slope Criteria							
Pipe Size	Minimum Slope (ft/ft)						
8"	0.004						
10"	0.0032						
12"	0.0024						
15"	0.0016						
18"	0.0014						
21"	0.0012						
24" and Up	0.001						
Pipe V	elocity Criteria						
Ріре Туре	Minimum / Maximum Velocity (fps)						
Gravity Sewer	Minimum 2 / Maximum 10						
Force Main	Desired 2 to 6.5 / Maximum 10						
ENGINEERING GROUP, INC.	3/2/2021						

Notes:

1. Source: Eastern Municipal Water District Wastewater Collection System Master Plan

2. Wastewater Collection System performance criteria shall be in accordance with EMWD WCSMP.

Minimum Pipe Sizes and Design Velocities

In order to minimize the settlement of sewage solids, it is standard practice in the design of gravity mains to specify that a minimum velocity of 2 feet per second (fps) be maintained when the pipeline is half-full. At this velocity, the sewer flow will typically result with self-cleaning of the pipe.

Due to the hydraulics of a circular conduit, velocity of half-full flows approaches the velocity of nearly full flows. Table 3.1 lists the minimum slopes, varying by pipe size, in accordance with the City's design standards. The design standards also specify minimum pipe sizes, depending on the peak dry weather flows, as shown on Table 3.1.

Changes in Pipe Size

When a smaller gravity wastewater pipe joins a larger pipe, the invert of the larger pipe is generally to maintain the same energy gradient. One of the methods used to approximate this condition includes placing the 80 percent depth point (d/D at 0.8) from both wastewater mains at the same elevation. For master planning purposes, and in the absence of known field data, wastewater main crowns were matched at the manholes.

3.1.2 Force Mains and Lift Stations

The Hazen-Williams formula is commonly used for the design of force mains as follows:

- Hazen Williams Velocity Equation: $V = 1.32 C R^{0.63} S^{0.54}$
 - Where: V = mean velocity, fps C = roughness coefficient R = hydraulic radius, ft S = slope of the energy grade line, ft/ft

The value of the Hazen-Williams 'C' varies and depends on the pipe material and is also influenced by the type of construction and pipe age. A 'C' value of 130 was used in this analysis.

The minimum recommended velocity in force mains is at 2 feet per second. The economical pumping velocity in force mains ranges between 3 and 5 fps. A maximum desired velocity is typically around 7 fps and a maximum not-to-exceed velocity is at 10 fps.

The capacities of pump stations are evaluated and designed to meet the peak wet weather flows with one standby pump having a capacity equal to the largest operating unit. The standby pump provides a safety factor in case the duty pump malfunctions during operations and allows for maintenance.

3.2 DRY WEATHER FLOW CRITERIA

Wastewater unit flow factors are coefficients commonly used in planning level analysis to estimate future average daily wastewater flows for areas with predetermined land uses. The unit factors are multiplied by the number of dwelling units or acreages for residential categories, and by the acreages for non-residential categories, to yield the average daily wastewater flow projections.

3.2.1 Unit Flow Factors Methodology

Wastewater unit factors are developed by using water consumption records and applying a return to sewer ratio for each land use to estimate wastewater flow coefficients. There are several methods for developing the unit factors. This analysis relied on the use of the City's water consumption billing records, which lists the monthly water consumption per customer account, by land use type, to estimate the unit factors within the service area.

3.2.2 Average Daily Sewer Unit Flow Factors

Wastewater flow factors were based on water demands as extracted from the City's water consumption billing records. These records provided geographical addresses and were part of the methodology used for distributing the wastewater flows in the hydraulic model. The methodology included applying a return to sewer ratio, applied to each unadjusted water demand factor by individual land use types. The system wide calculated wastewater flows were also balanced to match the flows recorded at the wastewater treatment plant. Table 3.2 characterizes the existing wastewater flows, by land use classification.

Generally, non-residential land uses return the majority of the water demand to the wastewater collection system. These unit factors were estimated at 85 percent return to sewer ratios. The same concept can be applied to single family and multi-family residential lots, which are typically estimated at 50 percent and 75 percent return to sewer ratio respectively. Single family residential lots have the lowest return to sewer ratio due to water lost for landscape irrigation. Lastly, unit factors were adjusted to 100 percent occupancy, and rounded. This analysis generally indicates that existing non-residential land uses have higher flow generation factors than that of residential land uses.

For projecting future flows, The City of Beaumont has adopted using the design flow criteria used by the adjacent Eastern Municipal Water District (EMWD). **Table 3.3** documents the EMWD factors, and also lists some minor adjustments applied by City staff for the purpose of this wastewater master plan. Thus, the wastewater unit factors listed on **Table 3.3** were used for projecting buildout flows in this master plan.

3.2.3 Peaking Factors

The wastewater collection system is evaluated based on its ability to convey peak wastewater flows. Peaking factors represent the increase in wastewater flows experienced above the average dry weather flows (ADWF). The various peaking conditions are numerical values obtained from a review of historical data and, at times, tempered by engineering judgment.

The peaking conditions that are significant to hydraulic analysis of the wastewater collection system include:

- Peak Dry Weather Flows (PDWF)
- Peak Wet Weather Flows (PWWF)

Table 3.2 Existing Wastewater Flows by Land Use Classification

Wastewater Master Plan

City of Beaumont

			7 Average Daily Water 2017 Average Dry Weather Sewer Flows 2017 Average Dry Weather Sewer Flows								
Land Use Classification	Existing Development	2017 Water Co	nsumption ¹	Deturn to	Dry Weather	Sewer Flows	Sewer	Flows at 100% (Dccupancy	Sewer Flo	ow Balance
		Annual Consumption	Unadjusted Water Unit Factors	Return to Sewer Ratio	Unadjusted Sewer Unit Factor	Balance using Recommended Unit Factor	Vacancy Rate ^{2,3}		ows at 100% pancy	Unit Factor	Balance Using Unit Factor
	(acre)	(gpd)	(gpd/acre)		(gpd/acre)	(gpd)		(gpd/acre)	(gpd)	(gpd/acre)	(gpd)
Residential											
Single Family Residential ⁴	2,568	5,432,317	2,116	0.50	1,064	2,732,455	10.0%	1,171	3,005,701	1,200	3,081,236
Multi-Family Residential	134	315,111	2,358	0.70	1,660	221,838	10.0%	1,826	244,022	1,850	247,193
Subtotal Residential	2,701	5,747,428				2,954,294			3,249,723		3,328,429
Non-Residential											
Commercial and Services ⁵	389	413,338	1,062	0.85	903	351,337	2.0%	921	358,364	925	360,038
Public Facilities ⁶	293	286,703	979	0.85	832	243,698	2.0%	849	248,572	850	248,974
Industrial ⁷	223	130,310	585	0.85	497	110,764	0.2%	498	110,985	500	111,360
Subtotal Non-Residential	905	830,351				705,798			717,921		720,372
Totals				2017 A	verage Dry Weath	ner Flows					
	3,606	6,577,779		Estima	ated Sewer Flows	3,660,092			3,967,644		4,048,800
AKEL				Measur	ed WWTP Flows ⁸	3,662,673					

Notes:

1. Water consumption extracted from water billing data received from City staff November 21, 2019.

2. Residential vacancy rate extracted from California Department of Finance E-5 Population estimates.

3. Office Commercial and Industrial vacancy rates extracted from "Beaumont Economic Development Strategic Plan". For planning purposes, Business Commercial vacancy rate assumed equal to Office Commercial.

4. "Single Family Residential" contains development and consumption for "Mobile Homes and Trailer Parks".

5. "Commercial And Services" contains development and consumption for "General Office".

6. "Public Facilities" contains development and consumption for "Educational Facilities"

7. Industrial consumption includes Perricone Juice (83,796 gpd), Dura Plastics Products (22,364 gpd), and Rudolph Food Company (3,728 gpd).

8. Measured WWTP flows provided by City staff February 18, 2020.

PRELIMINARY

Table 3.3 Wastewater Unit Factors for Projecting Future Flows

Wastewater Master Plan

City of Beaumont

					PRELIMINARY
Land Use ¹ Classification	Density ¹	Eastern I	Municipal Water [Wastewater Unit Flow Factors (Used for projecting future flows in 2021 Wastewater Master Plan)	
		Land Use Classification	Density	Unit Factor (gpd/net acre)	Unit Factor (gpd/net acre)
Residential					
Single Family Residential ³	0-4 du/acre	Low Density	2 du/acre	611	
		Medium Density	4.5 du/acre	1,058	1,396
		Mobile Home Park	10 du/acre	1,528	
Multi-Family Residential	0-24 du/acre	Medium High Density	6 du/acre	1,269	2,609
		Very High Density	17 du/acre	2,609	2,009
Rural Residential	0-2 du/acre	Estate Density	0.5 du/acre	188	611
Non-Residential					
Community Commercial	FAR up to 2.0	Commercial Retail	5 edu/acre	1,175	1,175
		Mixed Use Policy Area	5 edu/acre	1,175	1,175
General Commercial	FAR up to 0.3	Commercial Office	5 edu/acre	1,175	1,175
Industrial	FAR up to 0.7	Business Park/Light Industrial	5 edu/acre	1,175	
		Business Park/Light Industrial/Warehouse	1.25 edu/acre	294	1,763
		Heavy Industrial	7.5 edu/acre	1,763	
Public Facilities	FAR up to 1.0	Public Facility	5 edu/acre	1,175	1,175
_A K E L		Hospital	5 edu/acre	1,175	, , , , , , , , , , , , , , , , , , ,
-A N E L					0/20/202

ENGINEERING GROUP, INC.

8/20/2021

Notes:

1. Land Use classification and densities extracted from City of Beaumont General Plan.

2. Land use classifications, density and unit factors based on Eastern Municipal Water District 2015 Wastewater Collection System Master Plan.

3. Single Family Residential Factor includes a 10% contingency for potential Accessory Dwelling Unit construction per City staff direction via teleconference on October 15, 2020.

Typical values for peaking factors of 2.0 or less are generally used to estimate peak flows at treatment facilities where flow fluctuations are smoothed out during the time of travel in the wastewater collection system, while peaking factors between 3.0 and 4.0 are used to estimate peak flows in the smaller upstream areas of the system where low flow conditions are prone to greater fluctuations.

This master plan used 24-hour diurnal patterns for weekday and weekend dry weather flows tributary to each flow monitor, as shown on Figure 3.1, Figure 3.2, Figure 3.3 and Figure 3.4.

3.3 WET WEATHER FLOW CRITERIA


The wet weather flow criteria accounts for the infiltration and inflows (I&I) that seep into the City's wastewater collection system during storm events.


3.3.1 Infiltration and Inflow


Groundwater infiltration and inflow is associated with extraneous water entering the wastewater collection system through defects in pipelines and manholes. Infiltration occurs when groundwater rises or the soil is saturated due to seasonal factors such as a storm event which causes an increase in flows in the wastewater collection system. The ground water will enter the wastewater collection system through cracks in the pipes or deteriorating manholes. Inflow occurs when surface water enters the wastewater collection system from storm drain cross connections, manhole covers, or roof/footing drains. **Figure 3.5** was developed by King County, Washington and was included in this chapter to illustrate the typical causes of infiltration and inflow.


There are several accepted methodologies for estimating infiltration and inflows (I&I). These include:


- **Methodology 1.** Based on Acreages. In this methodology, factors that may range between 400 and 1,500 gallons per day (gpd) or more are applied to acreages for estimating the I&I component.
- **Methodology 2.** Based on Linear Feet of Pipe. In this methodology, factors that may range between 12 and 30 or more gallons per day per inch diameter per 100 linear feet (gpd/inch diameter/100LF) are applied to linear feet of gravity sewers.
- **Methodology 3**. Based on a percentage of Average Dry Weather Flows. In this methodology, Infiltration and Inflows (I&I) are calculated based on a percentage of the average dry weather flow.
- **Methodology 4**. Based on flow monitoring data. In this methodology, infiltration and inflows are determined by analyzing flow monitoring data of current and past flow monitoring efforts.











ENGINEERING GROUP, INC.

This capacity analysis and master plan based the infiltration and inflow on specific flow monitoring data from the Villalobos and Associates (V&A) 2020 Flow Monitoring Program (Appendix A). Thus, the infiltration and inflows are reasonable and reflect the actual behavior of the wastewater collection system.

3.3.2 Wastewater Collection System Flow Monitoring

In 2020, V&A's services were used for a temporary flow monitoring program to capture 14 sites during dry and wet weather flows, which are summarized on Figure 3.6.

There were six rain gauges used for the wet weather analysis. The rainfall historical data was then determined by weighted average of those six rain gauges. The six rain gauges were located in the City of Beaumont as shown in **Figure 3.6**. The flow monitoring and rain data were used in this analysis to calibrate the computer hydraulic model to average dry weather flow and wet weather flow conditions.

3.3.3 10-Year 24-Hour Design Storm

A synthetic design storm is typically used to evaluate the sewer collection system's response during wet weather flow conditions. The design storm information was collected from the National Oceanic and Atmospheric Administration (NOAA) Atlas 14 Volume 6 (Table 3.4).

- **10-Year Frequency.** Industry standards include design storms that range between 5-year and 20-year events. Based on current regulatory trends, a 10-year storm event was chosen for the City to evaluate the capacity adequacy of the wastewater collection system.
- **24-Hour Duration.** Peak flows from a storm event are usually cause by brief intense rains, that can happen as part of an individual event or as a portion of a larger storm. The 24-hour storm duration is longer than needed to determine peak flow but aids in identifying infiltration and inflows a wastewater collection system may experience during a storm event.
- Balanced Rainfall Centered Distribution. The National Resources Conservation Service, previously known as the Soil Conservation Service, has developed rainfall distributions for wide geographic regions based on traditional Depth-Duration-Frequency (DDF) rainfall data. In this methodology, the highest rainfall intensity is placed at the center of the storm. Incrementally lower intensities are placed on alternating sides of the peak.

Thus, the NOAA Atlas 14 Depth Duration Frequency (DDF), 10-year 24-hour (10yr-24hr) design storm, with a balanced rainfall distribution, was used to evaluate the capacity adequacy of the City's wastewater collection system during wet weather flow conditions.

The selected 10-year 24-hour design storm was further compared to historical storm events used for the calibration process, between February 2020 and April 2020, as shown on Table 3.5. The table lists the total rainfall volume, duration, peak hour intensity, and total rainfall depth (if available) for each storm event.




Table 3.4 Precipitation Depth-Duration-Frequency

Wastewater Master Plan

City of Beaumont

Duration	1-)	'ear	2-Y	'ear	5-Y	'ear	10-	Year	25-`	Year	100	-Year
Duration	(in)	(in/hr)	(in)	(in/hr)	(in)	(in/hr)	(in)	(in/hr)	(in)	(in/hr)	(in)	(in/hr)
5-min	0.12	1.48	0.16	1.94	0.22	2.66	0.28	3.32	0.37	4.38	0.53	6.41
10-min	0.18	1.06	0.23	1.40	0.32	1.91	0.40	2.39	0.52	3.14	0.77	4.59
15-min	0.21	0.85	0.28	1.12	0.39	1.54	0.48	1.92	0.63	2.53	0.93	3.70
30-min	0.31	0.62	0.41	0.81	0.56	1.11	0.70	1.39	0.92	1.83	1.34	2.68
1-hr	0.45	0.45	0.60	0.60	0.82	0.82	1.02	1.02	1.34	1.34	1.96	1.96
2-hr	0.65	0.32	0.81	0.40	1.05	0.53	1.27	0.64	1.62	0.81	2.27	1.14
3-hr	0.79	0.26	0.97	0.32	1.24	0.41	1.48	0.49	1.85	0.62	2.54	0.85
6-hr	1.15	0.19	1.40	0.23	1.76	0.29	2.07	0.35	2.54	0.42	3.38	0.56
12-hr	1.57	0.13	1.96	0.16	2.48	0.21	2.92	0.24	3.55	0.30	4.58	0.38
24-hr	2.11	0.09	2.73	0.11	3.55	0.15	4.21	0.18	5.12	0.21	6.52	0.27
A R E	UP, INC.											1/3/2020

Note:

PRELIMINARY

Source: Noaa Atlas 14 For City Of Beaumont Volume 6 Version 2.


Table 3.5 Storm Events Analysis

Wastewater Master Plan City of Beaumont

PRELIMINARY

	Estimated Return	Single Rainfall Event Volume and Intensity			
Storm Event	Interval	Volume	Peak Intensity		
		(in)	(in//hr)		
March 10 - March 11, 2020	2-Year 6-Hour	1.45	0.31		
March 12 - March 13, 2020	5-Year 12-Hour	2.69	0.64		
Design Storm	10-Year 24-Hour	4.21	0.88		
ENGINEERING GROUP, INC.			2/11/2021		

Figure 3.7 is intended to show the diurnal comparison between the design storm and the two storm events experienced during March of 2020. The comparison indicates that, based on the balanced centered hyetograph, the design storm's peak hour value is at 0.89 inches per hour (in/hr), while the March 10th and 12nd storms peak values are respectively 0.31 and 0.64 in/hr respectively. This comparison illustrates the more conservative nature of the design storm.



CHAPTER 4 - EXISTING WASTEWATER COLLECTION FACILITIES

This chapter provides a description of the City's existing wastewater collection system facilities including gravity trunks, force mains, lift stations, and sewer collection basins. The chapter also includes a brief description of the City's WWTP, which treats and disposes of the wastewater for the City.

4.1 WASTEWATER COLLECTION SYSTEM OVERVIEW

The City provides wastewater collection services to approximately 15,671 residential, commercial, public facilities and institutional accounts. The City's existing wastewater collection system consists of approximately 196 miles of gravity mains and force mains, and 10 lift stations that convey flows to the City's WWTP as summarized on Table 4.1.

The City's existing wastewater collection system is shown in **Figure 4.1**, which displays the existing system by pipe size. This figure provides a general color coding for the collection mains, as well as labeling the existing lift stations.

4.2 WASTEWATER COLLECTION BASINS AND TRUNKS


Based on the varying topography and numerous lift stations, the sewer system is divided into multiple collection basins that collect flows from smaller developments and route that flow to larger sewer trunk lines. These basins are based on the areas tributary to the flow monitors installed as part of the 2020 V&A flow monitoring program as discussed in a previous chapter. These collection basins are shown on Figure 4.2 and summarized in the following section.

4.2.1 Fairway Canyon Collection Basin

The Fairway Canyon collection basin encompasses approximately 108 acres in the northwest portion of the City of Beaumont service area, north of Palmer Avenue and west of Armour Avenue. Flows are collected in an 8-inch gravity pipeline along Crenshaw Street before entering the Fairway Canyon Lift Station. This collection basin is discharged to the Lower Oak Valley Lift Station at Palmer Avenue via an 8-inch force main.

4.2.2 Lower Oak Valley Collection Basin

The Lower Oak Valley collection basin encompasses approximately 645 acres in the northwest portion of the City of Beaumont service area, generally north of Oak Valley Parkway and west of Plantation Drive. Flows are collected in a 15-inch pipeline along Champions Drive to Palmer Avenue before being conveyed to the Lower Oak Valley Lift Station. This collection basin also includes flows tributary to the Fairway Canyon Lift Station. This collection basin is discharged to the Upper Oak Valley Lift Station at Oak Valley Parkway via dual 10-inch and 14-inch force mains.






Table 4.1 Existing Wastewater Pipeline Inventory

Wastewater Master Plan City of Beaumont

			PRELIMINAR
Pipeline Diameter	Leng	;th	Percent Contribution
(in)	(ft)	(mi)	% Total
Gravity Mains			
4	883	0.2	0.1%
6	2,612	0.5	0.3%
8	759,884	143.9	73.4%
10	28,526	5.4	2.8%
12	59,788	11.3	5.8%
15	48,929	9.3	4.7%
16	1,898	0.4	0.2%
18	7,782	1.5	0.8%
24	13,012	2.5	1.3%
30	8,890	1.7	0.9%
48	222	0.04	0.02%
Unknown	226	0.04	0.02%
Subtotal - Gravity Mains	932,653	176.6	90.1%
Force Mains			
6	1,060	0.2	0.1%
8	33,208	6.3	3.2%
10	17,254	3.3	1.7%
12	31,787	6.0	3.1%
14	18,776	3.6	1.8%
Subtotal - Force Mains	102,086	19.3	9.9%
Total Sewer Pipe			
Total	1,034,739	196.0	100.0%
AKEL ENGINEERING GROUP, INC. Note:			2/3/202

Source: Sewer System GIS provided by City staff on November 20, 2019.

4.2.3 Upper Oak Valley Collection Basin

The Upper Oak Valley collection basin encompasses approximately 930 acres in the north portion of City of Beaumont service area and is generally divided into two sections. The first section collects flows north of Oak Valley Parkway west of Desert Lawn Drive, which are ultimately conveyed by a 12-inch gravity main on Oak Valley Parkway. The second section consists of two separate 12-inch and 15-inch gravity main along Deodar Road and Monte Verde Drive collects flows before combining into a 15-inch gravity main under Interstate-10 which are then discharged to an existing 15-inch gravity main on Bay Hill Drive. These flows are eventually conveyed to Upper Oak Valley Lift Station on Oak Valley Parkway. This collection basin also includes flows tributary to the Fairway Canyon Lift Station and Lower Oak Valley Lift Station. This collection basin is discharged to the Beaumont Mesa Lift Station at Potrero Boulevard via dual 12-inch force mains.

4.2.4 Olivewood Collection Basin

The Olivewood collection basin encompasses approximately 313 acres in the west portion of the City of Beaumont service area, generally south of Oak Valley Parkway and west of Potrero Boulevard. Flows are collected by an 8-inch gravity mains along Castello Lane and Artisan Place before entering Olivewood Lift Station. This collection basin is discharged to the Beaumont Mesa Lift Station at Potrero Boulevard via 8-inch force main.

4.2.5 Noble Creek Collection Basin

The Noble Creek collection basin encompasses approximately 1,210 acres in the north portion of the City of Beaumont service area, south of Brookside Avenue north of Oak Valley Parkway between Interstate-10 and Beaumont Avenue. Two separate 10-inch and 15-inch gravity mains along Oak View Drive and Golf Club Drive respectively collects flows before combining into 18-inch gravity main on Oak Valley Parkway. These flows are eventually conveyed to Noble Creek Lift Station. This collection basin is discharged to the Marshall Creek Lift Station at Ring Ranch Road via 12-inch force main.

4.2.6 Marshall Creek Collection Basin

The Marshall Creek collection basin encompasses approximately 136 acres in the central portion of the City of Beaumont service area, generally east of Interstate 10, west of Claiborne Avenue and south of Florence Street. Flows are collected by 8-inch gravity mains along Ring Ranch Road before entering Marshall Creek Lift Station. This collection basin also includes flows tributary to Noble Creek Lift Station. This collection basin is discharged to the existing wastewater manhole at 8th Street via dual 10-inch and 12-inch force mains.

4.2.7 Industrial Park Collection Basin

The Industrial Park collection basin encompasses approximately 63 acres in the central portion of the City of Beaumont service area, south of Highway 60 between Distribution Way and Minnesota Avenue. Two separate 8-inch gravity mains on Nicholas Road and 4th Street collect flows before

combining into a 8-inch gravity main on Risco Circle. These flows are eventually conveyed to the Industrial Park Lift Station. This collection basin is discharged to the Beaumont Wastewater Treatment Plant at 4th Street via 6-inch force main.

4.2.8 Beaumont Collection Basin

The Beaumont collection basin encompasses approximately 1,155 acres in the north portion of the City of Beaumont service area, generally west of Palm Avenue, north of 4th Street and south of Brookside Avenue. Flows are collected by 12-inch and 15-inch pipelines along Luis Estrada Road and Elm Avenue before entering an existing 24-inch gravity main on Veile Avenue. This collection basin also includes flows tributary to Marshall Creek Lift Station.

4.2.9 Pennsylvania Collection Basin

The Pennsylvania collection basin encompasses approximately 1,810 acres in the north portion of the City of Beaumont service area, generally bound by Brookside Avenue and 1st Street from north to south and Palm Avenue to Highland Springs Avenue from west to east and divided into two sections. The first section collect flows by existing 12-inch gravity pipelines along Starlight Avenue. The second sections collected flows by existing 8-inch, 10-inch, and 15-inch gravity pipelines along Cherry Avenue before combining into a 24-inch gravity pipelines along American Avenue. This collection basin also includes flows from Highland Springs collection basin.

4.2.10 Highland Springs Collection Basin

The Highland Springs collection basin encompasses approximately 418 acres in the northeast portion of the City of Beaumont service area, generally west of Bellflower Avenue and north of Brookside Avenue. Existing 8-inch gravity pipelines collect flow along Brookside Avenue before being conveyed to existing 8-inch gravity pipelines along Cherry Avenue.

4.2.11 Seneca Springs Collection Basin

The Seneca Springs collection basin encompasses approximately 417 acres in the south portion of the City of Beaumont service area, generally west of Highland Springs Avenue, east of Beaumont Avenue, and south of 2nd Street. Two separate 8-inch and 16-inch gravity mains along Potrero Boulevard collects flows before combining into Seneca Springs Lift Station. This collection basin is discharged to the existing wastewater manhole at 1st Street and Michigan Avenue via dual 8-inch force mains.

4.2.12 Four Seasons Collection Basin

The Four Seasons collection basin encompasses approximately 869 acres in the southeast portion of the City of Beaumont service area, generally west of Highland Springs Avenue and south of 8th Street. Existing 10-inch, 12-inch and 15-inch gravity pipelines along Highland Springs Avenue collects flows before conveying into Four Seasons Lift Station. This collection basin is discharged to the existing wastewater manhole at 1st Street and Michigan Avenue via dual 8-inch and 14-inch force mains.

4.3 LIFT STATIONS

When routing flows by gravity is not possible due to adverse grades, lift stations are used to pump flows. The City currently maintains ten lift stations in the wastewater collection system, summarized on Table 4.2, and shown on Figure 4.2. Additionally, a flow diagram summarizing the connectivity of the existing lift stations is shown on Figure 4.3.

- **Fairway Canyon Lift Station.** The lift station is located at the northern end of Creenshaw Street. The lift station includes 2 canned pumps that are each rated at 400 gpm. The pumps discharges into an 8-inch force main that conveys flows southeast toward Lower Oak Valley Lift Station.
- Lower Oak Valley Lift Station. The lift station is located on Palmer Avenue, southwest of Morris Street and was built in 2005. The lift station includes 2 duty pumps and 1 standby pump that are rated at 650 gpm and 400 gpm respectively. The pump discharges into a parallel 8-inch and 10-inch force main that conveys flows southeast along Oak Valley Parkway toward Upper Oak Valley Lift Station.
- **Upper Oak Valley Lift Station.** The lift station is located on Oak Valley Parkway, west of Apron Lane and was built in 2004. The lift station includes 2 duty pumps and 1 standby pump that are rated at 1,350 gpm and 2,300 gpm respectively. The pump discharges into a parallel 12-inch force main that conveys flows north toward Beaumont Mesa Lift Station.
- Olivewood Lift Station. This lift station is located approximately 675 feet northwest of the intersection of Artisan Place and Castello Lane. The lift station includes 2 duty pumps that are both rated at 310 gpm. The pump discharges into an 8-inch force main that conveys flows east along Castello Lane toward Beaumont Mesa Lift Station.
- Beaumont Mesa Lift Station. This lift station is located southeast corner of Castello Lane and Potrero Boulevard, constructed prior 2006 and was rehabilitated in 2020. While this lift station was originally designed to include four pumps, two at 3,500 gpm and two at 1,500 gpm, the current configuration includes 2 duty pumps that are both rated at 1,797 gpm. The pump discharges into a 12-inch force mains that convey flows southeast toward 4th Street.
- Noble Creek Lift Station. The lift station is located approximately 200 feet south of Oak Valley Parkway and was built in 2001. The lift station includes 2 duty pumps that are both rated at 1,865 gpm. The pump discharges into a 12-inch force main that conveys flows southeast along Interstate 10 toward Marshall Creek Lift Station.
- Marshall Creek Lift Station. The lift station is located at the northern end of Ring Ranch Road and was built in 2001. The lift station includes 2 duty pumps that are both rated at 1,150 gpm. The pump discharges into a 10-inch and 12-inch force main that conveys flows southeast along Ring Ranch Road toward Veile Avenue.




Table 4.2 Lift Station Inventory

Wastewater Master Plan

City of Beaumont

Lift Station	nformation		Ρι	umps ¹				Pump Co	ontrols ²			Wet \	Nell Dimer	MINARY
No.	Location	Quantity	Full Capacity	Firm Capacity	Current Capacity	High Level	Low Level			Lag 2 On	Lag 2 Off	Area	Depth	Volume
			(gpm)	(gpm)	(gpm)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft)	(ft ²)	(ft)	(gal)
Beaumont Mesa	12940 Potrero Blvd.	2 @ 1,797 gpm	3,594	1,797	3,594	21.50	2.00	9.50	7.00	12.00	7.00	697.4	21.0	109,59
Fairway Canyon ³ (Little Lower Oak Valley)	34003 Crenshaw St.	2 @ 400 gpm	800	400	800	8.33	2.92	6.61	3.58	7.83	6.61	50.3	11.50	2,022
Lower Oak Valley	11246 Palmer Ave.	2 @ 650 gpm 1 @ 400 gpm	1,700	1,050	1,700	7.50	1.50	4.00	2.00	7.00	2.00	212.7	16.5	26,25
Marshall Creek	990 Ring Ranch Rd.	2 @ 1,150 gpm	2,300	1,150	2,300	10.75	8.08	9.75	8.25	10.50	8.25	223.9	18.0	30,14
Noble Creek	1899 W Oak Valley Pkwy.	2 @ 1,865 gpm	3,730	1,865	3,730	6.00	1.50	4.25	2.00	5.75	2.00	180.8	14.5	19,60
Seneca Springs	1390 Potrero Blvd.	3 @ 450 gpm	1,350	900	1,125	6.00	1.25	4.50	2.50	5.50	2.50	184.7	31.5	43,51
Upper Oak Valley	35980 Oak Valley Pkwy.	2 @ 1,350 gpm 1 @ 2,300 gpm	5,000	2,700	5,000	7.50	1.00	4.50	2.50	7.00	2.50	345.7	19.5	51,28
Four Seasons	1075 S Highland Springs Ave.	2 @ 1,675 gpm 1 @ 365 gpm	3,715	1,740	1,675	9.50	1.50	4.75	2.25	9.00	4.75	249.6	22.0	41,07
Industrial Park ⁴ (Coopers Creek)	715 W 4th St.	1 @ 112 gpm 1 @ 150 gpm	262	112	262	6.00	1.00	5.75	2.00	5.75	2.00	58.7	16.0	7,022
Olivewood	North of Artisan Pl.	2 @ 310gpm	620	310	620	6.25	2.00	5.25	3.00	5.75	3.00	50.3	19.5	7,332
														5/26/2

Notes:

1. Source: Pumps information provided by City staff on December 13, 2019.

2. Unless noted otherwise, pump controls and wet well dimensions provided by City staff on March 04, 2020.

3. Fairway Canyon wet well dimensions provided by City staff on April 28, 2021.

4. Industrial Park pump information provided by City Staff on May 26, 2020.

- Industrial Park (Coopers Creek) Lift Station. The lift station is located at the end of Risco Circle southwest of Beaumont WWTP and was built in 2003. The lift station includes 2 duty pumps that are rated at 112 gpm and 150 gpm. The pump discharges into a 6-inch force main that conveys flows east toward Beaumont WWTP.
- Seneca Springs Lift Station. The lift station is located on Potrero Boulevard between Berkshire Avenue and Seneca Springs Parkway, and was built in 2005. The lift station includes 3 duty pumps that are both rated at 450 gpm. The pump discharges into a parallel 8-inch force main that conveys flows west toward 24-inch gravity pipeline on 1st Street.
- Four Seasons Lift Station. The lift station is located on Highland Springs Avenue approximately 300 ft south of Breckenridge Avenue Berkshire Avenue, and was built in 2005. The lift station includes 2 duty pumps and 1 standby pump that are rated at 1,675 gpm and 365 gpm respectively. The pump discharges into a 8-inch and 14-inch force main that conveys flows west toward existing 24-inch gravity pipeline on 1st Street.

Table 4.2 lists each lift station with relevant information obtained from the City's records including:lift station number, location, wet well dimensions, and number of pumps and respective capacities.The lift stations are operated to turn "on" or "off" based on the levels in their wet wells.

4.4 BEAUMONT WASTEWATER TREATMENT PLANT

Beaumont Wastewater Treatment Plant (WWTP) treats on average 3.66 mgd of sewer flows, collected flows from 11 different tributary basins including: Fairway Canyon, Lower Oak Valley, Upper Oak Valley, Olivewood, Noble Creek, Marshall Creek, Industrial Park, Pennsylvania, Highland Springs, Beaumont, Seneca Springs, and Four Seasons. The wastewater treatment plant currently services approximately 52,000 people, in addition to non-residential users.

A recent expansion at the WWTP included constructing a 12-inch diameter brine waste disposal gravity pipeline extending 23 miles from the WWTP north to the nearest connection point of the Inland Empire Brine Line, located near the north side of E Street Bridge in the City of San Bernardino.

It should be noted that this wastewater master plan focuses on the capacity adequacy of the existing conveyance infrastructure, including gravity and force main pipelines, as well as lift stations. This wastewater master plan does not include any evaluations at the wastewater treatment plant, including treatment facilities, capacities, or redundancies.



CHAPTER 5 – WASTEWATER FLOWS

This chapter summarizes historical wastewater flows experienced at the Beaumont WWTP and defines flow terminologies relevant to this evaluation. This chapter discusses the wastewater flow distribution within the collection basins and identifies the design flows used in the hydraulic modeling effort and capacity evaluation. The design flows include the flows due to existing conditions and buildout development conditions.

5.1 FLOWS AT THE BEAUMONT WWTP

The wastewater flows collected and treated at the City of Beaumont WWTP vary monthly, daily, and hourly. While the dry weather flows are influenced by customer uses, the wet weather flows are influenced by severity of storm events and the condition of the system. **Figure 5.1** shows the monthly flows versus rainfall at the Beaumont WWTP for 2019. August and November were the maximum months during 2019, with November also being higher than average due to the considerable amount of rain received that month.

Flow data influent to the City of Beaumont WWTP was obtained from City operation staff. The flow data covered a period from 2012 to 2019. From this data monthly, daily, and peak daily flows, were determined as summarized on Table 5.1.

The following definitions are intended to document relevant terminologies shown on Table 5.1:

- Average Annual Flow (AAF). The average annual flow is the total annual flow, or average monthly flow, for a given year, expressed in daily or other time units. This flow includes the combined average of the average dry weather flow (ADWF) and average wet weather flow (AWWF).
- Average Dry Weather Flow (ADWF). The average dry weather flow occurs on a daily basis during the dry weather season, with no evident reaction to rainfall. The ADWF also includes the Base Wastewater Flow (BWF). The base wastewater flow is the average flow that is generated by residential, commercial, and industrial users. The flow pattern from these users varies depending on land use types.
- Average Wet Weather Flow (AWWF). This average wet weather flow occurs on a daily basis during the wet weather season. In addition to the flow components in the ADWF, the AWWF includes infiltration and inflow from storm rainfall events.
- Maximum Month Dry Weather Flow (MMDWF). This maximum month flow occurs during the dry weather season.
- Maximum Month Wet Weather Flow (MMWWF). This maximum month flow occurs during the wet weather season.




Table 5.1 Wastewater Treatment Plant - Historical Flow Data and Peaking Factors

Wastewater Master Plan

City of Beaumont

Maran	Average Annual	Average Annual Percentage		Average	Maximu	m Month	Maximum Day		
Year	Flow (AAF)	Change		AWWF ²	MMDWF	MMWWF	MDDWF	MDWWF	
	(mgd)		(mgd)	(mgd)	(mgd)	(mgd)	(mgd)	(mgd)	
2012	2.68		2.70	2.67	2.74	2.80	3.12	3.18	
2013	2.79	3.9%	2.68	2.90	2.82	3.12	3.40	3.50	
2014	2.98	6.9%	2.97	2.99	3.02	3.19	3.50	3.62	
2015	2.92	-1.8%	2.91	2.94	2.97	3.05	3.86	3.58	
2016	2.83	-3.4%	2.80	2.86	2.91	3.29	3.27	5.26	
2017	3.27	15.8%	-	-	-	-	-	-	
2018	3.39	3.7%	3.40	3.38	3.51	3.51	-	-	
2019	3.66	8.0%	3.66	3.67	3.72	3.77	4.14	5.07	
2020	-	-	-	-	-	4.01	-	4.57	
		н	istorical Pea	king Factors (Applied to Al	OWF)			
2012	1.00		1.00	0.99	1.02	1.04	1.16	1.18	
2013	1.04		1.00	1.08	1.05	1.17	1.27	1.31	
2014	1.00		1.00	1.01	1.02	1.07	1.18	1.22	
2015	1.00		1.00	1.01	1.02	1.05	1.33	1.23	
2016	1.01		1.00	1.02	1.04	1.18	1.17	1.88	
2017	-		-	-	-	-	-	-	
2018	1.00		1.00	0.99	1.03	1.03	-	-	
2019	1.00		1.00	1.00	1.02	1.03	1.13	1.39	
2020	-		-	-	-	-	-	-	
			Recommend	led Evaluatio	n Peaking Fac	tor			
				1.08	1.05	1.18	1.33	1.88	

Notes :

1. Source: 2012-2016 WWTP flows extracted from the City of Beaumont 2017 Inflow and Infiltration Study.

2. Source: 2017-2019 City Flow data provided by City staff on February 18, 2020.

3. Source: Hourly influent flows at the WWTP for the period of 02/20/20 to 04/09/20 provided by City staff on May 1, 2020.

- Maximum Day Dry Weather Flow (MDDWF). This is the highest measured daily flow that occurs during a dry weather season.
- Maximum Day Wet Weather Flow (MDWWF). This is the highest measured daily flow that occurs during a wet weather season.
- **Peak Dry Weather Flow (PDWF).** This is the highest measured hourly flow that occurs during a dry weather season.
- **Peak Wet Weather Flow (PWWF).** This is the highest measured hourly flow that occurs during a wet weather season.

Table 5.1 shows the average annual flows (AAF) collected at the City of Beaumont WWTP haveincreased from 2.68 mgd in 2012 to 3.66 mgd in 2019, which is an increase of approximately37%.

In addition to listing the 2012-2019 flows, and for comparison purposes, the table calculates the peaking factors applied to the corresponding average dry weather flows (ADWF) for each year. During wet weather flows in 2019, the maximum daily volume (MDWWF) contributed by the City at the City of Beaumont WWTP was 1.39 times higher than the average dry weather flow for the same year.

5.2 BUILDOUT WASTEWATER FLOWS

The land use methodology was used to estimate the buildout wastewater flows from City's Planning Area and to be consistent with the General Plan. Table 5.2 documents the total acreages for residential and non-residential land use, and the undeveloped lands designated for urbanization. The undeveloped lands were multiplied by the corresponding unit flow factor to estimate the wastewater flows. The buildout average daily flows were calculated at 17.8 mgd. Figure 5.2 documents the general hydraulic model allocation locations and methodology for the areas of future development.

5.3 WASTEWATER COLLECTION SYSTEM DESIGN FLOWS

The design flows most relevant in this capacity analysis of the wastewater collection system, in addition to the Maximum Day Dry Weather Flows (MDDWF), include the peak dry weather flow (PDWF) and peak wet weather flow (PWWF).

- **Peak Dry Weather Flow (PDWF).** The PDWF is used for evaluating the capacity adequacy of the wastewater collection system, and to meet the criteria set forth in the previous chapter and in the City standards.
- **Peak Wet Weather Flow (PWWF).** The PWWF is used for designing the capacity of the wastewater collection system, and to meet the criteria set forth in the previous chapter and in the City standards.




Table 5.2 Future Wastewater Flow Summary

Wastewater Master Plan

City of Beaumont

	Existing	Developmen	t		Future Develop	nent within Study Area	1				
Land Use Type	Existing Lands, No Redevelopment	Sewer Unit Factor	Average Daily Flow	Lands Planned for Redevelopment	New Development	Subtotal Future Development	Sewer Unit Factor	Average Dry Weather Flow	Total Development at Buildout of Study Area	Total Average [Flov	
1	(acre) 2	(gpd/acre) 3	(gpd) 4	(acre) 5	(acre) 6	(acre) 7	(gpd/acre) 8	(gpd) 9	(acre) 10	(gpd) 11	(gpd) 12
General Plan Residential											
Single Family Residential	2,389	1,396	3,335,391	118	588.3	706	1,396	986,125	3,096	4,321,516	4.32
High Density Residential	83	2,609	215,334	6	276.1	282	2,609	735,343	364	950,677	0.95
Rural Residential	0	611	0	2,446	312.3	2,758	611	1,685,107	2,758	1,685,107	1.69
Subtotal - General Plan Residential	2,472		3,550,725	2,570	1,176.7	3,746		3,406,575	6,218	6,957,301	6.96
General Plan Non-Residential											
General Commercial	242	1,175	284,837	28	323.8	352	1,175	413,753	595	698,590	0.70
Neighborhood Commercial	0	1,175	0	34	11.5	46	1,175	53,539	46	53,539	0.05
Industrial	211	1,763	371,281	52	315.2	367	1,763	646,780	577	1,018,062	1.02
Public Facility	280	800	224,260	44	63.6	107	800	85,932	388	310,191	0.31
Subtotal - General Plan Non-Residential	733		880,378	158	714.0	872		1,200,004	1,605	2,080,381	2.08
General Plan Overlays											
Traditional Neighborhood ¹	0	-	0	76	498.8	574	-	692,049	574	692,049	0.69
Downtown Mixed Use ¹	0	-	0	321	64.4	386	-	578,272	386	578,272	0.58
Urban Village ¹	0	-	0	107	536.0	643	-	1,041,439	643	1,041,439	1.04
Employment District ¹	0	-	0	0	179.1	179	-	216,814	179	216,814	0.22
Subtotal - General Plan Overlays	0		0	504	1,278.4	1,782		2,528,575	1,782	2,528,575	2.53
Known Developments											
Specific Plan and Other Developments ²	0	-	0	0	4,199.7	4,200	-	6,214,824	4,200	6,214,824	6.21
Subtotal - Known Developments	0		0	0	4,199.7	4,200		6,214,824	4,200	6,214,824	6.21
Total											
	3,205		4,431,103	3,231	7,368.8	10,600		13,349,978	13,805	17,781,081	17.78

Notes:

1. Development flows for Overlay Areas documented in Table 2, General Plan Overlay Development and Flows

2. Specific Plan and Other Development flows documented in Table 5, Specific Plan and Other Development, Remaining Development Flows

PRELIMINARY

The design flows used in evaluating the capacity adequacy of the wastewater collection system are summarized on **Table 5.3**. The table lists the maximum day and peak hour flows for dry and wet weather conditions. PDWF and PWWF used for evaluating the existing wastewater collection system were estimated at 9.3 mgd and 9.8 mgd respectively. The PDWF and PWWF used for designing the General Plan buildout system, including growth, were estimated at 31.2 mgd and 27.9 mgd respectively. It should be noted that the flows shown on **Table 5.3** are extracted from the wastewater system hydraulic model and reflect diurnal flow variations and flow attenuation.

Table 5.3 Design Flows

Wastewater Master Plan City of Beaumont

PRELIMINARY

Description	Flo	w
	Maximum Day	Peak Hour
	(mgd)	(mgd)
Existing Condition Scenarios		
Existing DWF	5.79	9.27
Existing WWF (10Yr-24HR Design Storm)	5.88	9.76
Ultimate Buildout Scenarios		
Buildout DWF	21.14	31.18
Buildout WWF (10Yr-24HR Design Storm)	18.98	27.85
ENGINEERING GROUP, INC.		2/18/2021

Notes:

1. Flows shown are extracted from wastewater system hydraulic model and reflect diurnal flow variations and flow attenuation.

CHAPTER 6 - HYDRAULIC MODEL DEVELOPMENT

This chapter describes the development and calibration of the City's wastewater collection system hydraulic model. Hydraulic network analysis has become an effectively powerful tool in all aspects of wastewater system planning, design, operation, management, and system reliability analysis. The City's hydraulic model was used to evaluate the capacity adequacy of the existing system and to plan its expansion to service anticipated future growth.

6.1 HYDRAULIC MODEL SOFTWARE SELECTION

The City's hydraulic model combines information on the physical characteristics of the wastewater collection system (pipelines, manholes, and lift stations) and operational characteristics (how they operate). The hydraulic model then performs calculations and solves series of equations to simulate flows in pipes, including backwater calculations for surcharged conditions.

There are several network analysis software products released by different manufacturers that can equally perform the hydraulic analysis satisfactorily. The selection of a particular software depends on user preferences, the wastewater collection system's unique requirements, and the costs for purchasing and maintaining the software.

The hydraulic modeling software used for evaluating the capacity adequacy of the City's wastewater collection system, InfoSWMM by Innovyze Inc., utilizes the fully dynamic St. Venant's equation which has a more accurate engine for simulating backwater and surcharge conditions, in addition to having the capability for simulating manifolded force mains. The software also incorporates the use of the Manning Equation in other calculations including upstream pipe flow conditions. The St Venant's and Manning's equations are discussed in the System Performance and Design Criteria chapter.

6.2 HYDRAULIC MODEL DEVELOPMENT

Developing the hydraulic model included system skeletonization, digitizing and quality control, developing pipe and manhole databases, and wastewater loading allocation.

6.2.1 Skeletonization

Skeletonizing the model refers to the process where pipes not essential to the hydraulic analysis of the system are stripped from the model. Skeletonizing the model is useful in creating a system that accurately reflects the hydraulics of the pipes within the system. In addition, skeletonizing the model will reduce complexities of large models, which will also reduce the time of analysis while maintaining accuracy, but will also comply with the limitations imposed by the computer program.

The hydraulic model for the City of Beaumont was skeletonized to include the pipelines essential to the hydraulic analysis. By comparison, skeletonizing was necessary to reduce the model from

4,300 pipes extracted from GIS to 800 pipes; the total system includes approximately 196 miles of pipe, whereas the hydraulic model includes approximately 56 miles of pipelines. The modeled pipes included pipes 8-inches in a diameter and larger, in addition to some critical smaller gravity wastewater pipes.

Table 6.1 documents the inventory of pipelines included in the hydraulic model by diameter and isapproximately 28 percent of the overall system. The modeled wastewater collection system isshown on Figure 6.1.

6.2.2 Digitizing and Quality Control

The City's existing wastewater collection system was digitized in GIS using several sources of data and various levels of quality control. The data sources included the City's existing system as documented in GIS drawings and schematics provided by City staff.

After reviewing the available data sources, the hydraulic model was built and verified by City staff. Using the available wastewater collection system data this master plan developed the wastewater collection system in GIS. Resolving discrepancies in data sources was accomplished by conducted manhole field surveys that recorded the rim elevations, pipe invert elevations, as well as the physical manhole location. Data received were incorporated in the verified model.

6.2.3 Pipes and Manholes

Computer modeling requires the compilation of large numerical databases that enable data input into the model. Detailed physical aspects, such as pipe size, ground elevation, invert elevations, and pipe lengths contribute to the accuracy of the model.

Pipes and manholes represent the physical aspect of the system within the model. A manhole is a computer representation of a place where wastewater flows may be allocated into the hydraulic system, while a pipe represents the conveyance aspect of the wastewater flows. In addition, selected lift station capacity and design head settings were also included into the hydraulic model.

6.2.4 Load Allocation

Load allocation consists of assigning wastewater flow to the appropriate manholes (nodes) in the model. The goal is to distribute the loads throughout the model to best represent actual system response.

The existing loading allocation was based off the water billing records. Using GIS, each customer account was geocoded and spatially joined within the existing wastewater collection system. Wastewater loads were developed by combining the flow factors developed in Chapter 3 with the water billing records for the City. The calculated loads were allocated to the nearest manhole that serves the corresponding customers.

Wastewater loads from each anticipated future development, as presented in previous chapters, were also allocated to the model for the purpose of sizing the required future facilities. The loads




Table 6.1 Existing Modeled Pipeline Inventory

Wastewater Master Plan City of Beaumont

City of Beaum			PRELIMINARY
Pipeline Diameter	Leng	gth	Percent Contribution
(in)	(ft)	(mi)	% Total
Gravity Mains			
8	18,847	3.6	6.4%
10	27,947	5.3	9.5%
12	59,569	11.3	20.3%
15	48,834	9.2	16.6%
16	1,898	0.4	0.6%
18	7,829	1.5	2.7%
24	12,336	2.3	4.2%
30	8,890	1.7	3.0%
Subtotal	186,151	35.3	63.4%
Force Mains			
6	1,060	0.2	0.4%
8	33,212	6.3	11.3%
10	17,260	3.3	5.9%
12	31,796	6.0	10.8%
14	18,941	3.6	6.5%
16	5,058	1.0	1.7%
Subtotal	107,327	20.3	36.6%
Total Modeled Pipe			
	293,478	55.6	100.0%
ENGINEERING GROUP, INC.			2/19/2021

from the General Plan Boundary were allocated based on proposed land use and the land use acreages. As many of the areas were very large in size, the loads were allocated evenly to the loading manholes within each area. Infill areas, redevelopment areas, and vacant lands were also included in the future load allocation.

6.3 MODEL CALIBRATION

Calibration is intended to instill a level of confidence in the flows that are simulated, and it generally consists of comparing model predictions to the 2020 V&A flow monitoring program, and making necessary adjustments.

6.3.1 Calibration Plan

Calibration can be performed for steady state conditions, which model the peak hour flows, or for dynamic conditions (24 hours or more). Dynamic calibration consists of comparing the model predictions to diurnal operational changes in the wastewater flows. The City's hydraulic model was calibrated for dynamic conditions.

In wastewater collection systems, and when using dynamic hydraulic modeling to evaluate the impact of wet weather flows, it is common practice to calibrate the model to the following three conditions:

- Peak dry weather flows.
- Peak wet weather flows from storm rainfall Event No. 1(12 March 2020 -13 March 2020)
- Peak wet weather flows from storm rainfall Event No. 2(9 March 2020 10 March 2020)

After the model is calibrated to these conditions, it is benchmarked and used for evaluating the capacity adequacy of the wastewater collection system, under dry and wet weather conditions.

6.3.2 2020 V&A Temporary Flow Monitoring Program

A temporary flow monitoring program was included in this project to validate the existing dry and wet weather flows from each wastewater collection basin. The program consisted of installing 14 flow meters, for a period of 8 weeks, from February 2020 to April 2020. Villalobos and Associates (V&A) was retained to install the flow meters, monitor rainfall, and perform an Infiltration and Inflow analysis. The selected flow monitoring sites are listed on Table 6.2 and shown on Figure 6.2. Additionally, Table 6.3 provided a calibration result summary for each of the respective sites monitored.

The 2020 V&A Flow Monitoring Program captured two rainfall events and included a summary report identifying areas of the City that were most affected by rain dependent infiltration and inflows. The two rainfall events experienced during the flow monitoring period varied in duration and intensity (Table 3.5), and provided an insight into the wastewater collection system response to storm conditions.




Table 6.2 Flow Monitor Locations

Wastewater Master Plan

City of Beaumont

PRELIMINARY

Site ID	Location Description	Pipe Size (in)	Manhole ID
Gravity Mair	n Flow Monitors		
FM-1	Cherry Avenue north of Mary Lane	8" N (In Pipe)	SSMH01048
FM-2	Minnesota Avenue approx 500' north of 4th Street	24" N (In Pipe)	SSMH01728
FM-3	California Avenue approx 400' north of 1st Street	30" N (In Pipe)	SSMH00381
FM-4	6th Street approx 400' west of American Avenue	24" E (In Pipe)	SSMH00330
Lift Station F	low Monitors		
FM-5	1075 South Highland Springs Road	-	LS-1 (Four Seasons)
FM-6	1390 Potrero Boulevard	-	LS-2 (Seneca Springs)
FM-7	990 Ring Ranch Road	-	LS-3 (Marshall Creek)
FM-8	1899 West Oak Valley Parkway	-	LS-4 (Noble Creek)
FM-9	715 West 4th Street	-	LS-5 (Industrial Park)
FM-10	35980 Oak Valley Parkway	-	LS-6 (Upper Oak Valley)
FM-11	11246 Palmer Avenue	-	LS-7 (Lower Oak Valley)
FM-12	34003 Crenshaw Street	-	LS-8 (Beaumont Mesa)
FM-13	12940 Potrero Boulevard	-	LS-9 (Olivewood)
FM-14	Castello Lane approx 450' north of Artisan Place	-	LS-10 (Fairway Canyon)

Notes:

1. GIS Manhole IDs based on GIS shapefiles provided by City staff November 18, 2019.

Table 6.3 Calibration Results Summary

Wastewater Master Plan City of Beaumont

Flov	w Monitoring ID	Units	Dry Period (Weekday)			Dry	Period (Weel	kend)		Weather (Eve Irch 12- March			Weather (Events of the second	
			Minimum	Maximum	Average	Minimum	Maximum	Average	Minimum	Maximum	Average	Minimum	Maximum	Avera
	Flow Monitored	(mgd)	0.018	0.156	0.066	0.017	0.166	0.073	0.017	0.351	0.127	0.014	0.191	0.08
S-1	Model	(mgd)	0.018	0.155	0.066	0.018	0.163	0.069	0.018	0.313	0.109	0.018	0.163	0.07
0-1	Difference	(mgd)	0.0002	-0.0009	0.0001	0.0009	-0.0024	-0.0043	0.0006	-0.0384	-0.0182	0.0035	-0.0288	-0.00
		(%)	1.36	-0.60	0.08	5.51	-1.43	-5.93	3.55	-10.94	-14.33	25.02	-15.03	-7.0
	Flow Monitored	(mgd)	0.334	1.077	0.791	0.329	1.202	0.783	0.319	1.955	0.965	0.290	1.407	0.87
S-2	Model	(mgd)	0.302	1.055	0.788	0.287	1.262	0.794	0.302	1.805	0.963	0.302	1.220	0.85
	Difference	(mgd)	-0.0320	-0.0224	-0.0023	-0.0416	0.0601	0.0111	-0.0168	-0.1500	-0.0016	0.0116	-0.1865	-0.01
	FI N N	(%)	-9.58	-2.08	-0.29	-12.64	5.00	1.42	-5.26	-7.67	-0.17	4.01	-13.26	-1.8
	Flow Monitored	(mgd)	0.195	1.471	0.955	0.150	1.687	1.026	0.169	2.839	1.240	0.194	2.102	1.05
S-3	Model	(mgd)	0.171	1.543	0.955	0.153	1.718	1.048	0.171	2.607	1.259	0.171	1.691	1.04
	Difference	(mgd)	-0.0234	0.0713	0.0001	0.0030	0.0304	0.0230	0.0027	-0.2318	0.0189	-0.0222	-0.4111	-0.00
	Flaw Maritanad	(%)	-12.01	4.84	0.01	2.01	1.80	2.24	1.62	-8.17	1.53	-11.48	-19.56	-0.5
	Flow Monitored	(mgd)	0.063	0.854	0.488	0.058	0.917	0.551	0.064	1.084	0.573	0.066	1.147	0.5
S-4	Model	(mgd)	0.067	0.852	0.489	0.064	0.903	0.552	0.067	1.100	0.588	0.067	0.910	0.5
	Difference	(mgd)	0.0040	-0.0024	0.0005	0.0063	-0.0147	0.0004	0.0025	0.0162	0.0152	0.0010	-0.2368	-0.00
	Flow Monitored	(%)	6.40 0.082	-0.28 0.399	0.11 0.254	10.82 0.078	-1.60 0.390	0.07	3.81 0.083	1.49 0.549	2.65 0.280	1.53 0.084	-20.65 0.404	- 1 . 0.2
	Model	(mgd) (mgd)	0.082	0.399	0.254	0.078	0.390	0.243	0.083	0.549	0.280	0.084	0.404	0.2
S-5	Model		0.0032		-0.0001	0.0044	-0.0094	-0.0019	0.0025	-0.0118	0.282	0.0012	0.0052	0.2
	Difference	(mgd)	3.93	-0.0022 - 0.56	-0.0001 -0.05	5.66	-0.0094 - 2.42	-0.0019 -0.79	0.0025 2.98	-0.0118 -2.15	0.0016	1.38	1.30	0.01 5.8
	Flow Monitored	(%) (mgd)	0.057	0.217	0.143	0.057	0.247	0.163	0.060	0.236	0.55	0.047	0.306	0.1
	Model		0.057	0.217	0.143	0.057	0.247	0.163	0.058	0.230	0.154	0.047	0.300	0.1
S-6	Model	(mgd)	0.0015	-0.0014	0.0001	0.0014	-0.0027	-0.0003	-0.0018	-0.0039	0.0056	0.0109	-0.0776	0.00
	Difference	(mgd) (%)	2.65	-0.0014 -0.66	0.0001	2.48	-0.0027 -1.09	-0.0003 -0.19	-0.0018 -3.03	-0.0039 - 1.67	3.68	22.99	-0.0776 -25.37	2.3
	Flow Monitored		0.118	0.595	0.416	0.115	0.768	0.431	0.080	1.062	0.521	0.113	0.711	0.4
	Model	(mgd)	0.118	0.586	0.416	0.113	0.708	0.431	0.080	0.958	0.321	0.113	0.666	0.4
S-7	Model	(mgd)	0.120	-0.0085	0.0002	0.123	-0.0562	-0.0080	0.0485	-0.1046	-0.0284	0.123	-0.0452	-0.0
	Difference	(mgd) (%)	6.54	-0.0085 -1.43	0.0002	6.92	-0.0302 -7.33	-0.0080 -1.85	60.59	-0.1040 -9.85	-0.0284 - 5.44	8.98	-0.0452 -6.36	-0.00
	Flow Monitored	(mgd)	0.076	0.341	0.241	0.072	0.394	0.242	0.069	0.560	0.286	0.074	0.375	0.2
	Model	(mgd)	0.070	0.341	0.241	0.072	0.394	0.242	0.003	0.572	0.284	0.074	0.375	0.2
S-8	Model	(mgd)	0.0009	-0.0006	0.0002	0.0005	-0.0043	-0.0011	0.0077	0.0122	-0.0023	0.0029	0.0126	0.00
	Difference	(mgu) (%)	1.18	-0.0000	0.08	0.66	-0.0040 -1.10	-0.45	11.03	2.18	-0.0020	3.90	3.36	0.00
	Flow Monitored	(mgd)	0.030	0.108	0.054	0.027	0.052	0.030	0.008	0.205	0.058	0.009	0.132	0.0
	Model	(mgd)	0.029	0.100	0.055	0.027	0.052	0.030	0.029	0.143	0.063	0.029	0.102	0.0
S-9		(mgd)	-0.0004	-0.0011	0.0006	-0.0003	-0.0014	-0.0005	0.0208	-0.0620	0.0050	0.0206	-0.0224	0.00
	Difference	(mgu) (%)	-0.0004	-1.04	1.13	-0.0000	-2.73	-0.0000 -1.81	246.44	-30.20	8.70	236.48	-0.0224	6.9
	Flow Monitored	(mgd)	0.213	1.070	0.696	0.204	1.117	0.734	0.154	1.451	0.864	0.159	1.475	0.7
	Model	(mgd)	0.208	1.036	0.716	0.222	1.178	0.777	0.240	1.436	0.818	0.236	1.126	0.7
6-10		(mgd)	-0.0057	-0.0334	0.0198	0.0174	0.0616	0.0432	0.0855	-0.0148	-0.0461	0.0768	-0.3488	-0.0
	Difference	(mgu) (%)	-0.0037 -2.67	-0.0004 -3.12	2.84	8.54	5.52	5.89	55.36	-0.0140 -1.02	-5.33	48.25	-0.3400	-0.0 -2.1
	Flow Monitored	(mgd)	0.116	0.564	0.371	0.116	0.664	0.416	0.109	0.627	0.400	0.107	0.603	0.3
	Model	(mgd)	0.130	0.560	0.379	0.119	0.639	0.421	0.130	0.642	0.413	0.130	0.585	0.3
6-11		(mgd)	0.0139	-0.0041	0.0078	0.0027	-0.0245	0.0045	0.0210	0.0152	0.0133	0.0238	-0.0174	0.0
	Difference	(%)	11.92	-0.73	2.11	2.36	-3.69	1.09	19.19	2.43	3.32	22.36	-2.89	4.3
	Flow Monitored	(mgd)	0.294	1.065	0.739	0.255	1.092	0.756	0.198	1.370	0.910	0.253	1.283	0.8
	Model	(mgd)	0.228	1.071	0.735	0.212	1.156	0.780	0.248	1.505	0.847	0.225	1.143	0.7
5-12		(mgd)	-0.0662	0.0066	-0.0044	-0.0427	0.0640	0.0236	0.0491	0.1347	-0.0626	-0.0279	-0.1401	-0.0
	Difference	(%)	-22.51	0.62	-0.59	-16.78	5.86	3.12	24.77	9.83	-6.88	-11.01	-10.92	-2.
	Flow Monitored	(mgd)	0.003	0.036	0.022	0.002	0.021	0.012	0.007	0.057	0.032	0.000	0.000	0.0
	Model	(mgd)	0.004	0.036	0.022	0.002	0.021	0.012	0.004	0.068	0.031	0.004	0.045	0.0
6-13		(mgd)	0.0008	-0.0002	0.0000	0.0006	0.0003	0.0000	-0.0023	0.0112	-0.0003	0.0043	0.0450	0.02
	Difference	(%)	23.44	-0.64	0.09	33.44	1.37	0.20	-34.88	19.73	-0.93	0.00	0.00	0.0
	Flow Monitored	(mgd)	0.021	0.090	0.061	0.017	0.096	0.064	0.020	0.087	0.043	0.016	0.110	0.0
	Model	(mgd)	0.023	0.090	0.061	0.018	0.095	0.064	0.023	0.090	0.062	0.023	0.090	0.0
S-14		(mgd)	0.0023	-0.0002	0.0000	0.0007	-0.0009	0.0000	0.0026	0.0033	0.0183	0.0068	-0.0206	-0.0
	Difference	(%)	11.30	-0.24	0.00	3.87	-0.89	0.00	12.70	3.80	42.14	42.02	-18.65	-4.

During the V&A flow monitoring program six rain gauges were set up within the City service area to record storm events during the monitoring period and are shown on **Figure 6.1**. Data from the V&A flow monitoring effort, as documented in the 2020 V&A Flow Monitoring Program, was used in this analysis to calibrate the computer hydraulic model to average dry weather flow (ADWF) and peak wet weather flow (PWWF) conditions.

6.3.3 Dynamic Model Calibration


The calibration process was iterative as it involved calibrating each of the 14 flow monitored sites and for the three calibration conditions: 1) peak dry weather flow, 2) peak wet weather flows from storm rainfall Event No. 1, and 3) peak wet weather flows from storm rainfall Event No. 2.


The rain events of March 12-13, 2020 (Event No. 1) and March 10-11, 2020 (Event No. 2), as listed on **Table 3.5**, were used to calibrate the hydraulic model to the wet weather conditions. The diurnal curves for each of the 14 sites were extracted from the 2020 V&A Flow Monitoring Program and the data was used for comparison purposes with the hydraulic model predictions. The calibration effort is an iterative process and continues until it yields acceptable results for each site and for each of the three calibration conditions.

The calibration results for each flow monitoring site are documented in Appendix B and briefly summarized on Table 6.3. These results indicate the calibration effort yielded reasonable comparisons between the flow monitoring data and the hydraulic model predictions at the 14 sites. The calibration results were reviewed and approved by City staff, and representative extracts from Appendix B are shown on Figures 6.3 and Figure 6.4. After each of the calibration process has been completed, the hydraulic model was benchmarked for further analysis and evaluation.

6.3.4 Use of the Calibrated Model

The calibrated hydraulic model was used as an established benchmark in the capacity evaluation of the existing wastewater collection system. The model was also used to identify improvements necessary for mitigating existing system deficiencies and for accommodating future growth. The hydraulic model is a valuable investment that will continue to prove its worth to the City as future planning issues or other operational conditions surface. It is recommended that the model be maintained and updated with new construction projects to preserve its integrity.







CHAPTER 7 - EVALUATION AND PROPOSED IMPROVEMENTS

This chapter presents a summary of the wastewater collection system capacity evaluation during peak dry weather flows and peak wet weather flows for the existing and buildout development conditions. This chapter summarizes the lift station condition assessment performed by V&A. The recommended wastewater collection system improvements needed to mitigate capacity deficiencies are also discussed in this chapter.

7.1 OVERVIEW

The calibrated hydraulic model was used for evaluating the wastewater collection system for capacity deficiencies during peak dry weather flows (PDWF) and peak wet weather flows (PWWF). Since the hydraulic model was calibrated for dynamic modeling, the analysis duration was established at 24 hours for most analyses.

The criteria used for evaluating the capacity adequacy of the wastewater collection system facilities (gravity mains, force mains, and lift stations) were discussed and summarized in the System Performance and Design Criteria chapter.


7.2 EXISTING SYSTEM CAPACITY EVALUATION


The system performance and design criteria summarized on **Table 3.1** were used as a basis to judge the adequacy of capacity for the existing wastewater collection system. The design flows simulated in the hydraulic model for existing conditions were summarized on **Table 5.3** and are listed as follows:

- Existing PDWF = 9.3 mgd
- Existing PWWF = 9.8 mgd

During the peak dry weather simulations, the maximum allowable pipe d/D criteria for gravity pipelines (0.50 for wastewater mains less than or equal to 12-inch or, 0.70 for wastewater mains greater than 12-inch) was used. During the peak wet weather simulations, the existing wastewater mains are allow to reach the full capacity of 1.0 while the future wastewater mains are allow to 75 percent full.

In general, the hydraulic model indicated that the wastewater collection system exhibited acceptable performance to service the existing customers during both peak dry weather flows (Figure 7.1) and peak wet weather flows (Figure 7.2). The results of the existing system capacity evaluations are discussed in the following sections.





7.2.1 Existing Peak Dry Weather Flows Capacity Evaluation

The existing dry weather flow analysis indicated that the existing wastewater collection system exhibited acceptable performance to service existing customers during peak dry weather flows, as documented on Figure 7.1, with the following exception:

- Apron Lane from Stableford Court to Oak Valley Parkway. This existing 8-inch pipeline experiences d/D ratios over 0.5 under peak dry weather flow conditions.
- Edgar Avenue from Oak Valley Parkway to approximately 580-feet south of Oak Valley Parkway. This existing 12-inch pipeline experiences d/D ratios over 0.5 under peak dry weather flow conditions.

7.2.2 Existing Peak Wet Weather Flows Capacity Evaluation

The existing wet weather flow analysis is intended to document the impact of rainfall events on the existing system, and to identify the improvements necessary to limit wastewater overflows. The design criteria for wet weather events allows pipeline to approach maximum allowable capacity criteria (d/D Ratio of 1.0). The hydraulic analysis indicates no existing deficient pipes observed, as shown on **Figure 7.2**.

7.3 BEAUMONT MESA LIFT STATION SPECIAL STUDIES

The Beaumont Mesa Lift Station serves as the critical lift station that conveys flows form the north reaches of the City's wastewater system to the WWTP. During the preparation of the WMP several special studies were performed for this lift station. These additional reviews included the following:

- Lift Station As-Built Preparation
- Offline Force Main Exploration
- Wet Well Expansion Site Constraints Analysis

These special studies are summarized in detail in the following sections.

7.3.1 Lift Station As-Built Preparation

City staff requested that detailed schematic drawings be prepared for the Beaumont Mesa Lift station, which would aid staff in reviewing the lift station and provide an updated record drawing source. Cannon completed a detailed survey of the lift station, which included imaging of the dry well interior and a detailed site plan. These updated record drawings are included in Appendix C.

7.3.2 Offline Force Main Exploration

The Beaumont Mesa Lift Station currently conveys flows to the City's WWTP via a single 12-inch force main. Additionally, an incomplete 16-inch force main exists between Highway 60 and the WWTP. However, prior to the WMP it was unknown if the incomplete force main crossed beneath Highway 60 or was only constructed up to the Highway's southern edge. In coordination with

Cannon and C-Below a field survey was completed to confirm the presence of the force main on the north side of the freeway. This field survey discovered approximately 5,220 feet of 16-inch force main on the north side of Highway 60, parallel to the existing 12-inch force main. The existence of this segment beneath the freeway mitigates the need for costly bore and jack construction to connect the 16-inch force main to the Beaumont Mesa Lift station. The survey report is included in Appendix D.

7.3.3 Wet Well Capacity Expansion

In order to provide emergency storage capacity at the lift station a wet well capacity analysis was performed. Following discussion with City staff it was determined that the wet well would be expanded to hold a volume equal to a one-hour duration of the peak inflow rate. Table 7.1 summarizes the results of the capacity analysis, which indicates that an additional volume of 0.25 MG is required to provide this emergency storage capacity. Additionally, a cost comparison was performed between constructing this expansion capacity and a no-action alternative. This cost comparison, summarized on Table 7.1, shows that the estimated cost to expand the wet well is less than the minimum possible fine should a sanitary sewer overflow occur.

Following the estimation of the volume expansion a review of the site constraints was performed. Based on the existing site layout and configuration of the existing lift station facilities, as shown on **Figure 7.3**, there is sufficient area within the existing site to construct the recommended additional volume. **Table 7.2** summarizes the Beaumont Mesa available wet well expansion volume excluding concrete volume.

7.4 BEAUMONT MESA LIFT STATION OPERATION

The Beaumont Mesa wet well analysis summarized on **Table 7.1** were used to size the volume of the new wet well with 30 minutes inflow and 60 minutes inflow assuming no wastewater pumping out. During the general plan buildout conditions, the spill duration for 60 minutes inflow are 49.2 minutes and 49.3 minutes under peak hour dry weather and peak hour wet weather events respectively.


The estimated minimum spill fine is \$2,501,400 dollar for 60 minutes wastewater inflows with possible spill fine rate range from minimum \$10 to \$1,000 dollars based on the fine rate provided by City staff. The estimated CIP cost for the new wet well is \$3,326,000 dollar based on Cannon's preliminary wet well design cost estimate.

7.5 OTHER SPECIAL STUDIES

This Wastewater Master Plan included several special studies requested by City staff and are included in the following:

- Fairway Canyon Preliminary Design Report (PDR) Review
- Wastewater Hydraulic Analysis for McClure Industrial Building

These special studies are summarized in detail in the following sections.



-ENGINEERING GROUP, INC.

Legend

Existing System

- **E**Lift Station
- ---· Force Mains
 - Gravity Mains
 - Potential Expansion Extents
 - Potential Expansion Extents

PRELIMINARY

Figure 7.3 Potential Wet Well Expansion Wastewater Master Plan City of Beaumont



Table 7.1 Beaumont Mesa LS - Estimated Time to Spill

Wastewater Master Plan City of Beaumont

PRELIMINARY **Future Flow Conditions Average Flow Conditions Peak Flow Conditions** Dry Weather Wet Weather **Dry Weather** Wet Weather Beamont Mesa LS Inflow (gpm) 1,850 1,850 3,700 3,700 Upper Oak Valley LS¹ 650 650 650 Olivewood LS² 650 Gravity Drainage³ 331 412 650 719 Maximum Infow 2,831 2,912 5,000 5,069 Estimated time to Spill Maximum Wet Well Volume (gallon)⁴ 54,000 54,000 54,000 54,000 Time to Spill, (mins)⁵ 19.1 18.5 10.8 10.7 **30 Minutes Inflow** Required Total Volume (gallon) 84,927 87,369 150,000 152,070 54,000 54,000 54,000 54,000 Existing Wet Well Volume Required Remaining Volume (gallon) 98,070 30,927 33,369 96,000 Spill duration (mins) 10.9 11.5 19.2 19.3 Min. Estimated Spill Fine (\$10/gallon)⁶ \$309,265 \$333,690 \$960,000 \$980,700 New Wet Well **Recommended Volume** 31,000 34,000 96,000 99,000 \$1,272,100 Estimated CIP Cost (\$8.50/gallons)^{7,8} \$410,800 \$450,600 \$1,311,900 **60 Minutes Inflow** Required Total Volume (gallon) 169,853 174,738 300.000 304.140 **Existing Wet Well Volume** 54,000 54,000 54,000 54,000 Required Remaining Volume (gallon) 250,140 115,853 120,738 246,000 Spill time (mins) 40.9 41.5 49.2 49.3 \$1,158,530 \$1,207,380 \$2,460,000 \$2,501,400 Min. Estimated Spill Fine (\$10/gallon)⁶ New Wet Well **Recommended Volume** 116,000 121,000 246,000 251,000 Estimated CIP Cost (\$8.50/gallons)^{7,8} \$1,603,400 \$3,259,800 \$3,326,000 \$1,537,200 A K E L-

ENGINEERING GROU Notes:

1. Flow based on recommended pump improvements and assumes the following pump operations:

Average Flow: One duty pump active

Peak Flow Conditions: Two duty pumps active

2. Flow based on recommended pump improvements and assumes the following pump operations:

Average/Peak Flow: One duty pump active

Peak flows extracted from wastewater hydraulic model. Average flows estimated based on peak flows and associated peaking factors.

 Volume estimated based on 21.0 wet well level and total wet well area estimated based on drawings provided by Cannon May 12, 2020.

5. Time to spill estimated based on maximum wet well volume and maximum inflow.

6. Spill fine cost shown reflected the minimum fine rate. Possible spill fine rate range from \$10 to \$1,000 dollars.

7. Wet Well costs estimated based on cost provided by Cannon August 12, 2020.

8. Cost includes additional Master Plan Contingencies of 20% for Construction Contingencies and 30% for Capital Improvement Contingencies

3/8/2021

Table 7.2 Potential Beaumont Mesa Wet Well Expansion

Wastewater Master Plan City of Beaumont

PRELIMINARY

Potential Expansion Exte	Potential Expansion Extents					
Wet Well Interior	Units					
Maximum Depth ¹	ft	9	9			
Freeboard ¹	ft	1	1			
Available Depth ¹	ft	8	8			
Interior Slope ²	%	6.76%	7.25%			
Available Wet Well Volume		_				
Total Volume With Sloped Concrete	gal	500,988	428,512			
Volume of Sloped Concrete	gal	182,049	155,923			
Available Wet Well Volume	gal	318,938	272,589			
ENGINEERING GROUP, INC.			5/19/2021			

Notes:

1. Wet well expansion maximum depth and available depth based on drawings provided by Cannon August 12, 2020.

2. Wet well expansion interior slope assumed 7-feet drop across wet well.

7.5.1 Fairway Canyon Preliminary Design Report (PDR) Review

City staff requested Akel Engineering Group to review the PDR prepared by Proactive Engineering Consultants West, Inc. for consistency with criteria documented in the City's inprogress 2021 Wastewater Master Plan. Fairway Canyon development is a four-phase residential development consists of 1,312 total dwelling units spread over approximately 310 acres in the northwest portion of the City of Beaumont (City). The PDR estimated the average flows using per capita sewer flow generation rates based on Eastern Municipal Water District (EMWD) standards while the in-progress City of 2021 Wastewater Master Plan estimated average flows for the study area that is based on EMWD unit flow factors applied to overall site acreage.

The review also included a lift station and force main capacity evaluation. Based on the findings, this study indicated that the PDR flow estimation methodology results are slightly higher than the flows estimated in the 2021 Wastewater Master Plan. The review indicates this PDR assumptions meet the 2021 Wastewater Master Plan criteria, as documented in the technical memorandum included in Appendix E.

7.5.2 Wastewater Hydraulic Analysis for McClure Industrial Building

McClure Industrial building is a 1.02 acres lot size development located at the northeast corner of Minnesota Avenue and 1st Street. The estimated average flows are based on EMWD unit flow factors on per acres basis, and uses daily peaking factors based on historical flow data and hourly peaking factors based on flow monitoring data. This study evaluates the capacity adequacy of the existing wastewater collection system to service the development flows and if necessary, improvements to mitigate capacity deficiencies. Based on the findings, this study indicates that the existing wastewater collection system is adequate to serve development flow. The hydraulic analysis package is included in **Appendix F**.

7.6 LIFT STATION ASSESSMENT

This Wastewater Master Plan included a review of the City's exiting wastewater lift stations, which included the following analyses:

- **Pumping Capacity Evaluation:** The pumping capacity of each modeled lift station was reviewed to ensure each station is capable of conveying wastewater flows under existing and buildout development conditions. This evaluation compared peak lift station inflows under peak wet weather conditions against the existing lift station firm capacities and documented any recommended improvements. The results of the pump station capacity evaluation are documented on Table 7.3.
- Force Main Capacity Evaluation: The existing lift station force mains were evaluated to determine capacity adequacy for both existing and buildout development conditions. This evaluation analyzed the pipeline velocity for the existing force mains and determined if a larger pipeline is required to convey either existing or buildout sewer flows. The results of the force main evaluation are documented on Table 7.4.

Table 7.3 Lift Station Capacity Analysis

Wastewater Master Plan

City of Beaumont

	Design Firm	Total Capacity	Exis	ting System An	alysis	Fut	ture System Ana	alysis		
Pump Station	Capacity	(Includes Standby)	Peak Wet We	eather Flows ¹	Surplus/ Deficiency	Peak Wet W	eather Flows ¹	Surplus/ Deficiency	Recommended Improvements	
	(gpm)	(gpm)	(gpm)	(mgd)	(gpm)	(gpm)	(mgd)	(gpm)		
Existing System										
Beaumont Mesa ³	1,797	3,594	2,020	2.91	-223	4,530	6.52	-2,733	Construct two 3,500 gpm and two 1,500 gpm pumps, three duty and one standby for total capacity of 10,000 gpm.	
Fairway Canyon ²	400	800	77	0.11	323	90	0.13	310		
Lower Oak Valley	1,050	1,700	965	1.39	85	1,217	1.75	-167	Construct three 625 gpm pumps, two du and one standby, for total capacity of 1,875 gpm	
Marshall Creek	1,150	2,300	778	1.12	372	1,696	2.44	-546	Construct two 1,700 gpm pumps, one du and one standby, for total capacity of 3,400 gpm	
Noble Creek	1,865	3,730	465	0.67	1,400	958	1.38	907		
Seneca Springs	900	1,350	201	0.29	699	378	0.54	522		
Upper Oak Valley	2,700	5,000	1,914	2.76	786	3,634	5.23	-934	Construct three 1,850 gpm pumps, two duty and one standby, for total capacity 5,550 gpm	
Four Seasons	1,740	3,715	442	0.64	1,298	2,616	3.77	-876	Construct three 1,350 gpm pumps, two duty and one standby, for total capacity 4,050 gpm	
Industrial Park	112	262	106	0.15	6	288	0.41	-176	Construct two 300 gpm pumps, one dut and one standby, for total capacity of 60 gpm	
Olivewood	310	620	53	0.08	257	612	0.88	-302	Construct two 625 gpm pumps, one dut and one standby, for total capacity of 1,250 gpm	
Future System										
Beaumont Ave South	-	-	-	-	-	1,788	2.57	-1,788	Construct three 900 gpm pumps, two du and one standby, for total capacity of 2,700 gpm	
Beaumont Crossroads	-	-	-	-	-	4,659	6.71	-4,659	Construct three 2,350 gpm pumps, two duty and one standby, for total capacity 7,050 gpm	
Brookside Ave	-	-	-	-	-	278	0.40	-278	Construct two 300 gpm pumps, one dut and one standby, for total capacity of 60 gpm	
Tukwet Canyon	-	-	-	-	-	709	1.02	-709	Construct three 375 gpm pumps, two du and one standby, for total capacity of 1,125 gpm	

Notes:

1. Maximum average hour flows extracted from sewer system hydraulic model.

2. Lift station current capacity is different than Design Capacity as directed by City staff December 15, 2020.

3. Pump information provided by Xylem staff March 02, 2021.

Table 7.4 Force Main Capacity Analysis

Wastewater Master Plan

City of Beaumont

Lift Station ID	Force Main	Force Main		Wet Weather		Wet Weather	Recommended
	Length	Diameter	Flow	Velocity	Flow	Velocity	Improvements
	(ft)	(in)	(mgd)	(ft/s)	(mgd)	(ft/s)	
Existing System						·	
Beaumont Mesa	11,750	12	2.91	5.7	2.09	4.1	
	5,250	16	-	-	4.46	4.9	Connect to currently incomplete force mair
Faiway Canyon	3,800	8	0.11	0.5	0.13	0.6	-
Lower Oak Valley ²	13,000	Varies 8- inch/10-inch	0.50	2.2	0.99	4.4	-
	13,000	Varies 10- inch/14-inch	0.89	2.5	1.77	5.0	-
Marshall Creek	4,300	10	0.43	1.2	0.93	2.6	-
	4,300	12	0.69	1.4	1.51	3.0	-
Noble Creek	1,950	12	0.67	1.3	1.38	2.7	-
Seneca Springs	3,150	8	0.14	0.6	0.27	1.2	-
	3,100	8	0.14	0.6	0.27	1.2	-
Upper Oak Valley	6,950	12	1.38	2.7	2.65	5.2	-
	6,950	12	1.38	2.7	2.65	5.2	-
Four Seasons	12,000	8	0.12	0.5	0.70	3.1	-
	12,000	14	0.52	0.7	3.06	4.4	-
Industrial Park	1,100	6	0.15	1.2	0.41	3.3	-
Olivewood	5,100	8	0.08	0.3	0.88	3.9	-
Future System							
Beaumont Ave	5,050	10	-	-	2.57	7.3	-
Beaumont Crossroads	9,150	6	-	-	0.47	3.7	-
	9,200	16	-	-	6.24	6.9	-
Brookside Ave	2,850	6	-	-	0.40	3.2	-
Tukwet Canyon	6,250	8	-	-	0.51	2.3	-
	6,250	8	-	-	0.51	2.3	-

ENGINEERING GROUP, INC.

2/19/2021

Notes:

1. Maximum average hour flows extracted from sewer system hydraulic model.

2. The maximum velocities shown are based on the peak wet weather flow in the smaller of the two force main diameters.

 Condition Assessment: V&A conducted a condition assessment of the 10 lift stations, which included documentation of the existing physical conditions, a condition rating of 1 (Very Good) to 5 (Very Poor) for various onsite components, and an opinion of probable cost for potential improvements. The condition assessment did not review the condition of the lift station pumps or the electrical, mechanical, and control elements of the lift stations.

The report completed by V&A for the condition assessment is included in **Appendix G**, while the following sections include a brief summary of the information prepared for each lift station. It should be noted that the discussion in the following sections only includes a summary of the condition assessment results for components that received a score of 4 (Poor) or 5 (Very Poor).

7.6.1 Fairway Canyon Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Fairway Canyon Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 77 gpm and 90 gpm under buildout PWWF conditions. The existing lift station capacity is sufficient for existing and buildout conditions.
- Force Main Evaluation: As documented on Table 7.4 the existing 8-inch Fairway Canyon force main is adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** Leak observed on the second duty pump, immediate repair is recommended to prevent further corrosion.

7.6.2 Lower Oak Valley Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Lower Oak Valley Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 965 gpm and 1,217 gpm under buildout PWWF conditions. This lift station is under capacity during buildout development conditions and is recommended for replacement.
- Force Main Evaluation: As documented on Table 7.4 the existing parallel of 8-inch, 10inch and 10-inch, 14-inch combination force main are adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that replacement of heavily corroded pump discharge pipeline is necessary.

7.6.3 Upper Oak Valley Lift Station

The following sections document the pumping capacity evaluation and force main evaluation for the Upper Oak Valley Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 1,914 gpm and 3,634 gpm under buildout PWWF conditions. This lift station is under capacity during buildout development conditions and is recommended for replacement.
- Force Main Evaluation: As documented on Table 7.4 the existing parallel 12-inch force main are adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that replacement of heavily corroded pump discharge pipeline is necessary. Additionally, repair cracking on pipe supports spanning concrete base to protect from moisture.

7.6.4 Olivewood Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Olivewood Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 53 gpm and 612 gpm under buildout PWWF conditions. This lift station is under capacity during buildout development conditions and is recommended for replacement.
- Force Main Evaluation: As documented on Table 7.4 the existing 8-inch force main is adequate to convey flows under existing and buildout development conditions
- **Condition Assessment:** The condition assessment recommended paving site surface to reduce risk of animals hiding.

7.6.5 Beaumont Mesa Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Beaumont Mesa Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 2,020 gpm and 4,530 gpm under buildout PWWF conditions. This lift station is under capacity during existing and buildout development conditions. It is recommended that the originally design pumps be installed, which will provide sufficient capacity under existing and buildout PWWF conditions.
- Force Main Evaluation: As documented on Table 7.4 the existing 12-inch force main is under capacity during buildout development conditions. It is recommended that the

existing incomplete force main be extended to the lift station. and is recommended to complete the existing 16-inch incomplete force main.

• **Condition Assessment:** The condition assessment recommended repair heavily corroded conduit (instrumentation) at top of wet well structure.

7.6.6 Noble Creek Lift Station

The following sections document the pumping capacity evaluation and force main evaluation for the Noble Creek Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 465 gpm and 958 gpm under buildout PWWF conditions. The existing lift station capacity is sufficient for existing and buildout conditions.
- Force Main Evaluation: As documented on Table 7.4 the existing 12-inch force main is adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that the components of this lift station are in generally acceptable condition, with no components receiving a score of 4 or greater.

7.6.7 Marshall Creek Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Marshall Creek Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 778 gpm and 1,696 gpm under buildout PWWF conditions. This lift station is under capacity during buildout development conditions and is recommended for replacement.
- Force Main Evaluation: As documented on Table 7.4 the existing parallel 10-inch and 12-inch force main are adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment recommended that pump discharge piping should be replace; additionally, lid and cover frame replacement are necessary.

7.6.8 Industrial Park Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Industrial Park Lift Station.

• **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 106 gpm and 288 gpm under buildout PWWF conditions. This lift

station is under capacity during buildout development conditions and is recommended for replacement.

- Force Main Evaluation: As documented on Table 7.4 the existing 6-inch force main is adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that the components of this lift station are in generally acceptable condition, with no components receiving a score of 4 or greater.

7.6.9 Seneca Springs Lift Station

The following sections document the pumping capacity evaluation and force main evaluation for the Seneca Springs Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 201 gpm and 378 gpm under buildout PWWF conditions. The existing lift station capacity is sufficient for existing and buildout conditions.
- Force Main Evaluation: As documented on Table 7.4 the existing parallel 8-inch force mains are adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that the components of this lift station are in generally acceptable condition, with no components receiving a score of 4 or greater.

7.6.10 Four Seasons Lift Station

The following sections document the pumping capacity evaluation, force main evaluation, and condition assessment for the Four Seasons Lift Station.

- **Pumping Capacity Evaluation:** The maximum modeled lift station inflow under existing PWWF conditions is 442 gpm and 2,616 gpm under buildout PWWF conditions. This lift station is under capacity during buildout development conditions and is recommended for replacement.
- Force Main Evaluation: As documented on Table 7.4 the existing parallel 8-inch and 14inch force mains are adequate to convey flows under existing and buildout development conditions.
- **Condition Assessment:** The condition assessment indicated that the components of this lift station are in generally acceptable condition, with no components receiving a score of 4 or greater.

7.7 ULTIMATE BUILDOUT CAPACITY IMPROVEMENTS

The system performance and design criteria summarized on **Table 3.1** were used as a basis to evaluate the capacity adequacy of the existing wastewater collection system. The design flows simulated in the hydraulic model for the General Plan buildout were summarized on **Table 5.3** and are documented as follows:

- Buildout PDWF = 31.2 mgd
- Buildout PWWF = 27.9 mgd


During the peak dry weather simulations, the maximum allowable pipe d/D criteria (0.5 for 12-inch or smaller and 0.70 for larger than 12-inches) was used. During the peak wet weather simulations, the maximum allowable pipe d/D criteria for new pipes 0.75 was used. For existing pipes, the criteria were relaxed to allow a maximum d/D ratio of 1.0 to prevent unnecessary pipe replacements.


The proposed capacity improvements for the wastewater collection system are shown graphically on **Figure 7.4** and summarized on **Table 7.5**, which includes lift station, force main, and gravity main improvements. This table lists the master plan assigned improvement number (e.g., P-1), along with other relevant information including alignment description, capacity or pipe size, and pipe length. These improvements are also summarized on the following pages. As shown on **Figure 7.4**, the improvements are separated into three categories, which are described as follows:


- Existing Pipeline Existing Capacity Deficiency: These improvements are intended to mitigate a capacity deficiency in an existing pipeline. The proposed improvement is sized to address this deficiency.
- Existing Pipeline Capacity Deficiency Triggered by Future Development: These improvements reflect existing system pipeline alignment that become deficient due to future developments. The proposed improvement is sized to address this future deficiency, when it is triggered. City staff are currently completing special studied for future developments, as they happen, to identify the triggers for these improvements.
- New Pipeline Triggered by Future Development: These improvements are intended to extend the wastewater collection system to serve future growth in new areas. City staff are currently completing special studied for future developments, as they happen, to identify the final alignments and final pipeline size requirements.

7.7.1 Lift Station Capacity Improvements

This section documents lift station improvements for the wastewater collection system. Lift station improvements were identified based on the results of the capacity analysis shown on Table 7.3 and summarized in a previous section.







Wastewater Master Plan

City of Beaumont

					Pipeli	ne Improvem	ELIMINAF ents
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length
Lower Oak	Valley Lift Statior	n Tributary Area		(in)		<u>(in)</u>	(ft)
	Improvements						
LOV-P1	Future Capacity Increase	Irwin St	From Floyd Cir to Palmer Ave	15	Replace	18	525
Lift Station Im	provements						
LOV-LS	Lift Station Replacement	Lower Oak Valley Lift S	tation		Replace	3 @ 62	5 gpm
Tukwet Can	iyon (New) Lift St	ation Tributary Area					
Force Main Im	provements						
TC-FM1	New Force Main	Sorenstam Dr/Price St	From Tukwet Canyon lift station to approx. 1,000' n/o Upper Oak Valley lift station	-	New	8	6,250
TC-FM2	New Force Main	Sorenstam Dr/Price St	From Tukwet Canyon lift station to approx. 1,000' n/o Upper Oak Valley lift station	-	New	8	6,250
Lift Station Im	provements						
TC-LS	New Lift Station	Tukwet Canyon Lift Sta	tion		New	3 @ 37	5 gpm
Upper Oak	Valley Lift Station	n Tributary Area					
Gravity Main	Improvements						
UOV-P1	Future Capacity Increase	Straightaway Dr	From Balata St to 350' sw/o Balata St	8	Replace	10	350
UOV-P2	Existing Capacity Deficiency	Apron Ln	From Stableford Ct to Oak Valley Pkwy	8	Replace	12	300
UOV-P3	Future Capacity Increase	Oak Valley Pkwy	From Apron Ln to 2,450' w/o Apron Ln	12	Replace	15	2,500
Lift Station Im	-						
UOV-LS	Lift Station Replacement	Upper Oak Valley Lift S	tation		Replace	3 @ 1,8	50 gpm
Olivewood	Lift Station Tribu	tary Area					
Gravity Main	Improvements						
O-P1	Future Capacity Increase	ROW	From Artisan PI to approx. 500' n/o Artisan PI	10	Replace	12	525
Lift Station Im	Lift Station						
O-LS	Replacement	Olivewood Lift Station			Replace	2 @ 62	5 gpm
Brookside A	Avenue (New) Lift	t Station Tributary Ar	ea				
Gravity Main	Improvements						
BR-P1	New Capacity	Brookside Ave	From 480' w/o Deodar Dr to Brookside Ave lift station	-	New	8	2,200
Force Main Im	provements		From Devolution Associations of the Devolution				
BR-FM1	New Force Main	Brookside Ave	From Brookside Ave lift station to Deodar Dr	-	New	6	2,825
Lift Station Im	-						
BR-LS	New Lift Station	Brookside Ave Lift Stati	on		New	2 @ 30	0 gpm
	Mesa Lift Station	Tributary Area					
Gravity Main	Improvements						

Wastewater Master Plan

						PR	ELIMINAF
	Type of				Pipeli	ne Improvem	ents
Improv. No.	Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length
BM-P2	New Capacity	ROW	From 2,600' e/o Potrero Blvd to 1,400' s/o Oak Valley Pkwy	(in) -	New	(in) 10	(ft) 1,600
BM-P3	New Capacity	ROW	From 1,400' s/o Oak Valley Pkwy to Beaumont Mesa lift station	-	New	15	2,350
Force Main Im	provements				1		
BM-FM1	New Force Main	Potrero Blvd/Western Knolls Ave	From Beaumont Mesa lift station to 1,300' w/o Western Knolls Ave	-	New	16	6,500
Lift Station Im	provements						
BM-LS	New Pump	Beaumont Mesa Lift S	tation		New	2 @ 3,50 2 @ 1,50	
BM-WW	New Wet Well	Beaumont Mesa Lift S	tation		New		
Beaumont	Crossroads (New) Lift Station Tributar	y Area				
Gravity Main	Improvements						
BC-P1	New Capacity	W 4th St	From 1,875' s/o Moreno Valley Fwy to Beaumont Crossroads lift station	-	New	15	3,125
BC-P2	New Capacity	W 4th St	From 275' w/o of Prosperity Way to 400' e/o Potrero Blvd	-	New	12	2,100
BC-P3	New Capacity	W 4th St	From 400' e/o Potrero Blvd to Potrero Blvd	-	New	15	375
BC-P4	New Capacity	W 4th St	From Potrero Blvd to 1,350' w/o Potrero Blvd	-	New	18	1,450
BC-P5	New Capacity	W 4th St	From 1,350' w/o Potrero Blvd to Beaumont Crossroads lift station	-	New	21	800
Force Main In	nprovements						
BC-FM1	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	16	9,175
BC-FM2	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	6	9,175
Lift Station Im	provements				L.		
BC-LS	New Lift Station	Beaumont Crossroads	Lift Station		New	3 @ 2,3	50 gpm
Marshall Cr	eek Lift Station T	ributary Area					
Lift Station Im	provements						
MC-LS	Lift Station Replacement	Marshall Creek Lift Sta	ation		Replace	2 @ 1,70	00 gpm
Industrial P	ark Lift Station T	ributary Area					
Gravity Main	Improvements						
IP-P1	Future Capacity Increase	Risco Cir	From W 4th St to 425' s/o W 4th St	8	Replace	10	475
Lift Station Im	provements						
IP-LS	Lift Station Replacement	Industrial Park Lift Sta	tion		Replace	2 @ 30	0 gpm
Beaumont	Avenue South (N	ew) Lift Station Tribu	itary Area				
Gravity Main	Improvements						
BAS-P1	New Capacity	Beaumont Ave	From 1,200' n/o Laird Rd to 2,775' sw/o Laird Rd	-	New	12	4,125
BAS-P2	New Capacity	Beaumont Ave	From 2,775' sw/o Laird Rd to Beaumont Avenue lift station	-	New	15	875
Force Main Im	provements						
BAS-FM1	New Force Main	Beaumont Ave	From Beaumont Avenue lift station to 2,450' s/o E 1st St	-	New	10	5,025

Wastewater Master Plan

					Pineli	PRI ne Improvem	ELIMINAR) ents
Improv. No.	Type of	Alignment	Limits		Pipeili	ie improvem	ents
	Improvement	Auginiteitt	Linits	Existing Diameter	New/ Replace	Diameter	Length
Lift Station Im	nrovomonto			(in)		(in)	(ft)
Lift Station Im BAS-LS	New Lift Station	Beaumont Avenue Sout	h Lift Station		New	3 @ 90) gom
		nt Tributary Area					
	mprovements	it insutary fired					
WWTP-P1	Future Capacity Increase	Oak Valley Pkwy	From 550' w/o San Miguel Dr to 150' w/o San Miguel Dr	12	Replace	12	425
WWTP-P2	Existing Capacity Deficiency	Edgar Ave	From Oak Valley Pkwy to 575' s/o Oak Valley Pkwy	12	Replace	15	575
WWTP-P3	Future Capacity Increase	Luis Estrada Rd	From 400' se/o Veile Ave to Veile Ave	12	Replace	12	425
WWTP-P4	Future Capacity Increase	Minnesota Ave/W 4th St	From 525' n/o W 4th St to 600' w/o Minnesota Ave	24	Replace	30	1,125
WWTP-P5	Future Capacity Increase	ROW	From 4th St to 1,100' w/o Minnesota Ave	30	Replace	36	950
WWTP-P6	New Capacity	ROW	From 2,300 ne/o Highland Springs Ave to 1,300 e/o Highland Springs Ave	-	New	12	3,875
WWTP-P7	New Capacity	ROW	From 1,300' e/o Highland Springs Ave to Highland Springs Ave	-	New	15	1,300
WWTP-P8	Future Capacity Increase	Brookside Ave	From Highland Springs Ave to Orchard Heights Ave	8	Replace	15	2,650
WWTP-P9	Future Capacity Increase	Brookside Ave	From Orchard Heights Ave to Cherry Ave	8	Replace	15	2,700
WWTP-P10	Future Capacity Increase	Cherry Ave	From Brookside Ave to Cougar Way	8	Replace	15	2,650
WWTP-P11	Future Capacity Increase	Cherry Ave	From Cougar Way to Oak Valley Pkwy	8	Replace	15	2,675
WWTP-P12	Future Capacity Increase	Cherry Ave	From oak Valley Pkwy to Antonell Ct	10	Replace	15	1,700
WWTP-P13	Future Capacity Increase	Cherry Ave	From Antonell Ct to E 8th St	12	Replace	15	3,675
WWTP-P14	Future Capacity Increase	Illinois Ave	From E 8th St to E 6th St	12	Replace	15	1,175
WWTP-P15	Future Capacity Increase	E 6th St	From Illinois Ave to Pennsylvania Ave	15	Replace	18	700
WWTP-P16	Future Capacity Increase	Pennsylvania Ave	From E 6th St to 175' s/o Interstate 10	18	Replace	24	975
WWTP-P17	Future Capacity Increase	ROW	From Pennsylvania Ave to 75' w/o Beaumont Ave	18	Replace	30	3,800
WWTP-P18	Future Capacity Increase	ROW	From 125' n/o 3rd St to 400' e/o Beaumont Ave	10	Replace	10	125
WWTP-P19	Future Capacity Increase	ROW	From 3rd St to 400' e/o Beaumont Ave	10	Replace	10	175
WWTP-P20	Future Capacity Increase	ROW	From Rover Ln to 350' w/o Houstonia Ln	12	Replace	15	2,550
WWTP-P21	Future Capacity Increase	E 1st St	From Palm Ave to Beaumont Ave	24	Replace	30	1,600
WWTP-P22	Future Capacity Increase	E 1st st	From California Ave to Minnesota Ave	30	Replace	36	2,125
WWTP-P23	Future Capacity Increase	Minnesota Ave	From E 1st St to 575' n/o E 1st St	30	Replace	36	575
WWTP-P24	Future Capacity Increase	ROW	From 575' n/o E 1st St to 1,025' w/o Minnesota Ave	30	Replace	36	1,100
WWTP-P25	New Capacity	Beaumont Ave	From E 1st St to 1,275' n/o Laird Rd	-	New	21	2,475

Wastewater Master Plan

City of Beaumont

					Pipeli	ne Improvem	ents
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length
				(in)		(in)	(ft)
Four Seaso	ns Lift Station Tri	butary Area					
Gravity Main	Improvements						
FS-P1	Future Capacity Increase	Highland Springs Ave	From E 6th St to 450' w/o Highland Springs Ave	10	Replace	12	1,225
FS-P2	Future Capacity Increase	Highland Springs Ave	From 550' n/o E 1st St to 100' s/o E 1st St	10	Replace	12	650
FS-P3	Future Capacity Increase	Highland Springs Ave	From 800' n/o Potrero Blvd to 50' s/o Potrero Blvd	12	Replace	15	850
FS-P4	Pipe Slope Reconstruction	Highland Springs Ave	From 100' n/o Crooked Creek to Crooked Creek	12	Replace	12	100
FS-P5	Future Capacity Increase	Highland Springs Ave	From 350' s/o Crooked Creek to 375' s/o Breckenridge Ave	15	Replace	18	1,525
FS-P6	Future Capacity Increase	Breckenridge Ave	From 75' w/o Highland Springs Ave to Highland Springs Ave	10	Replace	10	75
Lift Station In	nprovements						
FS-LS	Lift Station Replacement	Four Seasons Lift Statio	on		Replace	3 @ 1,3	50 gpm

Note:

1. Beaumont Crossroads 6-inch force main planned for replacement with 16-inch at buildout of tributary area.

- Lower Oak Valley: As documented on Table 7.3 the buildout flow requirement for the Lower Oak Valley lift station is 1,217 gpm. A new lift station is recommended for construction with three 625 gpm pumps, two duty and one standby, for a total lift station capacity of 1,875 gpm.
- **Upper Oak Valley:** As documented on **Table 7.3** the buildout flow requirement for the Upper Oak Valley lift station is 3,634 gpm. A new lift station is recommended for construction with three 1,850 gpm pumps, two duty and one standby, for a total lift station capacity of 5,550 gpm.
- **Olivewood:** As documented on **Table 7.3** the buildout flow requirement for the Olivewood lift station is 612 gpm. A new lift station is recommended for construction with two 625 gpm pumps, one duty and one standby, for a total lift station capacity of 1,250 gpm.
- Industrial Park: As documented on Table 7.3 the buildout flow requirement for the Industrial Park lift station is 288 gpm. A new lift station is recommended for construction with two 300 gpm pumps, one duty and one standby, for a total lift station capacity of 600 gpm.
- **Beaumont Mesa:** As documented on **Table 7.3** the buildout flow requirement for the Beaumont Mesa lift station is 4,530 gpm. A new lift station is recommended for construction with two 1,500 gpm and two 3,500 gpm pumps, three duty and one standby, for a total lift station capacity of 10,000 gpm.
- **Marshall Creek:** As documented on **Table 7.3** the buildout flow requirement for the Marshall Creek lift station is 1,696 gpm. A new lift station is recommended for construction with two 1,700 gpm pumps, one duty and one standby, for a total lift station capacity of 3,400 gpm.
- Four Seasons: As documented on Table 7.3 the buildout flow requirement for the Four Seasons lift station is 2,616 gpm. A new lift station is recommended for construction with three 1,350 gpm pumps, two duty and one standby, for a total lift station capacity of 4,050 gpm.
- **Beaumont Ave South:** In order to convey the future flows from the South urban development, a new lift station is recommended. This lift station is planned to have three 900 gpm pumps, two duty and one standby, for a total lift station capacity of 2,700 gpm.
- **Beaumont Crossroads:** In order to convey the future flows from the Beaumont Crossroads, a new lift station is recommended. This lift station is planned to have three 2,350 gpm pumps, two duty and one standby, for a total lift station capacity of 7,050 gpm.

- **Brookside Ave:** In order to convey the future flows from north of Brookside Avenue and west of Interstate 10, a new lift station is recommended. This lift station is planned to have two 300 gpm pumps, one duty and one standby, for a total lift station capacity of 600 gpm.
- **Tukwet Canyon:** In order to convey future flows from Tukwet Canyon development, a new lift station is recommended. This lift station is planned to have three 375 gpm pumps, two duty and one standby, for a total lift station capacity of 1,125 gpm.

7.7.2 Force Main Improvements

This section documents the recommended force main capacity improvements.

- **BR-FM1**: Construct a new 6-inch force main in Brookside Avenue from future Brookside Avenue lift station to Deodar Drive.
- **BM-FM1:** Connect a new 16-inch force main connecting to the incomplete 16-inch force main in Potrero Boulevard and Western Knolls Avenue from Beaumont Mesa lift station to 1,300 feet west of Western Knolls Avenue.
- **BC-FM1:** Construct a new 16-inch force main in 4th Street from future Beaumont Crossroads lift station to Nicholas Road.
- **BC-FM2**: Construct a new 6-inch force main in 4th Street from future Beaumont Crossroads lift station to Nicholas Road.
- **BAS-FM1:** Construct a new 10-inch force main in Beaumont Avenue from future Beaumont Avenue lift station to approximately 2,450 feet south of 1st Street.

7.7.3 Gravity Main Improvements

This section documents the gravity main improvements. This section documents pipeline improvements within the City of Beaumont wastewater collection service area.

7.7.3.1 Lower Oak Valley

This section documents pipeline improvements within the Lower Oak Valley collection basin.

• LOV-P1: Replace existing 15-inch gravity main with a new 18-inch gravity main in Irwin Street from Floyd Circle to Palmer Avenue.

7.7.3.2 Upper Oak Valley

This section documents pipeline improvements within the Upper Oak Valley collection basin.

• **UOV-P1:** Replace existing 8-inch gravity main with a new 10-inch gravity main in Straightway Drive from Balata Street to 350 feet southwest of Balata Street.

- **UOV-P2:** Replace existing 8-inch gravity main with a new 12-inch gravity main in Apron Lane from Stableford Court to Oak Valley Parkway.
- **UOV-P3**: Replace existing 12-inch gravity main with a new 15-inch gravity main in Oak Valley Parkway from Apron Lane to 2,450 feet west of Apron Lane.

7.7.3.3 Olivewood

This section documents pipeline improvements within the Olivewood collection basin.

• **O-P1:** Replace existing 10-inch gravity main with a new 12-inch gravity main in Right-Of-Way from Artisan Place to 525 feet north of Artisan Place.

7.7.3.4 Brookside Avenue

This section documents pipeline improvements within the Brookside Avenue collection basin.

• **BR-P1:** Construct a new 8-inch gravity main in Brookside Avenue from 480 feet west of Deodar Drive to new Brookside Avenue lift station.

7.7.3.5 Beaumont Mesa

This section documents pipeline improvements within the Beaumont Mesa collection basin.

- **BM-P1:** Construct a new 8-inch gravity main in Right-Of-Way from 800 feet north of Monero Valley Freeway to 2,600 feet east of Potrero Boulevard.
- **BM-P2:** Construct a new 10-inch gravity main in Right-Of-Way from 2,600 feet east of Potrero Boulevard to 1,400 feet south of Oak Valley Parkway.
- **BM-P3:** Construct a new 15-inch gravity main in Right-Of-Way from 1,400 feet south of Oak Valley Parkway to Beaumont Mesa lift station.

7.7.3.6 Beaumont Crossroads

This section documents pipeline improvements within the Beaumont Crossroads collection basin.

- **BC-P1:** Construct a new 15-inch gravity main in 4th Street from 1,875 feet south of Monero Valley Freeway to Beaumont Crossroads lift station.
- **BC-P2:** Construct a new 12-inch gravity main in 4th Street from 275 feet west of Prosperity Way to 400 feet east of Potrero Boulevard.
- **BC-P3:** Construct a new 15-inch gravity main in 4th Street from 400 feet east of Potrero Boulevard to Potrero Boulevard.
- **BC-P4:** Construct a new 18-inch gravity main in 4th Street from Potrero Boulevard to 1,350 feet west of Potrero Boulevard.

• **BC-P5:** Construct a new 21-inch gravity main in 4th Street from 1,350 feet west of Potrero Boulevard to future Beaumont Crossroads lift station.

7.7.3.7 Industrial Park

This section documents pipeline improvements within the Industrial Park collection basin.

• **IP-P1:** Replace existing 8-inch gravity main with a new 10-inch gravity main in Risco Circle from 4th Street to 425 feet south of 4th Street.

7.7.3.8 Beaumont Avenue South

This section documents pipeline improvements within the Beaumont Avenue South collection basin.

- **BAS-P1:** Construct a new 12-inch gravity main in Beaumont Avenue from 1,200 feet north of Laird Road to 2,775 southwest of Laird Road.
- **BAS-P2:** Construct a new 15-inch gravity main in Beaumont Avenue from 2,775 feet southwest of Laird Road to future Beaumont Avenue South lift station.

7.7.3.9 Wastewater Treatment Plant

This section documents pipeline improvements within the Wastewater Treatment Plant collection basin.

- **WWTP-P1**: Reconstruct existing 12-inch gravity main with a steeper slope in Oak Valley Parkway from 550 feet west of San Miguel Drive to 150 feet west of San Miguel Drive.
- **WWTP-P2:** Replace existing 12-inch gravity main with a new 15-inch gravity main in Edgar Avenue from Oak Valley Parkway to 575 feet south of Oak Valley Parkway.
- **WWTP-P3**: Reconstruct existing 12-inch gravity main with a steeper slope in Luis Estrada Road from 400 feet southeast of Veile Avenue to Veile Avenue. Prior to project initialization, it is recommended that this improvement section be surveyed by a licensed professional surveyor to determine the feasibility of reconstructing the pipe slope to meet necessary grade and corresponding capacity requirements.
- **WWTP-P4:** Replace existing 24-inch gravity main with a new 30-inch gravity main in Minnesota Avenue and 4th Street from 525 feet north of 4th Street to 600 feet west of Minnesota Avenue.
- **WWTP-P5:** Replace existing 30-inch gravity main with a new 36-inch gravity main in Right-Of-Way from 4th Street to 1,100 feet west of Minnesota Avenue.
- **WWTP-P6**: Construct a new 12-inch gravity main in Right-Of-Way from 2,300 feet northeast of Highland Springs Avenue to 1,300 feet east of Highland Springs Avenue.

- **WWTP-P7**: Construct a new 15-inch gravity main in Right-Of-Way from 1,300 feet east of Highland Springs Avenue to Highland Springs Avenue.
- **WWTP-P8**: Replace existing 8-inch gravity main with a new 15-inch gravity main in Brookside Avenue from Highland Springs Avenue to Orchard Heights Avenue.
- **WWTP-P9**: Replace existing 8-inch gravity main with a new 15-inch gravity main in Brookside Avenue from Orchard Heights Avenue to Cherry Avenue.
- **WWTP-P10**: Replace existing 8-inch gravity main with a new 15-inch gravity main in Cherry Avenue from Brookside Avenue to Cougar Way.
- **WWTP-P11:** Replace existing 8-inch gravity main with a new 15-inch gravity main in Cherry Avenue from Cougar Way to Oak Valley Parkway.
- **WWTP-P12:** Replace existing 10-inch gravity main with a new 15-inch gravity main in Cherry Avenue from Oak Valley Parkway to Antonell Court.
- **WWTP-P13:** Replace existing 12-inch gravity main with a new 15-inch gravity main in Cherry Avenue from Antonell Court 8th Street.
- **WWTP-P14**: Replace existing 12-inch gravity main with a new 15-inch gravity main in Illinois Avenue from 8th Street to 6th Street.
- **WWTP-P15:** Replace existing 15-inch gravity main with a new 18-inch gravity main in 6th Street from Illinois Avenue to Pennsylvania Avenue.
- **WWTP-P16:** Replace existing 18-inch gravity main with a new 24-inch gravity main in Pennsylvania Avenue from 6th Street to 175 feet south of Interstate 10.
- **WWTP-P17:** Replace existing 18-inch gravity main with a new 30-inch gravity main in Right-Of-Way from Pennsylvania Avenue to 75 feet west of Beaumont Avenue.
- **WWTP-P18:** Reconstruct existing 10-inch gravity main with a steeper slope in Right-Of-Way from 125 feet north of 3rd Street to 400 feet east of Beaumont Avenue. Prior to project initialization, it is recommended that this improvement section be surveyed by a licensed professional surveyor to determine the feasibility of reconstructing the pipe slope to meet necessary grade and corresponding capacity requirements.
- **WWTP-P19:** Reconstruct existing 10-inch gravity main with a steeper slope in Right-Of-Way from 3rd Street to 400 feet east of Beaumont Avenue. Prior to project initialization, it is recommended that this improvement section be surveyed by a licensed professional surveyor to determine the feasibility of reconstructing the pipe slope to meet necessary grade and corresponding capacity requirements.

- **WWTP-P20:** Replace existing 12-inch gravity main with a new 15-inch gravity main in Right-Of-Way from Rover Lane to 350 feet west of Houstonia Lane.
- **WWTP-P21:** Replace existing 24-inch gravity main with a new 30-inch gravity main in 1st Street from Palm Avenue to Beaumont Avenue.
- **WWTP-P22:** Replace existing 30-inch gravity main with a new 36-inch gravity main in 1st Street from California Avenue to Minnesota Avenue.
- **WWTP-P23:** Replace existing 30-inch gravity main with a new 36-inch gravity main in Minnesota Avenue from 1st Street to 575 feet north of 1st Street.
- **WWTP-P24:** Replace existing 30-inch gravity main with a new 36-inch gravity main in Right-Of-Way from 575 feet north of 1st Street to 1,025 feet west of Minnesota Avenue.
- **WWTP-P25:** Construct a new 21-inch gravity main in Beaumont Avenue from 1st Street to 1,275 feet north of Laird Road.

7.7.3.10 Four Seasons

This section documents pipeline improvements within the Four Seasons collection basin.

- **FS-P1:** Replace existing 10-inch gravity main with a new 12-inch gravity main in Highlands Springs Avenue from 6th Street to 450 feet west of Highland Springs Avenue.
- **FS-P2:** Replace existing 10-inch gravity main with a new 12-inch gravity main in Highlands Springs Avenue from 550 feet north of 1st Street to 100 feet south of 1st Street.
- **FS-P3:** Replace existing 12-inch gravity main with a new 15-inch gravity main in Highlands Springs Avenue from 800 feet north of Potrero Boulevard to 50 feet south of Potrero Boulevard.
- **FS-P4**: Reconstruct existing 12-inch gravity main with a steeper slope in Highland Springs Avenue from 100 feet north of Crooked Creek to Crooked Creek. Prior to project initialization, it is recommended that this improvement section be surveyed by a licensed professional surveyor to determine the feasibility of reconstructing the pipe slope to meet necessary grade and corresponding capacity requirements.
- **FS-P5:** Replace existing 15-inch gravity main with a new 18-inch gravity main in Highlands Springs Avenue from 350 feet south of Crooked Creek to 375 feet south of Breckenridge Avenue.
- **FS-P6:** Reconstruct existing 10-inch gravity main with a steeper slope in Breckenridge Avenue from 75 feet west of Highland Spring Avenue to Highland Springs Avenue. Prior to project initialization, it is recommended that this improvement section be surveyed by a

licensed professional surveyor to determine the feasibility of reconstructing the pipe slope to meet necessary grade and corresponding capacity requirements.

CHAPTER 8 - CAPITAL IMPROVEMENT PROGRAM

This chapter provides a summary of the recommended Capital Improvement Program (CIP) for the City's wastewater collection system. The program is based on the evaluation of the City's wastewater collection system and on the recommended projects described in the previous chapters. The CIP has been prepared to assist the City in planning and constructing the collection system improvements through the ultimate buildout scenario. This chapter also presents the cost criteria and methodologies for developing the capacity improvement costs.

8.1 COST ESTIMATE ACCURACY

Cost estimates presented in the capacity improvement costs were prepared for general master planning purposes and, where relevant, for further project evaluation. Final costs of a project will depend on several factors including the final project scope, costs of labor and material, and market conditions during construction.

The Association for the Advancement of Cost Engineering (AACE International), formerly known as the American Association of Cost Engineers, has defined three classifications. These classifications are presented in order of increasing accuracy: Order of Magnitude, Budget, and Definitive.

• Order of Magnitude Estimate. This classification is also known as an "original estimate", "study estimate", or "preliminary estimate", and is generally intended for master plans and studies.

This estimate is not supported with detailed engineering data about the specific project, and its accuracy is dependent on historical data and cost indices. It is generally expected that this estimate would be accurate within -30 percent to +50 percent.

- **Budget Estimate.** This classification is also known as an "official estimate" and generally intended for pre-design studies. This estimate is prepared to include flow sheets and equipment layouts and details. It is generally expected that this estimate would be accurate within -15 percent to +30 percent.
- **Definitive Estimate.** This classification is also known as a "final estimate" and prepared during the time of contract bidding. The data includes complete plot plans and elevations, and equipment data sheets, and complete specifications. It is generally expected that this estimate would be accurate within -5 percent to +15 percent.

Costs developed in this study should be considered "Order of Magnitude" and have an expected accuracy range of **-30 percent** and **+50 percent**.

8.2 COST ESTIMATE METHODOLOGY

Cost estimates presented in this chapter are opinions of probable construction and other relevant costs developed from several sources including cost curves, Akel experience on other master planning projects, and input from District staff on the development cost sharing. Where appropriate, costs were escalated to reflect the more current Engineering News Records (ENR) Construction Cost Index (CCI).

This section documents the unit costs used in developing the opinion of probable construction costs, the Construction Cost Index, and markups to account for construction contingency and other project related costs.

8.2.1 Unit Costs

The unit cost estimates used in developing the Capital Improvement Program are summarized on **Table 8.1**. Wastewater pipeline unit costs are based on length of pipe per chosen diameter. Lift station costs are based on capacity, per million gallons per day (MGD). The unit costs are intended for developing the Order of Magnitude estimate, and do not account for site specific conditions, labor or material costs during the time of construction, final project scope, implementation schedule, detailed utility and topography surveys, investigation of alternative routings for pipes, and other various factors. The capital improvement program included in this report accounts for construction and project-related contingencies as described in this chapter.

8.2.2 Construction Cost Index

Costs estimated in this study are adjusted utilizing the Engineering News Record (ENR) Construction Cost Index (CCI), which is widely used in the engineering and construction industries.

The costs in this Wastewater Master Plan were benchmarked using a 20-City national average ENR CCI of 11,849, reflecting a date of April 2021.

8.2.3 Land Acquisition

Construction of pipelines is assumed to generally be within existing or future street right-of-ways. Lift station land acquisition costs are included in the lift station unit costs.

8.2.4 Construction Contingency Allowance

Knowledge about site-specific conditions for each proposed project is limited at the master planning stage; therefore construction contingencies were used. The estimated construction costs in this master plan include a **20 percent** contingency allowance to account for unforeseen events and unknown field conditions.

Table 8.1 Unit Costs

Wastewater Master Plan City of Beaumont

PRELIMINARY

Pipeline	PRELIMINARY
Gravity Main ¹	
Pipe Size	Cost ¹
(in)	(\$/lineal foot)
8	\$191
10	\$200
12	\$208
15	\$230
18	\$247
21	\$331
24	\$396
27	\$468
30	\$526
36	\$670
Force Main ¹	L
6	\$216
8	\$264
10	\$278
16	\$376
Operational and Maintenance ²	
Sewer Pipeline CCTV	\$2.10
Sewer Pipeline Cleaning	\$1.80
Lift Station ³	
Estimated Lift Station Project Cost 314,097*Q + 365,718, where C	
ENGINEERING GROUP, INC.	5/21/2021

Notes :

- 1. Unit costs indexed using the Engineering News Record (ENR) Construction Cost Index of 11,849 for April 2021.
- 2. Sewer pipeline operational and maintenance costs based on Akel Engineering Group experience on similar projects.
- 3. Lift Station costs based on Akel Engineering Group experience on similar projects and escalated using the Engineering News Record (ENR) Construction Cost Index of 11,849 for April 2021.

8.2.5 **Project Related Costs**

The capital improvement costs also account for project-related costs, comprising of engineering design, project administration (developer and District staff), construction management and inspection, and legal costs. The project related costs in this master plan were estimated by applying an additional **30 percent** to the estimated construction costs.

8.3 LIFT STATION CONDITION ASSESSMENT COSTS

The lift station condition assessment, completed by V&A, included condition improvement recommendations for deficiencies identified during the assessment. An estimated opinion of probable costs for these improvements was prepared and submitted to City staff for review and approval. The recommended improvements and associated costs are documented in Table 8.2.

8.4 CAPITAL IMPROVEMENT PROGRAM

This section documents the capital improvement program, including estimated costs and recommended construction phasing.

8.4.1 Capital Improvement Costs

The Capital Improvement Program costs for the projects identified in this master plan for mitigating existing deficiencies and for servicing anticipated future growth throughout the City are summarized on Table 8.3.

Each improvement was assigned a unique coded identifier associated with the improvement type and is summarized graphically on Figure 8.1. The estimated construction costs include the baseline costs plus **20 percent** contingency allowance to account for unforeseen events and unknown filed conditions, as described in a previous section. Capital improvement costs include the estimated construction costs plus **30 percent** projected-related costs (engineering design, project administration, construction management and inspection, and legal costs).

Capital Improvement project sheets are provided in Appendix H. These project sheets document the location of the recommended improvements as well as providing a description of the improvement and the capital improvement costs.

8.4.2 Pipelines

The recommended pipeline improvements are grouped by collection basin and listed on **Table 8.3**. Each improvement includes a general description of the street alignment and limits as well as existing pipe diameter and length.

The Capital Improvement Program generally includes the following three types of improvements:

• **Replacement Pipeline, Existing Capacity Deficiency.** An existing pipeline is recommended for replacement to mitigate an existing system deficiency. This type of




Table 8.2 Lift Station Condition Assessment Improvements

Wastewater Master Plan

									PRELIMINARY
			Recommended		Infrastructure Costs		Baseline	Estimated	Capital
Lift Station	Specific Facility	Lift Station Component	Timeline	Unit Cost	Unit	Amount	Construction Cost	Construction Cost ¹	Improvement Cost ²
				(\$/unit)		(unit)			
Fairway Car	iyon								
FC-1	Pump	Repair leak from Pump #2	Immediately				0	0	0
FC-2	Wet Well	Apply mortar	2 to 5 years	30	Square Foot	30	900	1,100	1,500
FC-3	Dry Well	Repair Liner	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
FC-4	Dry Well	Touch up pipe coating	2 to 5 years	30	Square Foot	130	3,900	4,700	6,200
				Subtotal - Fai	rway Canyon Lift Station	n Improvements	7,800	9,400	12,400
Lower Oak	/alley								
LOV-1	Wet Well	Replace pump discharge piping	Immediately	5,200	Lump	-	5,200	6,300	8,200
LOV-2	Concrete	Monitor the state of degradation	2 to 5 years		No cost		0	0	0
LOV-3	Concrete	Repair cracked/broken concrete	2 to 5 years	2,600	Lump	-	2,600	3,200	4,200
LOV-4	Liner	Bond liner to concrete	2 to 5 years	30	Square Foot	30	900	1,100	1,500
LOV-5	Piping	Re-coat piping	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal - Low	er Oak Valley Lift Statio	n Improvements	11,700	14,200	18,600
Upper Oak	/alley								
UOV-1	Wet Well	Replace pump discharge piping	Immediately	5,200	Lump	-	5,200	6,300	8,200
UOV-2	Connection	Replace threaded tap connection	Immediately	1,000	Lump	-	1,000	1,200	1,600
UOV-3	Concrete	Repair cracked/broken concrete	2 to 5 years	2,600	Lump	-	2,600	3,200	4,200
UOV-4	Bypass Manhole	Replace liner	2 to 5 years	30	Square Foot	500	15,000	18,000	23,400
UOV-5	Piping	Re-coat piping	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal - Upp	er Oak Valley Lift Statio	n Improvements	26,800	32,300	42,100
Olivewood									
0-1	Piping	New coating	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal	l - Olivewood Lift Statio	n Improvements	3,000	3,600	4,700
Beaumont M	/lesa								
BM-1	Piping	New coating	Immediately	30	Square Foot	100	3,000	3,600	4,700
BM-2	Concrete	Repair cracked/broken concrete	2 to 5 years	2,600	Lump	-	2,600	3,200	4,200
BM-3	Wet Well	Repair liner	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
BM-4	Manhole	Replace liner	2 to 5 years	45	Square Foot	500	22,500	27,000	35,100
BM-5	Dry Well	Touch up pipe coating	2 to 5 years	30	Square Foot	130	3,900	4,700	6,200

Table 8.2 Lift Station Condition Assessment Improvements

Wastewater Master Plan

City of Beaumont

			Deserves and ad		Infrastructure Costs		Decelies	Estimated	Capital
Lift Station	Specific Facility	Lift Station Component	Recommended Timeline	Unit Cost	Unit	Amount	Baseline Construction Cost	Construction Cost ¹	Improvemer Cost ²
				(\$/unit)		(unit)			
BM-6	Wet Well	Coat the inlet pipe	2 to 5 years	30	Square Foot	130	3,900	4,700	6,200
				Subtotal - Beau	umont Mesa Lift Statio	n Improvements	38,900	46,800	61,100
Noble Creek									
NC-1	Wet Well	Replace pump discharge piping	2 to 5 years	5,200	Lump	-	5,200	6,300	8,200
NC-2	Piping	Re-coat piping	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal -	Noble Creek Lift Statio	n Improvements	8,200	9,900	12,900
Marshall Cre	eek								
MC-1	Wet Well	Replace pump discharge piping	Immediately	5,200	Lump	-	5,200	6,300	8,200
MC-2	Piping	Re-coat piping	Immediately	30	Square Foot	100	3,000	3,600	4,700
MC-3	Manhole	Patch-repair liner	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
MC-4	Manhole	Repair/replace lid and cover frame	2 to 5 years	1,500	Lump	-	1,500	1,800	2,400
				Subtotal - Ma	arshall Creek Lift Statio	n Improvements	12,700	15,300	20,000
Cooper Cree	k								
CC-1	Piping	Re-coat piping	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal - C	ooper Creek Lift Statio	n Improvements	3,000	3,600	4,700
Seneca Sprir	ngs								
SS-1	Couplings	Replace couplings showing damage	Immediately	1,500	Lump	-	1,500	1,800	2,400
SS-2	Concrete	Monitor state of corrosion	2 to 5 years		No cost		0	0	0
SS-3	Piping	Touch up pipe coating	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
				Subtotal - Se	neca Springs Lift Statio	n Improvements	4,500	5,400	7,100
Four Season	S								
FS-1	Manhole	Patch-repair liner	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
FS-2	Piping	Touch up pipe coating	2 to 5 years	30	Square Foot	100	3,000	3,600	4,700
FS-3	Couplings	Replace couplings showing damage	2 to 5 years	1,500	Lump	-	1,500	1,800	2,400
				Subtotal - F	our Seasons Lift Statio	n Improvements	7,500	9,000	11,800
Total Costs									
							124,100	149,500	195,400

ENGINEERING GROUP, INC. Notes:

1. Estimated Construction costs include 20 percent of baseline construction costs to account for unforeseen events and unknown field conditions.

2. Capital Improvement Costs also include an additional 30 percent of the estimated construction costs to account for administration, construction management, and legal costs.

Wastewater Master Plan

	City of Beaumon							1		1				PRELIMINARY
	Tupo of				Improveme	nts Details		Infrastru	cture Costs	Basalina Constr	Estimated Const.	Capital Impro.	Future Flow	
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Cost	Cost ¹	Cost ^{2,3}	Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Lower Oak	Valley Lift Statio	n Tributary Area												
Gravity Main	n Improvements							1		I.				
LOV-P1	Future Capacity Increase	Irwin St	From Floyd Cir to Palmer Ave	15	Replace	18	525	247	129,621	129,700	155,700	202,500	Within City Limit	Approximately 200 EDUs
Lift Station I	mprovements													
LOV-LS	Lift Station Replacement	Lower Oak Valley Lift St	ation	-	Replace	3@62	25 gpm	-	1,284,238	1,284,300	1,541,200	2,003,600	Within City Limit	Approximately 260 EDUs
				Subtota	al - Lower Oal	k Valley Lift S	tation Tribu	utary Area Im	provements	1,414,000	1,696,900	2,206,100		
Tuluut Car		tation Tributany Avaa						1						
		tation Tributary Area												
Force Main I	mprovements		From Tukwet Canyon lift station to											
TC-FM1	New Force Main	Sorenstam Dr/Price St	approx. 1,000' n/o Upper Oak Valley lift station	-	New	8	6,250	264	1,652,656	1,652,700	1,983,300	2,578,300	Within City Limit	As Development Occurs
TC-FM2	New Force Main	Sorenstam Dr/Price St	From Tukwet Canyon lift station to approx. 1,000' n/o Upper Oak Valley lift station	-	New	8	6,250	264	1,652,656	1,652,700	1,983,300	2,578,300	Within City Limit	As Development Occurs
Lift Station I	mprovements													
TC-LS	New Lift Station	Tukwet Canyon Lift Stat	ion	-	New	3@37	'5 gpm	-	899,920	900,000	1,080,000	1,404,000	Within City Limit	As Development Occurs
				Subtotal - T	ukwet Canyoi	n (New) Lift S	tation Tribu	utary Area Im	provements	4,205,400	5,046,600	6,560,600		
Upper Oak	Valley Lift Statio	n Tributary Area											1	
Gravity Mair	n Improvements													
UOV-P1	Future Capacity Increase	Straightaway Dr	From Balata St to 350' sw/o Balata St	8	Replace	10	350	200	69,910	70,000	84,000	109,200	Within City Limit	Approximately 70 EDUs
UOV-P2	Existing Capacity Deficiency	Apron Ln	From Stableford Ct to Oak Valley Pkwy	8	Replace	12	300	208	62,342	62,400	74,900	97,400	Within City Limit	FY 2023/24
UOV-P3	Future Capacity Increase	Oak Valley Pkwy	From Apron Ln to 2,450' w/o Apron Ln	12	Replace	15	2,500	230	575,740	575,800	691,000	898,300	Within City Limit	Approximately 1,360 EDUs
Lift Station I	mprovements							1		I			1	
UOV-LS	Lift Station Replacement	Upper Oak Valley Lift St	ation	-	Replace	3 @ 1,8	50 gpm	-	3,493,305	3,493,400	4,192,100	5,449,800	Within City Limit	Approxiamtely 2,360 EDUs
	Replacement			Subtota	al - Upper Oal	k Valley Lift S	tation Tribu	utary Area Im	provements	4,201,600	5,042,000	6,554,700		
Olivewood	Lift Station Tribu	itary Area												
Gravity Mair	n Improvements													
O-P1	Future Capacity Increase	ROW	From Artisan PI to approx. 500' n/o Artisan PI	10	Replace	12	525	208	109,099	109,100	131,000	170,300	Within City Limit	Approximately 750 EDUs
Lift Station I	mprovements							1						
O-LS	Lift Station Replacement	Olivewood Lift Station		-	Replace	2@65	60 gpm	-	987,577	987,600	1,185,200	1,540,800	Within City Limit	Approximately 710 EDUs
				9	Subtotal - Oliv	vewood Lift S	tation Tribu	utary Area Im	provements	1,096,700	1,316,200	1,711,100		

Wastewater Master Plan

	City of Beaumon	L												PRELIMINARY
					Improveme	nts Details		Infrastruc	ture Costs		Fatimeted Count	Constal language		
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Capital Impro. Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Brookside	Avenue (New) Lif	t Station Tributary Are	ea											
Gravity Mai	n Improvements							1					I	
BR-P1	New Capacity	Brookside Ave	From 480' w/o Deodar Dr to Brookside Ave lift station	-	New	8	2,200	191	420,656	420,700	504,900	656,400	Within City Limit	As Development Occurs
Force Main	Improvements							1		1				
BR-FM1	New Force Main	Brookside Ave	From Brookside Ave lift station to Deodar Dr	-	New	6	2,825	216	609,832	609,900	731,900	951,500	Within City Limit	As Development Occurs
Lift Station	mprovements													
BR-LS	New Lift Station	Brookside Ave Lift Stati	on	-	New	2 @ 30	0 gpm	-	644,313	644,400	773,300	1,005,300	Within City Limit	As Development Occurs
			S	ubtotal - Broo	okside Avenue	e (New) Lift St	ation Tribu	itary Area Im	provements	1,675,000	2,010,100	2,613,200		
Beaumont	Mesa Lift Station	Tributary Area						1		1			1	
Gravity Mai	n Improvements													
BM-P1	New Capacity	ROW	From 800' n/o Monero Valley Fwy to 2,600' e/o Potrero Blvd	-	New	8	2,575	191	492,359	492,400	590,900	768,200	Within City Limit	As Development Occurs
BM-P2	New Capacity	ROW	From 2,600' e/o Potrero Blvd to 1,400' s/o Oak Valley Pkwy	-	New	10	1,600	200	319,588	319,600	383,600	498,700	Within City Limit	As Development Occurs
BM-P3	New Capacity	ROW	From 1,400' s/o Oak Valley Pkwy to Beaumont Mesa lift station	-	New	15	2,350	230	541,196	541,200	649,500	844,400	Within City Limit	As Development Occurs
Force Main	Improvements ⁵													
BM-FM1	Force Main Desi	gn and Pump Design		-	New			-	-	-	-	450,000	Within City Limit	FY 2021/22
BM-FM1	New Force Main	Potrero Blvd/Western Knolls Ave	From Beaumont Mesa lift station to 1,300' w/o Western Knolls Ave	-	New	16	6,500	-	-	-	-	4,000,000	Within City Limit	FY 2022/23
Lift Station	mprovements ⁵							1					T	
BM-LS	Pump Replacem	ent/Addition Constructic	on	-	New	2 @ 3,50 2 @ 1,50		-	-	-	-	750,000	Within City Limit	FY 2022/23
BM-WW	Wet Well Design			-	New			-	-	-	-	400,000	Within City Limit	FY 2021/22
BM-WW	New Wet Well			-	New			-	-	-	-	4,000,000	Within City Limit	FY 2024/25
				Subto	tal - Beaumor	nt Mesa Lift St	ation Tribu	itary Area Im	provements	1,353,200	1,624,000	11,711,300		
Beaumont	Crossroads (New) Lift Station Tributary	/ Area					1						
Gravity Mai	n Improvements													
BC-P1	New Capacity	W 4th St	From 1,875' s/o Moreno Valley Fwy to Beaumont Crossroads lift station	-	New	15	3,125	230	719,676	719,700	863,700	1,122,900	Within City Limit	As Development Occurs
BC-P2	New Capacity	W 4th St	From 275' w/o of Prosperity Way to 400' e/o Potrero Blvd	-	New	12	2,100	208	436,397	436,400	523,700	680,900	With Annexation	As Development Occurs
BC-P3	New Capacity	W 4th St	From 400' e/o Potrero Blvd to Potrero Blvd	-	New	15	375	230	86,361	86,400	103,700	134,900	With Annexation	As Development Occurs
BC-P4	New Capacity	W 4th St	From Potrero Blvd to 1,350' w/o Potrero Blvd	-	New	18	1,450	247	358,001	358,100	429,800	558,800	With Annexation	As Development Occurs
BC-P5	New Capacity	W 4th St	From 1,350' w/o Potrero Blvd to Beaumont Crossroads lift station	-	New	21	800	331	264,625	264,700	317,700	413,100	With Annexation	As Development Occurs

Wastewater Master Plan

	City of Beaumon							1						PRELIMINAR
					Improveme	nts Details		Infrastruc	ture Costs		Estimated Const	Conital Impro		
Improv. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Force Main	Improvements			1				1					1	
BC-FM1	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	16	9,175	376	3,447,614	3,447,700	4,137,300	5,378,500	With Annexation	As Development Occurs
BC-FM2	New Force Main	W 4th St	From Beaumont Crossroads lift station to 100' e/o Nicholas Rd	-	New	6	9,175	216	1,980,605	1,980,700	2,376,900	3,090,000	With Annexation	As Development Occurs
Lift Station	Improvements			1				1					1	
BC-LS	New Lift Station	Beaumont Crossroad	s Lift Station	-	New	3 @ 2,3	50 gpm	-	4,550,536	4,550,600	5,460,800	7,099,100	With Annexation	As Development Occurs
			Subt	otal - Beaumo	ont Crossroad	s (New) Lift S	tation Tribu	utary Area Im	provements	11,844,300	14,213,600	18,478,200		
Marshall C	reek Lift Station	Tributary Area												
Lift Station	Improvements													
MC-LS	Lift Station Replacement	Marshall Creek Lift St	ation	-	Replace	2 @ 1,7	00 gpm	-	2,135,215	2,135,300	2,562,400	3,331,200	Within City Limit	Approximately 1,200 EDUs
				Subt	otal - Marsha	ll Creek Lift S	tation Tribu	utary Area Im	provements	2,135,300	2,562,400	3,331,200		
Industrial I	Park Lift Station 1	ributary Area												
Gravity Mai	n Improvements													
IP-P1	Future Capacity Increase	Risco Cir	From W 4th St to 425' s/o W 4th St	8	Replace	10	475	200	94,878	94,900	113,900	148,100	Within City Limit	Approximately 190 EDUs
Lift Station	Improvements			1				1						
IP-LS	Lift Station Replacement	Industrial Park Lift Sta	ation	-	Replace	2@30)0 gpm	-	644,313	644,400	773,300	1,005,300	Within City Limit	Approximately 20 EDUs
				Sub	total - Industr	ial Park Lift S	tation Tribu	utary Area Im	provements	739,300	887,200	1,153,400		
Beaumont	Avenue South (N	lew) Lift Station Trib	utary Area											
Gravity Mai	n Improvements													
BAS-P1	New Capacity	Beaumont Ave	From 1,200' n/o Laird Rd to 2,775' sw/o Laird Rd	-	New	12	4,125	208	857,209	857,300	1,028,800	1,337,500	With Annexation	As Development Occurs
BAS-P2	New Capacity	Beaumont Ave	From 2,775' sw/o Laird Rd to Beaumont Avenue lift station	-	New	15	875	230	201,509	201,600	242,000	314,600	With Annexation	As Development Occurs
Force Main	Improvements			1				1					1	
BAS-FM1	New Force Main	Beaumont Ave	From Beaumont Avenue lift station to 2,450' s/o E 1st St	-	New	10	5,025	278	1,398,669	1,398,700	1,678,500	2,182,100	With Annexation	As Development Occurs
Lift Station	Improvements			1				1						
BAS-LS	New Lift Station	Beaumont Avenue So	outh Lift Station	-	New	3 @ 90	00 gpm	-	1,733,029	1,733,100	2,079,800	2,703,800	With Annexation	As Development Occurs
			Subtota	l - Beaumont	Avenue Sout	n (New) Lift S	tation Tribu	utary Area Im	provements	4,190,700	5,029,100	6,538,000		
Wastewate	er Treatment Pla	nt Tributary Area												
Gravity Mai	n Improvements													
WWTP-P1	Future Capacity Increase	Oak Valley Pkwy	From 550' w/o San Miguel Dr to 150' w/o San Miguel Dr	12	Replace	12	425	208	88,319	88,400	106,100	138,000	Within City Limit	Approximately 370 EDUs

Wastewater Master Plan

City of Beaumont

					Improvemer	nts Details		Infrastruc	ture Costs					PRELIMINARY
Improv. No.	Type of	Alignment	Limits	Existing	New/			mastrac			Estimated Const.	Capital Impro. Cost ^{2,3}	Future Flow	Construction Trigger ⁴
	Improvement			Diameter	Replace	Diameter	Length	Unit Cost	Infr. Cost	Cost	Cost ¹	Cost "	Service Location	
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
WWTP-P2	Existing Capacity Deficiency	Edgar Ave	From Oak Valley Pkwy to 575' s/o Oak Valley Pkwy	12	Replace	15	575	230	132,420	132,500	159,000	206,700	Within City Limit	FY 2022/23
WWTP-P3	Future Capacity Increase	Luis Estrada Rd	From 400' se/o Veile Ave to Veile Ave	12	Replace	12	425	208	88,319	88,400	106,100	138,000	Within City Limit	Approximately 3,830 EDUs
WWTP-P4	Future Capacity Increase	Minnesota Ave/W 4th St	From 525' n/o W 4th St to 600' w/o Minnesota Ave	24	Replace	30	1,125	526	592,178	592,200	710,700	924,000	Within City Limit	Approximately 5,890 EDUs
WWTP-P5	Future Capacity Increase	ROW	From 4th St to 1,100' w/o Minnesota Ave	30	Replace	36	950	670	636,064	636,100	763,400	992,500	Within City Limit	Approximately 8,820 EDUs
WWTP-P6	New Capacity	ROW	From 2,300 ne/o Highland Springs Ave to 1,300 e/o Highland Springs Ave	-	New	12	3,875	208	805,257	805,300	966,400	1,256,400	With Annexation	As Development Occurs
WWTP-P7	New Capacity	ROW	From 1,300' e/o Highland Springs Ave to Highland Springs Ave	-	New	15	1,300	230	299,385	299,400	359,300	467,100	With Annexation	As Development Occurs
WWTP-P8	Future Capacity Increase	Brookside Ave	From Highland Springs Ave to Orchard Heights Ave	8	Replace	15	2,650	230	610,285	610,300	732,400	952,200	With Annexation	As Development Occurs
WWTP-P9	Future Capacity Increase	Brookside Ave	From Orchard Heights Ave to Cherry Ave	8	Replace	15	2,700	230	621,800	621,800	746,200	970,100	Within City Limit With Annexation	Approximately 320 EDUs
WWTP-P10	Future Capacity Increase	Cherry Ave	From Brookside Ave to Cougar Way	8	Replace	15	2,650	230	610,285	610,300	732,400	952,200	Within City Limit With Annexation	Approximately 300 EDUs
WWTP-P11	Future Capacity Increase	Cherry Ave	From Cougar Way to Oak Valley Pkwy	8	Replace	15	2,675	230	616,042	616,100	739,400	961,300	Within City Limit With Annexation	Approximately 210 EDUs
WWTP-P12	Future Capacity Increase	Cherry Ave	From oak Valley Pkwy to Antonell Ct	10	Replace	15	1,700	230	391,504	391,600	470,000	611,000	Within City Limit With Annexation	Approximately 1,170 EDUs
WWTP-P13	Future Capacity Increase	Cherry Ave	From Antonell Ct to E 8th St	12	Replace	15	3,675	230	846,338	846,400	1,015,700	1,320,500	Within City Limit With Annexation	Approximately 2,430 EDUs
WWTP-P14	Future Capacity Increase	Illinois Ave	From E 8th St to E 6th St	12	Replace	15	1,175	230	270,598	270,600	324,800	422,300	Within City Limit With Annexation	Approximately 2,300 EDUs
WWTP-P15	Future Capacity Increase	E 6th St	From Illinois Ave to Pennsylvania Ave	15	Replace	18	700	247	172,828	172,900	207,500	269,800	Within City Limit With Annexation	Approximately 4,070 EDUs
WWTP-P16	Future Capacity Increase	Pennsylvania Ave	From E 6th St to 175' s/o Interstate 10	18	Replace	24	975	396	385,811	385,900	463,100	602,100	Within City Limit With Annexation	Approximately 1,940 EDUs
WWTP-P17	Future Capacity Increase	ROW	From Pennsylvania Ave to 75' w/o Beaumont Ave	18	Replace	30	3,800	526	2,000,246	2,000,300	2,400,400	3,120,600	Within City Limit With Annexation	Approximately 380 EDUs
WWTP-P18	Future Capacity Increase	ROW	From 125' n/o 3rd St to 400' e/o Beaumont Ave	10	Replace	10	125	200	24,968	25,000	30,000	39,000	Within City Limit	Approximately 2,680 EDUs
WWTP-P19	Future Capacity Increase	ROW	From 3rd St to 400' e/o Beaumont Ave	10	Replace	10	175	200	34,955	35,000	42,000	54,600	Within City Limit	Approximately 1,760 EDUs
WWTP-P20	Future Capacity Increase	ROW	From Rover Ln to 350' w/o Houstonia Ln	12	Replace	15	2,550	230	587,255	587,300	704,800	916,300	Within City Limit	Approximately 2,070 EDUs
WWTP-P21	Future Capacity Increase	E 1st St	From Palm Ave to Beaumont Ave	24	Replace	30	1,600	526	842,209	842,300	1,010,800	1,314,100	Within City Limit	Approximately 6,350 EDUs
WWTP-P22	Future Capacity Increase	E 1st st	From California Ave to Minnesota Ave	30	Replace	36	2,125	670	1,422,776	1,422,800	1,707,400	2,219,700	Within City Limit With Annexation	Approximately 15,780 EDUs
WWTP-P23	Future Capacity Increase	Minnesota Ave	From E 1st St to 575' n/o E 1st St	30	Replace	36	575	670	384,986	385,000	462,000	600,600	Within City Limit With Annexation	Approximately 23,390 EDUs
WWTP-P24	Future Capacity Increase	ROW	From 575' n/o E 1st St to 1,025' w/o Minnesota Ave	30	Replace	36	1,100	670	736,496	736,500	883,800	1,149,000	Within City Limit With Annexation	Approximately 2,500 EDUs
WWTP-P25	New Capacity	Beaumont Ave	From E 1st St to 1,275' n/o Laird Rd	-	New	21	2,475	331	818,683	818,700	982,500	1,277,300	With Annexation	As Development Occurs
				Subtota	l - Wastewate	er Treatment I	Plant Tribu	itary Area Im	provements	14,021,100	16,826,200	21,875,400		

PRELIMINARY

Wastewater Master Plan

City of Beaumont

					Improveme	nts Details		Infrastruc	ture Costs					PRELIMINA
nprov. No.	Type of Improvement	Alignment	Limits	Existing Diameter	New/ Replace	Diameter	Length	Unit Cost	Infr. Cost	Baseline Constr. Cost	Estimated Const. Cost ¹	Capital Impro. Cost ^{2,3}	Future Flow Service Location	Construction Trigger ⁴
				(in)		(in)	(ft)	(\$)	(\$)	(\$)	(\$)	(\$)		
Four Seaso	ns Lift Station Tril	outary Area												
Gravity Mai	n Improvements													
FS-P1	Future Capacity Increase	Highland Springs Ave	From E 6th St to 450' w/o Highland Springs Ave	10	Replace	12	1,225	208	254,565	254,600	305,600	397,300	Within City Limit	Approximately 640 EDU
FS-P2	Future Capacity Increase	Highland Springs Ave	From 550' n/o E 1st St to 100' s/o E 1st St	10	Replace	12	650	208	135,075	135,100	162,200	210,900	Within City Limit	Approximately 690 EDU
FS-P3	Future Capacity Increase	Highland Springs Ave	From 800' n/o Potrero Blvd to 50' s/o Potrero Blvd	12	Replace	15	850	230	195,752	195,800	235,000	305,500	Within City Limit	Approximately 1,340 EDU
FS-P4	Pipe Slope Reconstruction	Highland Springs Ave	From 100' n/o Crooked Creek to Crooked Creek	12	Replace	12	100	208	20,781	20,800	25,000	32,500	Within City Limit	Approximately 1,470 ED
FS-P5	Future Capacity Increase	Highland Springs Ave	From 350' s/o Crooked Creek to 375' s/o Breckenridge Ave	15	Replace	18	1,525	247	376,518	376,600	452,000	587,600	Within City Limit	Approximately 1,840 EDI
FS-P6	Future Capacity Increase	Breckenridge Ave	From 75' w/o Highland Springs Ave to Highland Springs Ave	10	Replace	10	75	200	14,981	15,000	18,000	23,400	Within City Limit	Approximately 1,830 EDI
Lift Station I	Improvements							1		1				
FS-LS	Lift Station Replacement	Four Seasons Lift Statio	n	-	Replace	3 @ 1,3	50 gpm	-	2,526,260	2,526,300	3,031,600	3,941,100	Within City Limit	Approximately 3,810 ED
				Su	btotal - Four S	Seasons Lift St	ation Tribu	itary Area Im	provements	3,524,200	4,229,400	5,498,300		
Other Was	tewater System Ir	nprovements ⁶												
	Lift Station Cond	ition Assessment						-	-	-	-	3,600,000	Within City Limit	FY 2022/23 - FY 2030/3
	CCTV Program							-	-	-	-	300,000	Within City Limit	FY 2023/24 FY 2029/30
	On-going Pipeline	e Replacement Program						-	-	-	-	4,800,000	Within City Limit	FY 2023/24 - FY 2030/3
	Wastewater Trea	tment Plant Improveme	nts					-	-	-	-	2,000,000	Within City Limit	FY 2021/22 - FY 2024/2 FY 2028/29 - FY 2030/3
					Su	btotal - Other	Wastewat	er System Im	provements	-	-	10,700,000		
Total Costs	;													
							Gra	wity Main Im	provements	20,759,000	24,912,800	32,388,800		
							F	orce Main Im	provements	10,742,400	12,891,200	21,208,700		
						e .1		ift Station Im		18,899,400	22,679,700	34,634,000		
						Other	Wastewat	er System Im	provements	-	-	10,700,000		
	E L							Total Improv	vement Cost	50,400,800	60,483,700	98,931,500		

Notes:

1. Estimated Construction costs include 20 percent of baseline construction costs to account for unforeseen events and unknown field conditions.

2. Unless noted otherwise, Capital Improvement Costs also include an additional 30 percent of the estimated construction costs to account for administration, construction management, and legal costs.

3. Cost allocation for development related improvements to be reviewed as construction triggers are reached.

4. EDU triggers based on remaining pipeline and lift station capacity and assumes 235 gpd/EDUs, consistent with EMWD Wastewater Master Plan Criteria.

5. Beaumont Mesa force main and wet well expansion reflects City staff budgetary planning estimate provided by City staff June 1, 2021.

6. Other wastewater system improvements reflects City staff budgetary planning estimate provided by City staff June 1, 2021.

improvement is listed as *Existing Capacity Deficiency* on **Table 8.3**. The recommended size for these improvements are based on buildout flow requirements.

- **Replacement Pipeline, Capacity Deficiency Triggered by Future Development.** An existing pipeline is recommended for replacement where additional flow due to future development will create a capacity deficiency. This type of improvement is listed as *Future Capacity Increase* on Table 8.3.
- New Pipeline, Triggered by Future Development. A new pipeline is proposed to serve future growth. This type of improvement is listed as *New Capacity* on Table 8.3.

The opinion of probable construction costs, for the projects included in this master plan, are based on the pipe unit costs summarized on Table 8.1.

It is assumed that in general any replacement pipes will be in the same alignment and the same slope as the existing pipe. However, this study recommends an investigation of the alignment during the pre-design stage of each project.

8.4.3 Improvement Service Location

The Capital Improvement Program on **Table 8.3** classifies the improvements based on the future flow service location. These classifications are summarized as follows:

- Within City Limits: This improvement will convey existing and future flows from development within the existing City limits.
- With Annexation: This improvement will convey future flows from development outside of the existing City limits but within the General Plan Boundary, which would require future annexation.

It should be noted that some improvements convey flows from both service location classifications, as shown on Table 8.2.

8.4.4 Construction Triggers

The CIP improvements are prioritized based on their urgency to mitigate existing deficiencies and to serve future growth. The construction triggers for each improvement are classified as:

- **Fiscal Year:** For improvements included in the 10-Year Capital Improvement Program (Table 8.4) the fiscal year for planned implementation is shown on Table 8.3.
- Equivalent Dwelling Unit: A equivalent dwelling unit (EDU) construction trigger is provided for improvements designated as capacity increases for future development. This trigger is based on remaining capacity in the existing facility planned for future improvement. The remaining capacity is converted to EDUs assuming 235 gpd/EDU.

Table 8.4 10-Year Improvement Phasing

Wastewater Master Plan

City of Beaumont

	Funding Type	Type of Improvement	Project Name	Project Description	Fiscal Year Improvement Phasing									Tota	
IP ID					FY 2021/22	FY 2022/23	FY 2023/24	FY 2024/25	FY 2025/26	FY 2026/27	FY 2027/28	FY 2028/29	FY 2029/30	FY 2030/31	Improvement Cost
		2			(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)
ravity M	ain Improveme			Poplace quicting 9 inch growity main with now 12 inch							1			1	1
UOV-P2		Existing Capacity Deficiency	Apron Lane Pipeline Replacement	Replace existing 8-inch gravity main with new 12-inch gravity main in Apron Ln			97,400								97,4
/WTP-P2		Existing Capacity Deficiency	Edgar Ave Pipeline Replacement	Replace existing 12-inch gravity main with new 15-inch gravity main in Edgar Ave		206,700									206,
				Subtotal - Gravity Main Improvements	0	206,700	97,400	0	0	0	0	0	0	0	304,
eaumon	t Mesa Improve	ments										1		1	
		New Force Main	Force Main Design and Pump Design	Design of new force main and pump additions	450,000										450,0
			Pump Replacement/Addition Construction	Construction of replacement pumps and additional pumps for LS		750,000									750,0
			Force Main Construction	Construction of new 16-inch force main		4,000,000									4,000
		New Wet Well	Wet Well Design	Design of New Wet Well	400,000										400,
			Wet Well Construction	Construction of New Wet Well				4,000,000							4,000
				Subtotal - Beaumont Mesa Improvements	850,000	4,750,000	0	4,000,000	0	0	0	0	0	0	9,600
ift Statio	n Condition Ass	essment Improver	nents	l l		1	11		1	1	1	1	1	1	1
	I	lift Station Condition		Ongoing lift station improvements to include new electrical, new pumps, repairs to wetwells, repairs to components at the LS, etc		400,000	400,000	400,000	400,000	400,000	400,000	400,000	400,000	400,000	3,600
			Sul	btotal - Lift Station Condition Assessment Improvements	0	400,000	400,000	400,000	400,000	400,000	400,000	400,000	400,000	400,000	3,600
)peratior	and Maintena	nce Improvements	;			I			I	I	I	I	I	I	
			CCTV Program	CCTV Wastewater System every 3-years (approx. 59 miles/year) - camera & truck			150,000						150,000		300,
			On-going Pipeline Replacement Program	As-needed pipeline replacement for ongoing system improvements			500,000	500,000	500,000	600,000	600,000	600,000	750,000	750,000	4,800
				Subtotal - Operation and Maintenance Improvements	0	0	650,000	500,000	500,000	600,000	600,000	600,000	900,000	750,000	5,100
Vastewa	ter Treatment P	lant				1	1		1	1	1	1	1	1	
		Study	Wastewater Rate Study	Rate Study for FY24 - FY28	200,000										200,
		Construction	I&I Project - Flow Meters	Installation of Flow Meters at LS	200,000										200,
		Construction	I&I System Repairs - Phase 3	Various needed repairs system wide		200,000									200,
	I	Design/ Construction	Office Expansion	WWTP office and staff workspace building			500,000								500,
		Construction	UV Bulb Replacement	WWTP UV bulb replacement			50,000	50,000	50,000			50,000	50,000	50,000	300
		Construction	RO Module Replacement	WWTP RO module replacement					300,000					300,000	600,
				Subtotal - Wastewater Treatment Plant	400,000	200,000	550,000	50,000	350,000	0	0	50,000	50,000	350,000	2,00
otal Imp	rovement Costs													1	
				Fiscal Year Total	1,250,000	5,556,700	1,697,400	4,950,000	1,250,000	1,000,000	1,000,000	1,050,000	1,350,000	1,500,000	
	E L			Cumulative Total	1,250,000	6,806,700	8,504,100	13,454,100	14,704,100	15,704,100	16,704,100	17,754,100	19,104,100	20,604,100	20,60

Notes:

1. Unless noted otherwise, budgetary planning estimate provided by City staff on June 01, 2021.

2. Existing Wastewater System capacity deficiency Capital Improvement Program.

• As Development Occurs: New infrastructure required to serve future growth is to be constructed on an as-needed basis as development occurs.

8.5 10-YEAR IMPROVEMENT PHASING

This section discusses the 10 Year Capital Improvement Program (10 Year CIP) and recommended improvement phasing. This 10-Year CIP includes capacity improvements for the existing wastewater collection system, as identified as part of the existing system capacity evaluation, as well as other improvements and planning efforts for the ongoing operations and maintenance of the collection system. The improvements included in the 10 Year CIP are summarized as follows:

- **Gravity Main Improvements:** These improvements reflect the required pipeline upgrades to mitigate existing system deficiencies.
- **Beaumont Mesa Improvements:** These improvements consist of the design and construction of a wet well expansion and new force main for the Beaumont Mesa Lift Station. This also includes new and replacement lift station pumps.
- Lift Station Condition Assessment Improvements: This reflects ongoing lift station improvements including new electrical equipment, replacement pumps, wet well repairs, component repairs, and other as-needed improvements identified by City staff.
- **Operation and Maintenance Improvements:** This reflects the acquisition of a new CCTV camera and truck as well as an allowance for as-needed pipeline replacement
- Wastewater Treatment Plant: This reflects currently planned improvements related to the wastewater treatment plant, including flow meters and system-wide improvements to identify and mitigate I/I issues and on-site improvements. This also includes a wastewater race study for FY2024-28.

The 10-Year CIP is intended to provide general guidance for implementing the capital improvement projects listed in this master plan. Additional improvements may be constructed as developments occurs and the phasing and implementation of a sequence of construction is subject to the approval of the City Engineer.



APPENDICES




APPENDIX A

Sewer Flow Monitoring and Inflow/Infiltration Study, 2020 (V&A)

City of Beaumont

Sewer Flow Monitoring and Inflow/Infiltration Study



Prepared for:

Akel Engineering Group 7433 N. First Street, Suite 103 Fresno, CA. 93720

Report Date:

August 2020

Prepared by:



V&A Project No. 19-0280

In the promotion of environmental consciousness, this document is designed to be printed double-sided, if at all. V&A strives to do all it can to be a green company. Think twice before printing. Reduce. Reuse. Recycle.

Table of Contents

Exe	ecutive S	Summar	у	1		
	Scope a	1				
	Monitoring Sites and Basins					
	Rainfal	3				
	Average	nalysis	4			
	Peak M	leasured	d Flows and Pipeline Capacity Analysis	5		
	Infiltrat	ion and	Inflow	7		
	Recom	10				
1	Introdu	ction				
	1.1	Scope	11			
	1.2	P Flow Monitoring Sites				
	1.3	Flow M	onitoring Basins			
2	Method	14				
	2.1	Confined Space Entry				
	2.2	Flow Meter Installation				
	2.3	Flow Calculation				
	2.4	Measu	rement Error and Uncertainty			
		2.4.1	Flow Addition versus Flow Subtraction			
	2.5	Averag	e Dry Weather Flow Determination			
	2.6	Flow At	20			
	2.7	Inflow ,	/ Infiltration Analysis: Definitions and Identification	21		
		2.7.1	Inflow / Infiltration Analysis: Definitions and Identification	21		
		2.7.2	Infiltration Components	22		
		2.7.3	Impact and Cost of Source Detection and Removal	22		
		2.7.4	Graphical Identification of I/I	23		
		2.7.5	Analysis Metrics	23		
		2.7.6	Normalization Methods	24		
3	Results	and An	alysis	25		
	3.1	Π	25			
		3.1.1	Regional Rainfall Event Classification	27		
		3.1.2	Rain Gauge Triangulation Distribution			

i

	3.2	Flow M	onitoring: Average Dry Weather	32			
	3.3	Flow Monitoring: Peak Measured Flows / Pipeline Capacity					
	3.4	Inflow	and Infiltration	38			
		3.4.1	Preface	38			
		3.4.2	Inflow Results Summary	40			
		3.4.3	Combined I/I Results	42			
4	Recom	mendati	ions	44			
Ap	Appendix A Flow Monitoring Sites: Data, Graphs, and InformationA - 1						

Tables

Table ES-1. List of Flow Monitoring Sites	1
Table ES-2. Dry Weather Flow	4
Table ES-3. Capacity Analysis Summary	5
Table ES-4. Inflow/Infiltration Analysis Summary	7
Table 1-1. List of Monitoring Locations	12
Table 1-2. Isolated Flow Monitoring Basins	12
Table 3-1. Summary of Rainfall	
Table 3-2. Rainfall Event Classification	
Table 3-3. Rain Gauge Distribution per Monitoring Site	
Table 3-4. Dry Weather Flow	
Table 3-5. Capacity Analysis Summary	35
Table 3-6. Results and Rankings, Inflow Analysis	40
Table 3-7. Results and Rankings, Total I/I Analysis	42

Figures

Figure ES-1. Map of Flow Monitoring Sites – Overall	2
Figure ES-2. Map of Flow Monitoring Basins	2
Figure ES-3. Rainfall Over Monitoring Period, Average of Beaumont Rain Gauges	3
Figure ES-4. March 12 Peak Storm Event Classification (per rain gauge, duration = 3-hours)	4
Figure ES-5. Peak Measured Flow (Flow Schematic)	6
Figure ES-6. Temperature Map: Inflow Final Basin Rankings	8
Figure ES-7. Temperature Map: Total I/I Final Basin Rankings	9
Figure 1-1. Map of Flow Monitoring Sites	. 13

ii

Figure 1-2. Map of Flow Monitoring Basins	13
Figure 2-1. Typical Installation for Isco 2150 Flow Meter with Submerged Sensor	15
Figure 2-2. Sample ADWF Diurnal Flow Patterns	19
Figure 2-3. Attenuation Illustration	20
Figure 2-4. Typical Sources of Infiltration and Inflow	21
Figure 2-5. Sample Infiltration and Inflow Isolation Graph	23
Figure 3-1. Map of Rain Gauge Locations	25
Figure 3-2. Rainfall during Flow Monitoring Period – Average of Beaumont Rain Gauges	26
Figure 3-3. Rainfall Accumulation Plot	26
Figure 3-4. NOAA Southern California Rainfall Frequency Map	27
Figure 3-5. Short-Term Rainfall Event Classification – Central Rain Gauge	28
Figure 3-6. Long-Term Rainfall Event Classification – Central Rain Gauge	28
Figure 3-7. March 12 Peak Storm Event Classification (per rain gauge, duration = 3-hours)	29
Figure 3-8. Rainfall Inverse Distance Weighting Method	30
Figure 3-9. Shelter-in-Place Illustration (FM-07 [Marshall Creek LS] flows shown)	32
Figure 3-10. FM-07: pre-SIP and post-SIP Average Dry Weather Flow Curves with Comparison	33
Figure 3-11. Average Dry Weather Flow Schematic	34
Figure 3-12. Peaking Factors and Max d/D Ratios	
Figure 3-13. Peak Measured Flow (Flow Schematic)	37
Figure 3-14. I/I Isolation, Site FM-03, March 12/13 Rainfall Event	38
Figure 3-15. I/I Isolation, Site FM-10, March 12/13 Rainfall Event	39
Figure 3-16. Temperature Map: Inflow Final Basin Rankings	41
Figure 3-17. Temperature Map: Combined I/I Final Basin Rankings	43

Photo Log

Photo 2-1.	Confined Space Entry	14
Photo 2-2.	Typical Personal Four-Gas Monitor	14

Abbreviations and Acronyms

Abbreviations/Acronyms	Definition
ADWF	Average Dry Weather Flow
AVG	Average
ССТV	Closed-Circuit Television
CDEC	California Data Exchange Center
CIP	Capital Improvement Plan
СО	Carbon Monoxide
CWOP	Citizen Weather Observing Program
DIA	Diameter
d/D	Depth/Diameter Ratio
FT	Feet
FM	Flow Monitor
GPD	Gallons per Day
GPM	Gallons per Minute
GWI	Groundwater Infiltration
H2S	Hydrogen Sulfide
IN	Inch
1/1	Inflow and Infiltration
IDM	Inch-Diameter Mile
IDW	Inverse Distance Weighting
LEL	Lower Explosive Limit
MAX	Maximum
MGD	Million Gallons per Day
MIN	Minimum
NOAA	National Oceanic and Atmospheric Administration
N/A	Not applicable
PF	Peaking Factor
PWS	Private Weather Station
Q	Flow Rate
RDI	Rainfall-Dependent Infiltration
RG	Rain Gauge
	V&A Consulting Engineers, Inc.
WEF	Water Environment Federation
WRCC	Western Regional Climate Center

Terms and Definitions

Term De	efinition
Average dry weather flow (ADWF)	The average flow rate or pattern from days without noticeable inflow or infiltration response. ADWF usage patterns for weekdays and weekends differ and must be computed separately. ADWF is expressed as a numeric average and may include the influence of normal groundwater infiltration (not related to a rain event).
Basin	Sanitary sewer collection system upstream of a given location (often a flow meter), including all pipelines, inlets, and appurtenances. Also refers to the ground surface area near and enclosed by pipelines. A basin may refer to the entire collection system upstream from a flow meter or exclude separately monitored basins upstream.
Depth/diameter (d/D) ratio	Depth of water in a pipe as a fraction of the pipe's diameter. A measure of the fullness of the pipe used in the capacity analysis.
Infiltration and inflow	Infiltration and inflow (I/I) rates are calculated by subtracting the ADWF flow curve from the instantaneous flow measurements taken during and after a storm event. Flow in excess of the baseline consists of inflow, rainfall-responsive infiltration, and rainfall-dependent infiltration. Total I/I is the total sum in gallons of additional flow attributable to a storm event.
Infiltration, groundwater	Groundwater infiltration (GWI) is groundwater that enters the collection system through pipe defects. GWI depends on the depth of the groundwater table above the pipelines as well as the percentage of the system that is submerged. The variation of groundwater levels and subsequent groundwater infiltration rates are seasonal by nature. On a day-to-day basis, groundwater infiltration rates are relatively steady and will not fluctuate greatly.
Infiltration, rainfall- dependent	Rainfall-dependent infiltration (RDI) is similar to groundwater infiltration but occurs as a result of storm water. The storm water percolates into the soil, submerges more of the pipe system, and enters through pipe defects. RDI is the slowest component of storm-related infiltration and inflow, beginning gradually and often lasting 24 hours or longer. The response time depends on the soil permeability and saturation levels.
Inflow	Inflow is defined as water discharged into the sewer system, including private sewer laterals, from direct connections such as downspouts, yard, and area drains, holes in manhole covers, cross-connections from storm drains, or catch basins. Inflow creates a peak flow problem in the sewer system and often dictates the required capacity of downstream pipes and transport facilities to carry these peak instantaneous flows. Overflows are often attributable to high inflow rates.
Peak Wet Weather Flow	The highest daily flow during and immediately after a significant storm event. Includes sanitary flow, infiltration, and inflow.
Peaking factor (PF)	PF is the ratio of peak measured flow to average dry weather flow. This ratio expresses the degree of fluctuation in flow rate over the monitoring period and is used in the capacity analysis.
Surcharge	When the flow level is higher than the crown of the pipe, then the pipeline is said to be in a surcharged condition. The pipeline is surcharged when the d/D ratio is greater than 1.0.

v

Executive Summary

Scope and Purpose

V&A Consulting Engineers (V&A) was retained by Akel Engineering Group (AEG) to perform sanitary sewer flow monitoring for the City of Beaumont, CA (City) in support of the City's Sewer System Master Plan. Flow monitoring was performed for approximately seven weeks from February 20 to April 8, 2020 at 14 sites, which included four open-channel gravity sewer mains and 10 pump stations. There were three general purposes for this study.

- 1. Establish the baseline sanitary sewer flows at the flow monitoring sites.
- 2. Measure the peak flow characteristics of the subject pipes during the monitoring period.
- 3. Isolate infiltration and inflow (I/I) and run analyses pertaining to I/I response levels.

Monitoring Sites and Basins

The flow monitoring site locations were selected and approved by the City and AEG and are listed in Table ES-1, and shown in Figure ES-1. The isolated basins are illustrated in Figure ES-2.

Monitoring Site	Structure ID	Monitored Pipe	Pipe Dia. (in)	Location		
FM-01	SSMH01061	North Inlet	24	Cherry Avenue north of Mary Lane		
FM-02	SSMH01725	West Inlet	30	Veile Avenue north of West 4th Street		
FM-03	SSMH00381	West Inlet	24	California Avenue north of East 1st Street		
FM-04	SSMH00450	North Inlet	57	East 6th Street east of Illinois Avenue		
FM-05	Four Seasons LS			Highland Springs, 320 feet south of Breckenridge Ave		
FM-06	Seneca Springs	s LS		Potrero Blvd and Seneca Springs Blvd		
FM-07	Marshall Creek	LS		Northwest end of Ring Ranch Road		
FM-08	Noble Creek LS	;		Northbound I-10 off-ramp to Oak Valley Parkway, 265 feet south of Oak Valley Pkwy		
FM-09	Industrial Park	LS		Off road, 540 feet south of end of Risco Circle		
FM-10	Upper Oak Valle	ey LS		Oak Valley Parkway, 0.48 miles west of Apron Lane		
FM-11	Lower Oak Valle	ey LS		Palmer Avenue, 300 feet west of Morris Street		
FM-12	Beaumont Mesa LS			Potrero Blvd, just south of Costello Way		
FM-13	Olivewood LS			Northwest end of Olivewood Gated Community, off of Costello Way		
FM-14	Fairway Canyon LS			Northwest end of Crenshaw Street		

Table ES-1. List of Flow Monitoring Sites






Figure ES-1. Map of Flow Monitoring Sites - Overall





Figure ES-2. Map of Flow Monitoring Basins

Rainfall Monitoring

There was approximately 13.18 inches of rainfall during the flow monitoring study (average of Beaumont rainfall gauges) as shown in Figure ES-3. The cumulative precipitation was approximately 2.5 times higher than historical averages over the flow monitoring period.





There were four classifiable rainfall events during the flow monitoring period:

- March 9/10, 2020: Classified as approximately a 1-year, 12-hour event at two of six rain gauges.
- March 12/13, 2020: The strongest rainfall event of the flow monitoring period, classified as between a 15-year and 35-year, 3-hour event across the region. This event elicited the strongest I/I response system-wide, and also had the highest intensity rain over the flow monitoring period. This rain event will be used for the I/I analyses.
- March 22/23, 2020: Classified as a 2-year, 3-hour event at one rain gauge.
- April 6/7/8, 2020: Classified as between a 2-year and 3-year, 12-hour event at five of six rain gauges.
- Long-Term: The 30 days between March 10 and April 9, 2020, were classified as between a 4.5year and 15-year, 30-day rain event.

The highest classification over the period and for all rain gauges was a three-hour period (from approximately 1:15 pm to 4:15pm) on March 12, 2020. Figure ES-4 illustrates this classification regionally.






Figure ES-4. March 12 Storm Event, Peak Classification (per rain gauge, duration = 3-hours)

Average Flow Analysis

Two sets of average dry weather flow (ADWF) curves were established due to the "shelter-in-place" (SIP) order for Covid-19. Table ES-2 summarizes the ADWF values per site during the flow monitoring period.

	Pre-SIP ADWF (mgd)					Post-SIP ADWF (mgd)				SIP	
Site	Mon- Thu	Fri	Sat	Sun	Overall	Mon- Thu	Fri	Sat	Sun	Overall	Delta
FM-01	0.066	0.066	0.073	0.074	0.068	0.072	0.073	0.084	0.081	0.075	10%
FM-02	0.811	0.770	0.823	0.743	0.797	0.820	0.811	0.802	0.753	0.806	1%
FM-03	1.005	0.904	0.978	1.073	0.996	1.127	1.153	1.191	1.139	1.142	15%
FM-04	0.497	0.480	0.511	0.591	0.510	0.612	0.617	0.623	0.674	0.623	22%
FM-05	0.253	0.256	0.243	0.244	0.251	0.217	0.230	0.226	0.222	0.221	-12%
FM-06	0.140	0.145	0.156	0.170	0.147	0.142	0.144	0.145	0.158	0.145	-2%
FM-07	0.414	0.418	0.425	0.438	0.419	0.426	0.423	0.435	0.433	0.428	2%
FM-08	0.241	0.241	0.237	0.247	0.241	0.237	0.239	0.245	0.246	0.240	0%
FM-09	0.056	0.052	0.032	0.028	0.048	0.063	0.072	0.026	0.015	0.052	8%
FM-10	0.707	0.686	0.712	0.756	0.712	0.827	0.856	0.842	0.871	0.840	18%
FM-11	0.381	0.361	0.393	0.439	0.388	0.441	0.444	0.459	0.441	0.444	14%
FM-12	0.745	0.734	0.735	0.778	0.747	0.853	0.907	0.906	0.893	0.874	17%
FM-13	0.022	0.022	0.022	0.024	0.022	0.025	0.026	0.026	0.028	0.026	15%
FM-14	0.060	0.062	0.062	0.067	0.062	0.064	0.064	0.065	0.064	0.064	4%

Table ES-2. Dry Weather Flow



Peak Measured Flows and Pipeline Capacity Analysis

Peak measured flows and the hydraulic grade line data (flow depths) are important to understanding the capacity limitations of a collection system. The capacity analysis terms used in the text below are defined as follows:

- Peaking Factor: Peaking factor is defined as the peak measured flow divided by the average dry weather flow (ADWF). Peaking factors are influenced by many factors, including size and topography of the tributary area, flow attenuation, flow restrictions, and characteristics of I/I entering the collection system. Municipal standards for peaking factor vary agency by agency; the City should refer to jurisdictional standards when evaluating peaking factors¹. For this study, peaking factors over 5.0 are highlighted RED.
- d/D Ratio: The d/D ratio is the peak measured depth of flow (d) divided by the pipe diameter (D). The d/D ratio for each site was computed based on the maximum depth of flow for the study. Standards for d/D ratio vary from agency to agency, but typically range between $d/D \le$ 0.5 and $d/D \le 0.75$. The City should refer to jurisdictional standards when evaluating d/Dratios. For this study, d/D ratios over 0.75 are highlighted ORANGE. Surcharged sites are highlighted **RED**.

Table ES-3 summarizes the peak recorded flows, levels, d/D ratios, and peaking factors per site during the flow monitoring period. Capacity analysis data is presented on a site-by-site basis and represents the hydraulic conditions only at the site locations; hydraulic conditions in other areas of the collection system will differ.

Monitored Site	ADWF pre-SIP ^A (mgd)	Peak Measured Flow (mgd)	Peaking Factor	Pipe Diameter, D (in)	Max Depth <i>, d</i> (in)	<i>Max</i> d/D Ratio	Surcharge above pipe crown (ft)
FM-01	0.068	0.39	5.7	8	3.3	0.42	-
FM-02	0.797	1.97	2.5	24	4.1	0.17	-
FM-03	0.996	3.21	3.2	30	18.6	0.62	-
FM-04	0.510	1.57	3.1	21	6.8	0.33	-
FM-05	0.251	0.62	2.5	n/a	n/a	n/a	n/a
FM-06	0.147	0.48	3.2	n/a	n/a	n/a	n/a
FM-07	0.419	1.40	3.3	n/a	n/a	n/a	n/a
FM-08	0.241	0.57	2.4	n/a	n/a	n/a	n/a
FM-09	0.048	0.25	5.1	n/a	n/a	n/a	n/a
FM-10	0.712	1.76	2.5	n/a	n/a	n/a	n/a
FM-11	0.388	0.87	2.2	n/a	n/a	n/a	n/a
FM-12	0.747	1.94	2.6	n/a	n/a	n/a	n/a
FM-13	0.022	0.070	3.1	n/a	n/a	n/a	n/a
FM-14	0.062	0.12	2.0	n/a	n/a	n/a	n/a

Table ES-3. Capacity Analysis Summary

^A Pre-SIP ADWF was used for this analysis.

¹ WEF Manual of Practice FD-6 and ASCE Manual No. 62 suggests typical peaking factor ratios range between 3 and 4, with higher values possibly indicative of pronounced I/I flows.

The following capacity analysis results are noted:

- Peaking Factors: Only two sites had peaking factors over 5.0.
 - Site FM-01: Site FM-01 was an open-channel flow monitoring site and was not influenced by pump station operations. Peak flows occurred during the March 12 rainfall event.
 - Site FM-09: FM-09 is the Industrial Park LS, and peak flows did not occur corresponding to I/I contribution of a large rainfall event. The higher peaking factor for this site is attributed to pump station operations and the type of service (industrial flows).
- d/D Ratio: All open-channel flow monitoring sites had d/D ratios less than 0.75 for the entirety of the flow monitoring period.

Figure ES-5 shows a schematic diagram of the peak measured flows at the flow monitoring sites, with peak flow levels shown for open-channel flow monitoring sites.




Figure ES-5. Peak Measured Flow (Flow Schematic)



Infiltration and Inflow

Flow monitoring basins are localized areas of a sanitary sewer collection system upstream of a given location (often a flow meter), including all pipelines, inlets, and appurtenances. The basin refers to the ground surface area near and enclosed by the pipelines. A basin may refer to the entire collection system upstream from a flow meter or may exclude separately monitored basins upstream. I/I analysis in this report will be conducted on a site-by-site basis. For this study subtraction of flows was required to isolate the drainage areas of some flow monitoring basins.

I/I results were taken from the March 12/13 rainfall event, the highest classified rainfall event of the season which also elicited the strongest I/I response. Table ES-4 summarizes the I/I results for this study; the top 3 and next 3 ranked basins have been shaded **RED** and **ORANGE**. Please refer to the I/I Methods section for more information on inflow and infiltration analysis methods and ranking methods.

Temperature maps for inflow and total I/I are shown in Figure ES-6 and Figure ES-7.

Basin	ADWF (mgd)	Inflow Rate (mgd)	Peak I/I per ADWF Ratio	Total I/I (gallons)	Total I/I per-ADWF (MG/adwf/ inch-rain)	Final Inflow Ranking	Final Total I/I Ranking
Basin 01	0.068	0.290	4.28	120,553	0.45	1	1
Basin 02	0.377	0.530	1.40	289,648	0.19	5	5
Basin 03	0.418	1.234	2.95	335,977	0.20	2	3
Basin 04	0.510	0.448	0.88	189,565	0.09	8	9
Basin 05	0.251	0.301	1.20	117,106	0.14	6	7
Basin 06	0.147	0.033	0.22	26,709	0.05	11	12
Basin 07	0.179	0.266	1.49	142,914	0.20	4	2
Basin 08	0.241	0.258	1.07	85,298	0.08	7	10
Basin 09	0.048	0.006	0.13	18,854	0.10	12	8
Basin 10	0.324	0.208	0.64	246,795	0.19	10	4
Basin 11	0.326	0.250	0.77	94,206	0.08	9	11
Basin 13	0.022	0.035	1.56	13,305	0.16	3	6
Basin 14	0.062	0.006	0.09	9,059	0.04	13	13

Table ES-4. Inflow/Infiltration Analysis Summary

The following I/I results are noted:

- Inflow: Basins 1, 3, and 13 had the highest normalized peak I/I rates, an indicator of high inflow within the flow monitoring basin.
- **RDI**: Throughout the region, for the rainfall events monitored, there was minimal RDI². Systemwide, flows returned to near-baseline levels within 24 hours. Given the scale of the rainfall events that occurred during this study, RDI does not appear to be an issue for the City.
- Total I/I: Basins 1, 3, and 7 had the highest normalized combined I/I rates, an indicator of high combined inflow and infiltration within the flow monitoring basin

² Basins 5 and 7 may have shown a hint of a sustained RDI component.




Figure ES-6. Temperature Map: Inflow Final Basin Rankings






Figure ES-7. Temperature Map: Total I/I Final Basin Rankings

Note: There was uncertainty as to whether using IDM and ACRE normalization methods were the most appropriate means of normalization for this study for some basins. For example, the full Basin 13 (Olivewood LS) areas and IDMs were reported, but the development is still in construction and only approximately 15% to 20% occupied. Using the reported IDM and ACRE values for Basin 13 may underrepresent the I/I within that basin. Conversely, Basin 09 (Industrial LS) has sporadic flows due to the type of service, and few pipelines shown within its service area. Using reported IDM and ACRE values may have over-represented I/I in this basin.

For the purposes of basin I/I rankings, the per-ADWF normalization method was used; however, the inflow and infiltration normalization values for the per-IDM and per-ACRE are also reported. It is noted that construction repairs and I/I reduction and mitigation methods are most typically priced on pipe length basis. The reviewing engineer may wish to review the rankings made in this report and consider the IDM metric when making CIP decisions.



Recommendations

V&A advises that future I/I reduction plans consider the following recommendations:

- 1. Master Plan and Model Implementation: This study focuses on inflow and infiltration generation; however, the capacity deficiencies of the collection system may be of greater concern relative to I/I response during peak wet weather events. The City may wish to have a model designed and/or a master plan study conducted to determine the overall needs of the City relative to I/I. Or simply, the study results can be used to update the master plan and compare with previous model assumptions and flow monitoring results.
- 2. Determine I/I Reduction Program: The City should examine its I/I reduction needs to determine their needs and goals for a future I/I reduction program.
 - a. If peak flows, sanitary sewer overflows, and pipeline capacity issues are of greater concern, then priority can be given to investigate and reduce sources of inflow within the basins with the greatest inflow problems.
 - b. If total infiltration and general pipeline deterioration are of greater concern, then the program can be weighted to investigate and reduce sources of infiltration within the basins with the greatest infiltration problems. Generally, RDI rates and hence total I/I were relatively low for this system.
 - c. Basins 1 and 3 ranked in the top 3 for both inflow and total combined I/I. An I/I reduction program could begin within these basins.
- 3. I/I Reduction Cost Effective Analysis: The City should conduct a study to determine which is more cost-effective: (1) locating the sources of inflow/infiltration and systematically rehabilitating or replacing the faulty pipelines; or (2) continued treatment of the additional rainfall dependent I/I flow.



1 Introduction

Scope and Purpose 1.1

V&A Consulting Engineers (V&A) was retained by Akel Engineering Group (AEG) to perform sanitary sewer flow monitoring for the City of Beaumont, CA (City) in support of the City's Sewer System Master Plan. Flow monitoring was performed for approximately seven weeks from February 20 to April 8, 2020 at 14 sites, which included four open-channel gravity sewer mains and 10 pump stations³. There were three general purposes for this study.

- 1. Establish the baseline sanitary sewer flows at the flow monitoring sites.
- 2. Measure the peak flow characteristics of the subject pipes during the monitoring period.
- 3. Isolate infiltration and inflow (I/I) and run analyses pertaining to I/I response levels.

1.2 Flow Monitoring Sites

Open-channel flow monitoring sites are identified from the manholes where the flow monitors were secured and the pipelines in which the flow sensors were placed. Pump station flow monitoring measured flows into the pump station wet wells. Capacity analysis and flow rate information is presented on a siteby-site basis. The flow monitoring site locations were selected and approved by the City and AEG. Information regarding the flow monitoring locations is listed in Table 1-1. Figure 1-1 illustrates the flow monitoring locations. Detailed descriptions of the individual flow monitoring sites, including photographs, are included in Appendix A.

1.3 Flow Monitoring Basins

Flow monitoring site data may include the flows of one or many drainage basins. Flow monitoring basins are localized areas of a sanitary sewer collection system upstream of a given location (often a flow meter), including all pipelines, inlets, and appurtenances. The basin refers to the ground surface area near and enclosed by the pipelines. A basin may refer to the entire collection system upstream from a flow meter or may exclude separately monitored basins upstream, requiring basin isolation (subtraction of upstream flows). One of the primary issues that arises as a result is that it is necessary to subtract flows in order to isolate basins. For more details on problems that arise from subtraction of flows, see Section 2.4 Measurement Error and Uncertainty.

Information regarding the isolated flow monitoring basins are summarized in Table 1-2 and illustrated in Figure 1-2.



³ Initially 13 sites and 9 pump stations were planned for installation; however, Olivewood LS was not accessible during installation. V&A and AEG instead installed equipment at Fairway Canyon LS ("added as Site 14"). Mid-study, and before the March 12, 2020 rain event, Olivewood was made accessible, and V&A/AEG was able to collect data from Site 13 Olivewood LS.

Monitoring Site	Structure ID	Monitored Pipe	Pipe Dia. (in)	Location		
FM-01	SSMH01061	North Inlet	24	Cherry Avenue north of Mary Lane		
FM-02	SSMH01725	West Inlet	30	Veile Avenue north of West 4th Street		
FM-03	SSMH00381	West Inlet	24	California Avenue north of East 1st Street		
FM-04	SSMH00450	North Inlet	57	East 6th Street east of Illinois Avenue		
FM-05	Four Seasons LS			Highland Springs, 320 feet south of Breckenridge Ave		
FM-06	Seneca Springs LS			Potrero Blvd and Seneca Springs Blvd		
FM-07	Marshall Creek	LS		Northwest end of Ring Ranch Road		
FM-08	Noble Creek LS	;		Northbound I-10 off-ramp to Oak Valley Parkway, 265 feet south of Oak Valley Pkwy		
FM-09	Industrial Park	LS		Off road, 540 feet south of end of Risco Circle		
FM-10	Upper Oak Valle	ey LS		Oak Valley Parkway, 0.48 miles west of Apron Lane		
FM-11	Lower Oak Valle	ey LS		Palmer Avenue, 300 feet west of Morris Street		
FM-12	Beaumont Mes	a LS		Potrero Blvd, just south of Costello Way		
FM-13	Olivewood LS			Northwest end of Olivewood Gated Community, off of Costello Way		
FM-14	Fairway Canyon LS			Northwest end of Crenshaw Street		

Table 1-1. List of Monitoring Locations

Table 1-2. Isolated Flow Monitoring Basins

Basin	Size (Acres)	Pipe Length (IDM)	Basin Flow Equation
1	459	54.4	= QFM-01
2	1148	285.2	= QFM-02 - QFM-07
3	581	165.9	= QFM-03 - QFM-01 - QFM-04
4	1230	301.9	= QFM-04
5	869	152.6	= Q _{FM-05}
6	417	88.3	= QFM-06
7	136	35.8	= QFM-07 - QFM-08
8	1212	164.6	= Q _{FM-08}
9	63	26.2	= Q _{FM-09}
10	927	164.2	= QFM-10 - QFM-11
11	644	104.3	= QFM-11 - QFM-14
12	0.8	1.3	= QFM-12 - QFM-10 - QFM-13
13	312	55.3	= QFM-13
14	108	18.8	= Q _{FM-14}




Figure 1-1. Map of Flow Monitoring Sites




Figure 1-2. Map of Flow Monitoring Basins



2 Methods and Procedures

Confined Space Entry 2.1

A confined space (Photo 2-1) is defined as any space that is large enough and so configured that a person can bodily enter and perform assigned work, has limited or restricted means for entry or exit and is not designed for continuous employee occupancy. In general, the atmosphere must be constantly monitored for sufficient levels of oxygen (19.5% to 23.5%), and the presence of hydrogen sulfide (H_2S) gas, carbon monoxide (CO) gas, and lower explosive limit (LEL) levels. A typical confined space entry crew has members with OSHA-defined responsibilities of Entrant, Attendant, and Supervisor. The Entrant is the individual performing the work. He or she is equipped with the necessary personal protective equipment needed to perform the job safely, including a personal four-gas monitor (Photo 2-2). If it is not possible to maintain line-of-sight with the Entrant, then more Entrants are required until line-of-sight can be maintained. The Attendant is responsible for maintaining contact with the Entrants to monitor the atmosphere using another four-gas monitor and maintaining records of all Entrants if there is more than one. The Supervisor is responsible for developing the safe work plan for the job at hand prior to entering.



Photo 2-1. Confined Space Entry



Photo 2-2. Typical Personal Four-Gas Monitor



2.2 Flow Meter Installation

V&A installed twenty-one (21) Isco 2150 and Hach 902 flow meters for temporary monitoring within the collection system. Both types of meters use submerged sensors with a pressure transducer to collect depth readings and an ultrasonic Doppler sensor to determine the average fluid velocity. The ultrasonic sensor emits high-frequency sound waves, which are reflected by air bubbles and suspended particles in the flow. The sensor receives the reflected signal and determines the Doppler frequency shift, which indicates the estimated average flow velocity. The sensor is typically mounted at a manhole inlet to take advantage of smoother upstream flow conditions. The sensor may be offset to one side to lessen the chances of fouling and sedimentation where these problems are expected to occur. Manual level and velocity measurements were taken during the installation of the flow meters and again when they were removed and compared to simultaneous level and velocity readings from the flow meters to ensure proper calibration and accuracy. Figure 2-1 shows a typical installation for a flow meter with a submerged sensor.




Figure 2-1. Typical Installation for Isco 2150 Flow Meter with Submerged Sensor



Flow Calculation 2.3

Data retrieved from the flow meters were placed into a spreadsheet program for analysis. Data analysis includes data comparison to field calibration measurements, as well as necessary geometric adjustments as required for sediment (sediment reduces the pipe's wetted cross-sectional area available to carry flow). Area-velocity flow metering uses the continuity equation,

$$Q = v \cdot A = v \cdot (A_T - A_S)$$

where Q: volume flow rate

v: average velocity as determined by the ultrasonic sensor

A: cross-sectional area available to carry the flow

Ar: total cross-sectional area with both wastewater and sediment

As: cross-sectional area of sediment.

For circular pipe,

$$A_{T} = \left[\frac{D^{2}}{4}\cos^{-1}\left(1 - \frac{2d_{W}}{D}\right)\right] - \left[\left(\frac{D}{2} - d_{W}\right)\left(\frac{D}{2}\right)\sin\left(\cos^{-1}\left(1 - \frac{2d_{W}}{D}\right)\right)\right]$$

$$A_{s} = \left[\frac{D^{2}}{4}\cos^{-1}\left(1 - \frac{2d_{s}}{D}\right)\right] - \left[\left(\frac{D}{2} - d_{s}\right)\left(\frac{D}{2}\right)\sin\left(\cos^{-1}\left(1 - \frac{2d_{s}}{D}\right)\right)\right]$$

where dw: distance between wastewater level and pipe invert

ds: depth of sediment

D: pipe diameter



2.4 Measurement Error and Uncertainty

For traditional engineering applications, measurement "error" is explained as a difference between a computed, estimated, or measured value and the generally accepted true or theoretically correct value. It can also be thought of as a difference between the desired and the actual performance of equipment. For equipment, error is usually expressed as a percentage relative to accuracy (i.e., "...the velocity sensor has an accuracy of $\pm 2\%$ of the reading...").

However, for this study and flow monitoring applications, the cause of the measurement difference is important and a distinction will be made between the equipment not performing to industry standards ("error") and expected inaccuracies ("uncertainty") associated with monitoring technology limitations.

Gauging "error" occurs when the equipment is not performing to industry standards. This can occur as a result of the following common categories of conditions that can be encountered at a wastewater monitoring site.

- Malfunctioning equipment (i.e. a sensor is damaged, battery life ends, or a desiccant canister becomes saturated)
- Improper equipment choice or maintenance (i.e. the selected gauging equipment technologies are incompatible with hydraulic conditions within the sewer, or excessive gravel deposits are allowed to accumulate around the sensors without being removed)
- Improper equipment calibration (i.e. depth and/or velocity measurements are incorrectly taken within the sewer, or equipment is allowed to drift out of calibration)
- Field conditions within the sewer, (i.e. foaming at the water surface that "blinds" an ultrasonic depth sensor, or toilet paper catching and accumulating on a combination sensor, blinding the acoustic Doppler velocity meter)

For flow monitoring applications, gauging "uncertainty" is used to describe and quantify the expected inaccuracies that result from the limitations of the technologies that utilize indirect measurements to quantify wastewater flow.

It is important to try and install flow meters in "ideal" flow conditions. Ideal flow conditions are generally defined by as laminar flow in a straight-through, constant-slope pipeline with no disturbances (elbows, tees, hydraulic shifts, etc.) 10 diameters upstream and 5 diameters downstream from the flow monitoring location. If ideal flow conditions are met, then an expected uncertainty of final flow calculation from an open-channel flow meter may be approximately ±5%. For many situations, ideal flow conditions cannot be met and uncertainties increase.

2.4.1 Flow Addition versus Flow Subtraction

Due to the uncertainties involved in subtracting flows of similar magnitudes, the addition of flows at multiple monitoring sites is usually preferred over subtraction of flows. Subtraction becomes an issue especially when the flow difference from the subtraction falls within the measurement uncertainty range of the two larger flow data sets (i.e. subtracting a large flow from another large flow to obtain a small difference).

This concept is best demonstrated per the following example:

1. Meter A measures 2.00 MGD of flow and has an expected uncertainty of ±5%, thus the uncertainty range of the flow measurement is ± 0.10 MGD.



- 2. Meter B measures 2.50 MGD of flow and has an expected uncertainty of ±6%, thus the uncertainty range of the flow measurement is ±0.15 MGD.
- 3. Meter C measures 0.50 MGD of flow and has an expected uncertainty of ±8%, thus the uncertainty range of the flow measurement is ±0.04 MGD.
 - Scenario 1 Flow Addition
 - Meter A + Meter B = $2.00 \text{ MGD} (\pm 0.10) + 2.50 \text{ MGD} (\pm 0.15) = 4.50 \text{ MGD} (\pm 0.25)$
 - Overall uncertainty = $\pm 0.25 / 4.50 = \pm 5.6\%$
 - For flow addition, the final uncertainty is essentially a weighted average of the component. uncertainties.
 - Scenario 2 Flow Subtraction, Large Flow less Small Flow
 - Meter B Meter C = $2.50 \text{ MGD} (\pm 0.15) 0.50 \text{ MGD} (\pm 0.04) = 2.00 \text{ MGD} (\pm 0.19)$
 - Overall uncertainty = $\pm 0.19 / 2.00 = \pm 9.5\%$
 - For flow subtraction, the final uncertainty will always be greater than the component uncertainties.
 - When subtracting a small flow from a large flow, the resulting uncertainties can still be manageable.
 - Scenario 3 – Flow Subtraction, Large Flow less a similarly Large Flow
 - Meter B - Meter A = 2.50 MGD (±0.15) - 2.00 MGD (±0.10) = 0.50 MGD (±0.25)
 - Overall uncertainty = ±0.25 / 0.50 = ±50%
 - When subtracting a similarly sized flow rates, the resulting uncertainties may not be manageable. In this example, an uncertainty of ±50% may be considered unacceptable for confident analyses.

Scenario 3 is a very "real-world" situation. The uncertainties for Meter A and Meter B are extremely reasonable (indeed, most flow monitoring service providers would be extremely pleased with true meter uncertainties of $\pm 5\%$ to $\pm 6\%$). However, the reality of the math is clear and the above example demonstrates the concept of flow subtraction and compounding or inflating uncertainty ranges.

The following points are emphasized in relation to the items of this section:

- For subtraction of flows, the overall uncertainty can be an inflated value that far exceeds the component uncertainties.
- The smaller the resultant flow from the subtraction equation, the larger the percentage uncertainty.
- Whenever possible, basins flows should be directly measured, rather than calculated as a subtraction of two or more flow meters.
- If flow subtraction cannot be avoided, it is better to have the magnitudes of the component flows be as dissimilar as possible.



2.5 Average Dry Weather Flow Determination

For this study, four distinct average dry weather flow curves were established for each site location:

- Mondays Thursdays
- Fridays
- Saturdays
- Sundays

Flows for many sites differ on Friday evenings compared to Mondays through Thursdays. Starting around 7 pm, the flows are often decreased (compared to Monday through Thursday). Similarly, flow patterns for Saturday and Sunday were also separated due to their unique evening flow pattern. This type of differentiation can be important when determining I/I response, especially if a rain event occurs on a Friday, Saturday, or Sunday evening.




Figure 2-2 illustrates a sample of varying flow patterns within a typical dry week.

Figure 2-2. Sample ADWF Diurnal Flow Patterns


ADWF curves are taken from "Dry Days" when RDI had the least impact on the baseline flow. The overall average dry weather flow (ADWF) was calculated per the following equation:

$$ADWF = \left(ADWF_{Mon-Thu} \times \frac{4}{7}\right) + \left(ADWF_{Fri} \times \frac{1}{7}\right) + \left(ADWF_{Sat} \times \frac{1}{7}\right) + \left(ADWF_{Sun} \times \frac{1}{7}\right),$$



Flow Attenuation 2.6

Flow attenuation in a sewer collection system is the natural process of the reduction of the peak flow rate through redistribution of the same volume of flow over a longer period of time. This occurs as a result of friction (resistance), internal storage and diffusion along the sewer pipes. Fluids are constantly working towards equilibrium. For example, a volume of fluid poured into a static vessel with no outside turbulence will eventually stabilize to a static state, with a smooth fluid surface without peaks and valleys. Attenuation within a sanitary sewer collection system is based upon this concept. A flow profile with a strong peak will tend to stabilize towards equilibrium, as shown in Figure 2-3.



Within a sanitary sewer collection system, each individual basin will have a specific flow profile. As the flows from the basins combine within the trunk sewer lines, the peaks from each basin will (a) not necessarily coincide at the same time, and (b) due to the length and time of travel through the trunk sewers, peak flows will attenuate prior to reaching the treatment facility. The sum of the peak flows of the individual basins within a collection system will usually be greater than the peak flows observed at the treatment facility.



2.7 Inflow / Infiltration Analysis: Definitions and Identification

Inflow and infiltration (I/I) consists of storm water and groundwater that enter the sewer system through pipe defects and improper storm drainage connections and is defined as follows:

2.7.1 Inflow / Infiltration Analysis: Definitions and Identification

- Inflow: Storm water inflow is defined as water discharged into the sewer system, including private sewer laterals, from direct connections such as downspouts, yard and area drains, holes in manhole covers, cross-connections from storm drains, or catch basins.
- Infiltration: Infiltration is defined as water entering the sanitary sewer system through defects in pipes, pipe joints, and manhole walls, which may include cracks, offset joints, root intrusion points, and broken pipes.




Figure 2-4 illustrates the possible sources and components of I/I.

Figure 2-4. Typical Sources of Infiltration and Inflow

2.7.2 Infiltration Components

Infiltration can be further subdivided into components as follows:

- Groundwater Infiltration: Groundwater infiltration depends on the depth of the groundwater table above the pipelines as well as the percentage of the system submerged. The variation of groundwater levels and subsequent groundwater infiltration rates is seasonal by nature. On a day-to-day basis, groundwater infiltration rates are relatively steady and will not fluctuate greatly.
- Rainfall-Dependent Infiltration: This component occurs as a result of storm water and enters the sewer system through pipe defects, as with groundwater infiltration. The storm water first percolates directly into the soil and then migrates to an infiltration point. Typically, the time of concentration for rainfall-related infiltration may be 24 hours or longer, but this depends on the soil permeability and saturation levels.
- **Rainfall-Responsive Infiltration** is storm water which enters the collection system indirectly through pipe defects, but normally in sewers constructed close to the ground surface such as private laterals. Rainfall-responsive infiltration is independent of the groundwater table and reaches defective sewers via the pipe trench in which the sewer is constructed, particularly if the pipe is placed in impermeable soil and bedded and backfilled with a granular material. In this case, the pipe trench serves as a conduit similar to a French drain, conveying storm drainage to defective joints and other openings in the system. This type of infiltration can have a quick response and graphically can look very similar to inflow.

2.7.3 Impact and Cost of Source Detection and Removal

Inflow:

- Impact: This component of I/I creates a peak flow problem in the sewer system and often dictates the required capacity of downstream pipes and transport facilities to carry these peak instantaneous flows. Because the response and magnitude of inflow is tied closely to the intensity of the storm event, the short-term peak instantaneous flows may result in surcharging and overflows within a collection system. Severe inflow may result in sewage dilution, resulting in upsetting the biological treatment (secondary treatment) at the treatment facility.
- Cost of Source Identification and Removal: Inflow locations are usually less difficult to find and less expensive to correct. These sources include direct and indirect cross-connections with storm drainage systems, roof downspouts, and various types of surface drains. Generally, the costs to identify and remove sources of inflow are low compared to potential benefits to public health and safety or the costs of building new facilities to convey and treat the resulting peak flows.

Infiltration:

- Impact: Infiltration typically creates long-term annual volumetric problems. The major impact is the cost of pumping and treating the additional volume of water, and of paying for treatment (for municipalities that are billed strictly on flow volume).
- Cost of Source Detection and Removal: Infiltration sources are usually harder to find and more expensive to correct than inflow sources. Infiltration sources include defects in deteriorated sewer pipes or manholes that may be widespread throughout a sanitary sewer system.



2.7.4 Graphical Identification of I/I

Inflow is usually recognized graphically by large-magnitude, short-duration spikes immediately following a rain event. Infiltration is often recognized graphically by a gradual increase in flow after a wet-weather event. The increased flow typically sustains for a period after rainfall has stopped and then gradually drops off as soils become less saturated and as groundwater levels recede to normal levels. Realtime flows were plotted against ADWF to analyze the I/I response to rainfall events. Figure 2-5 illustrates a sample of how this analysis is conducted and some of the measurements that are used to distinguish infiltration and inflow. Similar graphs were generated for the individual flow monitoring sites and can be found in Appendix A.




Figure 2-5. Sample Infiltration and Inflow Isolation Graph

2.7.5 Analysis Metrics

After differentiating I/I flows from ADWF flows, various calculations can be made to determine which I/I component (inflow or infiltration) is more prevalent at a particular site and to compare the relative magnitudes of the I/I components between drainage basins and between storm events:

- Inflow Peak I/I Flow Rate: Inflow is characterized by sharp, direct spikes occurring during a rainfall event. Peak I/I rates are used for inflow analysis. 4
- Groundwater Infiltration (GWI): GWI analysis is conducted by looking at minimum dry weather flow to average dry weather flow ratios and comparing them to established standards to quantify the rate of excess groundwater infiltration.
- Rainfall-Dependent Infiltration (RDI): RDI Analysis is conducted by looking at the infiltration rates at set periods after the conclusion of a storm event. Depending on the particular



⁴ I/I flow rate is the real time flow less the estimated average dry weather flow rate. It is an estimate of flows attributable to rainfall. By using peak measured flow rates (inclusive of ADWF), the I/I flow rate would be skewed higher or lower depending on whether the storm event I/I response occurs during low-flow or high-flow hours.

collection system and the time required for flows to return to ADWF levels, different periods may be examined to determine the basins with the greatest or most sustained rainfall-dependent infiltration rates.

Combined I/I: The combined inflow and infiltration is measured in gallons per site and per storm event. Because it is based on combined I/I volume, it is used to identify the overall volumetric influence of I/I within the monitoring basin.

2.7.6 Normalization Methods

There are three ways to normalize the I/I analysis metrics for an "apples-to-apples" comparison amongst the different drainage basins:

- per-ADWF: The metric is divided by the established average dry weather flow rate and typically expressed as a ratio. Peaking Factors are examples of using ADWF to normalize data from different sites.
- per-IDM: The metric is divided by length of pipe (IDM [inch-diameter mile]) contained within the upstream basin. Final units typically are gallons per day (gpd) per IDM.
- per-ACRE: The metric is divided by the acreage of the upstream basin. Final units typically are gallons per day (gpd) per ACRE.

The infiltration and inflow indicators were normalized by all methods in this report and these results will be shown in the following I/I analysis results sections. For the purposes of basin rankings, however, only the per-ACRE normalization method will be used. This is due to some amount of uncertainty regarding the true IDM and ACRE measurements for some basins:

- Basin 13 (Olivewood LS): The entirety of the housing division has been included for IDM and ACRE measurements; however, it appears that this development is only 15% to 20% occupied and there is still much construction occurring. The safest metric for normalization in this case is the ADWF measurement.
- Basin 09 (Industrial LS): Given the industrial nature of this location and sporadic flows, it was uncertain if the IDM and ACRE measurements were representative of this basin. The safest metric for normalization in this case is the ADWF measurement.

It is noted that construction repairs and I/I reduction and mitigation methods are most typically priced on pipe length basis. The reviewing engineer may wish to review the rankings made in this report and consider the IDM metric when making CIP decisions.



3 Results and Analysis

Rainfall 3.1

V&A captured rainfall data from publicly available private weather stations (PWS⁵), allowing for good coverage over the flow monitoring area. Rain gauge locations are shown in Figure 3-1.




Figure 3-1. Map of Rain Gauge Locations

Figure 3-2 shows the rainfall during the flow monitoring period, averaged between the six rain gauges. Table 3-1 summarizes the rainfall that fell for all rain gauges for key rainfall events and overall for the flow monitoring period. Figure 3-3 shows the rain accumulation plot versus historical average⁶ period rainfalls for these same six rain gauges; rainfall for this study was approximately 2.5 times higher than historical normal precipitation for the days of the flow monitoring period.

⁶ Historical data taken from the WRCC (Station 040409 in Beaumont): <u>http://www.wrcc.dri.edu/summary/climsmsca.html</u>



⁵ National Oceanic and Atmospheric Administration (NOAA) Citizen Weather Observer Program (CWOP) members send datat from their PWS to the NOAA MADIS server; the data undergoes quality checking and then is distributed. While V&A has no direct control over the rain gauges, V&A performs additional QA/QC on the data to ensure its suitability for use.

Dates	Avg.	Northwest	North	Northeast	Central	East	Southeast
February 22/23, 2020	0.80	0.54	0.76	0.97	0.72	0.82	1.01
March 9/10, 2020	1.49	1.75	1.92	1.10	1.36	1.47	1.36
March 12/13, 2020	3.92	3.76	4.39	3.88	4.04	4.20	3.26
March 16 - 23, 2020	2.55	2.46	3.19	2.43	2.73	2.14	2.34
April 6/7/8, 2020	4.18	3.96	4.62	3.64	4.43	4.46	3.96
Period Total:	13.18	12.71	15.15	12.30	13.53	13.34	12.06

Table 3-1. Summary of Rainfall





Figure 3-2. Rainfall during Flow Monitoring Period – Average of Beaumont Rain Gauges



3.1.1 Regional Rainfall Event Classification

It is important to classify the relative size of a major storm event that occurs over the course of a flow monitoring period⁷. Rainfall events are classified by intensity and duration. Based on historical data, frequency contour maps for storm events of given intensity and duration have been developed by the NOAA for all areas within the continental United States (Figure 3-4).




Figure 3-4. NOAA Southern California Rainfall Frequency Map

For example, the NOAA Rainfall Frequency Atlas[®] classifies a 10-year, 24-hour storm event at the 'Central' rain gauge location as 4.21 inches. This means that in any given year, at this specific location, there is a 10% chance that 4.21 inches of rain will fall in any 24-hour period.

From the NOAA frequency maps, for a specific latitude and longitude, the rainfall densities for period durations ranging from 1 hour to 60 days are known for rain events ranging from 1-year to 100-year intensities. These are plotted to develop a rain event frequency map specific to each rainfall monitoring site. Superimposing the peak measured densities for the rainfall events on the rain event frequency plot determines the classification of the rainfall event.

Figure 3-5 and Figure 3-6 illustrate the rain event classification plots at the Central Rain Gauge for both shortterm and long-term rainfall, respectively. On these plots, for example, the March 12/13 rainfall event was classified as a 25-year, 3-hour rainfall event and the 30-day period from March 10 to April 9 was classified as a 10-year, 30-day event.

⁸ NOAA Western U.S. Precipitation Frequency Maps Atlas 14, Volume 6, 2011: ftp://hdsc.nws.noaa.gov/pub/hdsc/data/sw/ca10y24h.pdf



⁷ Sanitary sewers are often designed to withstand I/I contribution to sanitary flows for specific-sized "design" storm events.

Table 3-2 summarizes the classifications for the main storm events of this study at each rain gauge location. The highest classification for all rain gauges was a three-hour period (from approximately 1:15 pm to 4:15pm) on March 12, 2020. Figure 3-7 illustrates this classification regionally.




Figure 3-5. Short-Term Rainfall Event Classification – Central Rain Gauge




Figure 3-6. Long-Term Rainfall Event Classification – Central Rain Gauge

Rain Gauge	March 9/10	March 12/13	March 22/23	April 6/7/8	March 10 – April 9, 2020
Northwest	1.1-year, 12-hr	30-year, 3-hour 3.5-year, 24-hr	< 1-year	2-year, 12-hour 1.6-year, 24-hr	8-year, 30-day
North	1-year, 12-hour	35-year, 3-hour 4-year, 24-hour	2-year, 3-hour	2.5-year, 12-hr 1.9-year, 24-hr	15-year, 30-day
Northeast	< 1-year	15-year, 3-hour 1.6-year, 24-hr	< 1-year	< 1-year	4.5-year, 30-day
Central	< 1-year	25-year, 3-hour 3-year, 24-hour	< 1-year	3-year, 12-hour 1.8-year, 24-hr	10-year, 30-day
East	< 1-year	35-year, 3-hour 3-year, 24-hour	< 1-year	2.2-year, 12-hr 1.8-year, 24-hr	8-year, 30-day
Southeast	< 1-year	25-year, 3-hour 1.8-year, 24-hr	< 1-year	2-year, 12-hour 1.1-year, 24-hr	6-year, 30-day

Table 3-2. Rainfall Event Classification




Figure 3-7. March 12 Peak Storm Event Classification (per rain gauge, duration = 3-hours)

3.1.2 Rain Gauge Triangulation Distribution

The rainfall affecting the sanitary sewer collection system basins must be calculated based on the proximity to the rain gauge locations. The mean precipitation for each site's upstream basin was calculated by taking data from the rain gauges and using the inverse distance weighting (IDW) method. IDW is an interpolation method that assumes the influence of each rain gauge location diminishes with distance. The center of an upstream basin⁹ is identified, and a weighted triangulated average is taken of the precipitation data from nearby rain gauge locations.

The IDW function is as follows:

weight(d) =
$$\frac{1/d^{p}}{\sum 1/d^{p}}$$
, where: d = distance p = power ($p > 0$)

The value of p is user defined. The most common choice for hydrological studies of watershed areas is p = 2.

Figure 3 6 illustrates the IDW method with sample data. The rain gauge distribution as calculated for each flow monitoring basin is shown in Table 3-3.




Figure 3-8. Rainfall Inverse Distance Weighting Method

⁹ Note that the full basin upstream of the site was used instead of the isolated basins as the rain data will be compared to the flow at each site



Site	Northwest	North	Northeast	Central	East	Southeast
FM-01	0%	2.1%	92.8%	0%	5.2%	0%
FM-02	1.7%	36.9%	2.6%	26.2%	31.5%	1.1%
FM-03	0%	0.4%	30.5%	13.9%	47.4%	7.8%
FM-04	0%	0%	21.8%	12.8%	56.0%	9.4%
FM-05	0%	0%	0%	0.7%	0.9%	98.4%
FM-06	0%	0%	0%	6.9%	7.5%	85.6%
FM-07	3.1%	63.9%	2.2%	23.7%	7.1%	0%
FM-08	3.5%	71.0%	2.4%	15.2%	7.9%	0%
FM-09	12.6%	0%	0%	75.0%	0%	12.4%
FM-10	83.8%	12.1%	0%	4.1%	0%	0%
FM-11	100.0%	0%	0%	0.0%	0%	0%
FM-12	82.3%	10.2%	0%	7.6%	0%	0%
FM-13	74.0%	0%	0%	26.0%	0%	0%
FM-14	100.0%	0%	0%	0%	0%	0%

Table 3-3. Rain Gauge Distribution per Monitoring Site



Flow Monitoring: Average Dry Weather 3.2

For this study, two sets of average dry weather flow (ADWF) curves were established due to the advent of "shelter-in-place" (SIP) order for Covid-19. There were generally three time-periods during this study, as detailed below and shown in Figure 3-9.




Figure 3-9. Shelter-in-Place Illustration (FM-07 [Marshall Creek LS] flows shown)

- 1. Pre-SIP: Sets of ADWF curves were established during "typical" dry days prior to SIP and can be used for modelling purposes.
- 2. Transition period: On March 13, schools were closed statewide. Although "Shelter-in-Place" was officially announced on March 20, 2020, it is clear from the flow monitoring data that people were already transitioning (in terms of sewage) towards SIP behavior starting from March 13. Saturday, March 14, was already a transition day, and by Sunday, March 15, people were mostly in SIP mode.

The true predicted ADWF curves during the transition period would be speculative at best. When looking at the transition period, the safer analyses would be to review I/I response during the earlymorning hours when human behavior is more predictable. However, even during this period, we are observing more flows from midnight to 3 am hours, presumably people shifting schedules and working late.

- The main large rainfall event (March 12) occurred prior to the transition period when ADWF curves were still generally stable. I/I analyses for three different rain events were analyzed and shown in the Appendix; however, the March 12 I/I analyses was used for the ranking metrics later in this report.
- 3. Post-SIP: Second sets of ADWF curves were established during "typical" dry days post-SIP and were used for I/I analysis that occurred during the transition period and during the post-SIP period (April 6/7/8).



There were clear differences in ADWF patterns and volumes before and after the 'shelter-in-place' order. Daily peaks are delayed by 1-2 hours and without the sharp early-morning peak.

Figure 3-10 shows the sets of pre-SIP ADWF, post-SIP curves for Site FM-07, and a direct comparison of the pre- and post-SIP curves for weekday diurnal patterns. Table 3-4 summarizes the dry weather flow data measured for this study. Figure 3-11 illustrates a flow schematic of the ADWF values (pre-SIP) for the flow monitoring sites of this study. ADWF curves for each site pre- and post-SIP can be found in Appendix A.





Figure 3-10. FM-07: pre-SIP and post-SIP Average Dry Weather Flow Curves with Comparison



	Pre-SIP ADWF (mgd)			Post-SIP ADWF (mgd)				SIP			
Site	Mon- Thu	Fri	Sat	Sun	Overall	Mon- Thu	Fri	Sat	Sun	Overall	Delta
FM-01	0.066	0.066	0.073	0.074	0.068	0.072	0.073	0.084	0.081	0.075	10%
FM-02	0.811	0.770	0.823	0.743	0.797	0.820	0.811	0.802	0.753	0.806	1%
FM-03	1.005	0.904	0.978	1.073	0.996	1.127	1.153	1.191	1.139	1.142	15%
FM-04	0.497	0.480	0.511	0.591	0.510	0.612	0.617	0.623	0.674	0.623	22%
FM-05	0.253	0.256	0.243	0.244	0.251	0.217	0.230	0.226	0.222	0.221	-12%
FM-06	0.140	0.145	0.156	0.170	0.147	0.142	0.144	0.145	0.158	0.145	-2%
FM-07	0.414	0.418	0.425	0.438	0.419	0.426	0.423	0.435	0.433	0.428	2%
FM-08	0.241	0.241	0.237	0.247	0.241	0.237	0.239	0.245	0.246	0.240	0%
FM-09	0.056	0.052	0.032	0.028	0.048	0.063	0.072	0.026	0.015	0.052	8%
FM-10	0.707	0.686	0.712	0.756	0.712	0.827	0.856	0.842	0.871	0.840	18%
FM-11	0.381	0.361	0.393	0.439	0.388	0.441	0.444	0.459	0.441	0.444	14%
FM-12	0.745	0.734	0.735	0.778	0.747	0.853	0.907	0.906	0.893	0.874	17%
FM-13	0.022	0.022	0.022	0.024	0.022	0.025	0.026	0.026	0.028	0.026	15%
FM-14	0.060	0.062	0.062	0.067	0.062	0.064	0.064	0.065	0.064	0.064	4%

Table 3-4. Dry Weather Flow







Flow Monitoring: Peak Measured Flows / Pipeline Capacity 3.3

Peak measured flows and the hydraulic grade line data (flow depths) are important to understanding the capacity limitations. The capacity analysis terms used in the text below are defined as follows:

- Peaking Factor: Peaking factor is defined as the peak measured flow divided by the average dry weather flow (ADWF). Peaking factors are influenced by many factors, including size and topography of the tributary area, flow attenuation, flow restrictions, and characteristics of I/I entering the collection system. Municipal standards for peaking factor vary agency by agency; the City should refer to jurisdictional standards when evaluating peaking factors¹⁰. For this study, peaking factors over 5.0 are highlighted RED.
- d/D Ratio: The d/D ratio is the peak measured depth of flow (d) divided by the pipe diameter (D). The d/D ratio for each site was computed based on the maximum depth of flow for the study. Standards for d/D ratio vary from agency to agency, but typically range between $d/D \le$ 0.5 and $d/D \le 0.75$. The City should refer to jurisdictional standards when evaluating d/Dratios. For this study, d/D ratios over 0.75 are highlighted ORANGE. Surcharged sites are highlighted RED.

Table 3-5 summarizes the peak flows, levels, d/D ratios, and peaking factors during the flow monitoring period. Capacity analysis data are presented on a site-by-site basis and represents the hydraulic conditions only at the site nodes; hydraulic conditions in other areas of the collection system will differ.

Monitored Site	ADWF pre-SIP ^a (mgd)	Peak Measured Flow (mgd)	Peaking Factor	Pipe Diameter, D (in)	Max Depth, <i>d</i> (in)	Max d/D Ratio	Surcharge above pipe crown (ft)
FM-01	0.068	0.39	5.7	8	3.3	0.42	-
FM-02	0.797	1.97	2.5	24	4.1	0.17	-
FM-03	0.996	3.21	3.2	30	18.6	0.62	-
FM-04	0.510	1.57	3.1	21	6.8	0.33	-
FM-05	0.251	0.62	2.5	n/a	n/a	n/a	n/a
FM-06	0.147	0.48	3.2	n/a	n/a	n/a	n/a
FM-07	0.419	1.40	3.3	n/a	n/a	n/a	n/a
FM-08	0.241	0.57	2.4	n/a	n/a	n/a	n/a
FM-09	0.048	0.25	5.1	n/a	n/a	n/a	n/a
FM-10	0.712	1.76	2.5	n/a	n/a	n/a	n/a
FM-11	0.388	0.87	2.2	n/a	n/a	n/a	n/a
FM-12	0.747	1.94	2.6	n/a	n/a	n/a	n/a
FM-13	0.022	0.070	3.1	n/a	n/a	n/a	n/a
FM-14	0.062	0.12	2.0	n/a	n/a	n/a	n/a

Table 3-5. Capacity Analysis Summary

^A Pre-SIP ADWF was used for this analysis.

¹⁰ WEF Manual of Practice FD-6 and ASCE Manual No. 62 suggests typical peaking factor ratios range between 3 and 4, with higher values possibly indicative of pronounced I/I flows.



The following capacity analysis results are noted:

- Peaking Factors: Only two sites had peaking factors over 5.0.
 - Site FM-01: Site FM-01 was an open-channel flow monitoring site and was not influenced by pump station operations. Peak flows occurred during the March 12 rainfall event.
 - Site FM-09: FM-09 is the Industrial Park LS, and peak flows did not occur corresponding to I/I contribution of a large rainfall event. The higher peaking factor for this site is attributed to pump station operations and the type of service (industrial flows).
- d/D Ratio: All open-channel flow monitoring sites had d/D ratios less than 0.75 for the entirety of the flow monitoring period.

Figure 3-12 shows bar graph summaries of the peaking factors and d/D ratios. Figure 3-13 shows the schematic diagram of the peak measured flows of the whole monitoring period, with peak flow levels shown for open-channel flow monitoring sites.




Figure 3-12. Peaking Factors and Max d/D Ratios






Figure 3-13. Peak Measured Flow (Flow Schematic)

3.4 Inflow and Infiltration

3.4.1 Preface

I/I analyses are presented on a basin-by-basin basis. Items relevant to the analysis in this study are noted below and referenced in Figure 3-14:

- Basin 12: FM-12 (Beaumont Mesa LS) schematically operates as the sum of flow from FM-10 and FM-13; the isolated "Basin 12" does not have a substantial collection area and is not analyzable due to flow subtraction (see Section 2.4). Basin 12 will not be evaluated.
- Pump Stations and Peak Flows: There are several pump stations within the collection system. Basins downstream from ON/OFF (constant speed) pump stations are subject to attenuation (Section 2.6) and forced peak flows. Peak flows can be dampened due to being throttled while held in wet wells. Conversely, peak flows out of a pump station are typically higher than flows into a pump station and are strictly based on the pumping rates (not influent rates) from the pump station. Peak flows downstream from pump stations should be evaluated appropriately.
- I/I Isolation: The I/I flow rate is the real-time flow less the estimated average dry weather flow rate (shown below as the RED line).
- Inflow: Inflow is usually recognized graphically by large-magnitude, short-duration spikes immediately following a rain event. The peak inflow rate is the highest spike in the isolated I/I hydrograph immediately following the evaluated rainfall event.
- RDI: RDI is typically taken as the average I/I flow rate measured approximately 24 to 36 hours after the rainfall event has concluded. Throughout the region, for the rainfall events monitored, there was minimal RDI; systemwide, flows returned to near-baseline levels within 24 hours. Basins 5 and 7 may have shown a hint of a sustained RDI component; however, n RDI analysis will not be made for this study. Given the scale of the rainfall events that occurred during this study, RDI does not appear to be an issue for the City.
- Combined I/I: the totalized volume (in gallons) of both inflow and RDI over the course of a rainfall event (shown below as the orange area).




Figure 3-14. I/I Isolation, Site FM-03, March 12/13 Rainfall Event

Inflow above Noise: For sites with clean and repeatable daily flow measurements, the peak I/I calculation is clear and straight-forward measurement (refer to FM-03 in Figure 3-14). However, for some sites the daily flows are more atypical and sporadic. This could be due to pump station operations (common in this study), or due to atypical usage (for example, FM-09, industrial usage). This can result in daily instantaneous spikes above the smoothed average dry weather flow curves. These spikes could be misinterpreted as inflow during a rainfall event, even if inflow is not prevalent. To account for this, the measured inflow can be evaluated against the typical daily spikes or 'noise' on a site-by-site basis.

For example, for FM-10, a large component of the flows into the pump station are connected directly from upstream flow meter FM-11, the Lower Oak Valley Lift Station force main. The resulting spikes are obvious and occur daily; the exact timing is random and cannot be predicted (refer to Figure 3-15). During the March 12 storm event, there is also a clear inflow response. To best comparatively measure this inflow versus other flow monitoring sites, the inflow above expected noise is measured to prevent an exaggerated and misinterpreted inflow measurement.




Figure 3-15. I/I Isolation, Site FM-10, March 12/13 Rainfall Event



3.4.2 Inflow Results Summary

Inflow is storm water discharged into the sewer system through direct connections such as downspouts, area drains, cross-connections to catch basins, etc. These sources transport rain water directly into the sewer system and the corresponding flow rates are tied closely to the intensity of the storm. This component of I/I often causes a peak flow problem in the sewer system and often dictates the required capacity of downstream pipes and transport facilities to carry these peak instantaneous flows.

Inflow results were taken from the March 12/13 rainfall event and considered potential noise due to spikes from pump stations or service type. Table 3-6 summarizes the peak measured inflow and inflow analysis results for the relevant flow monitoring basins; the "top 3" ranked basins have been shaded RED; basins ranked 4-6 have been shaded ORANGE. Figure 3-16 shows a temperature map summary of the inflow analysis results per basin. The following inflow results are noted:

Basins 1, 3, and 13 had the highest normalized peak I/I rates, an indicator of high inflow within the flow monitoring basin.

Basin	ADWF (mgd)	Inflow Rate (mgd)	Peak I/I per IDM (gpd/IDM)	Peak I/I per ACRE (gpd/ACRE)	Peak I/I per ADWF Ratio	Final Inflow Ranking
Basin 01	0.068	0.290	5,337	632	4.28	1
Basin 02	0.377	0.530	1,858	462	1.40	5
Basin 03	0.418	1.234	7,440	2,124	2.95	2
Basin 04	0.510	0.448	1,485	365	0.88	8
Basin 05	0.251	0.301	1,973	347	1.20	6
Basin 06	0.147	0.033	369	78	0.22	11
Basin 07	0.179	0.266	7,418	1,955	1.49	4
Basin 08	0.241	0.258	1,569	213	1.07	7
Basin 09	0.048	0.006	234	97	0.13	12
Basin 10	0.324	0.208	1,268	225	0.64	10
Basin 11	0.326	0.250	2,396	388	0.77	9
Basin 13	0.022	0.035	628	111	1.56	3
Basin 14	0.062	0.006	305	53	0.09	13

Table 3-6. Results and Rankings, Inflow Analysis






Figure 3-16. Temperature Map: Inflow Final Basin Rankings



3.4.3 Combined I/I Results

Combined I/I analysis considers the totalized volume (in gallons) of both inflow and rainfall-dependent infiltration over the course of a storm event. Table 3-7 summarizes the combined I/I flow results from the March 12/13 rain event. The "top 3" ranked basins have been shaded RED; basins ranked 4-6 have been shaded **ORANGE**. A temperature map is shown in Figure 3-17.

The following total I/I results are noted:

Basins 1, 3, and 7 had the highest normalized combined I/I rates, an indicator of high combined inflow and infiltration within the flow monitoring basin.

Basin	Total I/I (gallons)	Total I/I per-IDM (gal/IDM/ inch-rain)	Total I/I per-ACRE (R-Value)	Total I/I per-ADWF (MG/adwf/ inch-rain)	Final Total I/I Ranking
Basin 01	120,553	566	0.25%	0.45	1
Basin 02	289,648	144	0.10%	0.19	5
Basin 03	335,977	158	0.13%	0.20	3
Basin 04	189,565	156	0.14%	0.09	9
Basin 05	117,106	234	0.15%	0.14	7
Basin 06	26,709	89	0.07%	0.05	12
Basin 07	142,914	177	0.10%	0.20	2
Basin 08	85,298	121	0.06%	0.08	10
Basin 09	18,854	184	0.28%	0.10	8
Basin 10	246,795	219	0.14%	0.19	4
Basin 11	94,206	203	0.12%	0.08	11
Basin 13	13,305	63	0.04%	0.16	6
Basin 14	9,059	128	0.08%	0.04	13

Table 3-7. Results and Rankings, Total I/I Analysis






Figure 3-17. Temperature Map: Combined I/I Final Basin Rankings



4 Recommendations

V&A advises that future I/I reduction plans consider the following recommendations:

- 1. **Master Plan and Model Implementation**: This study focuses on inflow and infiltration generation; however, the capacity deficiencies of the collection system may be of greater concern relative to I/I response during peak wet weather events. The City may wish to have a model designed and/or a master plan study conducted to determine the overall needs of the City relative to I/I. Or simply, the study results can be used to update the master plan and compare with previous model assumptions and flow monitoring results.
- 2. Determine I/I Reduction Program: The City should examine its I/I reduction needs to determine their needs and goals for a future I/I reduction program.
 - a. If peak flows, sanitary sewer overflows, and pipeline capacity issues are of greater concern, then priority can be given to investigate and reduce sources of inflow within the basins with the greatest inflow problems.
 - b. If total infiltration and general pipeline deterioration are of greater concern, then the program can be weighted to investigate and reduce sources of infiltration within the basins with the greatest infiltration problems. Generally, RDI rates were very low for this system.
 - c. Basins 1 and 3 ranked in the top 3 for both inflow and total combined I/I. An I/I reduction program could begin within these basins.
- 3. I/I Reduction Cost Effective Analysis: The City should conduct a study to determine which is more cost-effective: (1) locating the sources of inflow/infiltration and systematically rehabilitating or replacing the faulty pipelines; or (2) continued treatment of the additional rainfall dependent I/I flow.



Appendix A Flow Monitoring Sites: Data, Graphs, and Information



City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-01

City Structure: SSMH01061

Location: Cherry Avenue north of Mary Lane

Data Summary Report



Vicinity Map: FM-01

FM-01

Site Information

Location:	Cherry Avenue north of Mary Lane
City Manhole:	SSMH01061
Coordinates:	116.9642°W, 33.9574°N
Rim Elevation (Earth):	2750 feet
Pipe Diameter:	8 inches
ADWF:	0.072 mgd
Peak Measured Flow:	0.388 mgd






Sanitary Map



Street View

Satellite Map



Flow Sketch



Plan View

A&**V**

FM-01

Additional Site Photos

Effluent Pipe




Monitored Influent Pipe



FM-01 Period Flow Summary: Daily Flow Totals


Avg Period Flow: 0.084 MGal Peak Daily Flow: 0.138 MGal Min Daily Flow: 0.064 MGal

Total Period Rainfall: 12.42 inches




V&A | FM-01-4

FM-01 Flow Summary: 2/21/2020 to 3/15/2020




FM-01 Flow Summary: 3/16/2020 to 4/8/2020




Avg Flow: 0.085 mgd Peak Flow: 0.338 mgd Min Flow: 0.016 mgd

> **X**&**A** | FM-01-6


FM-01 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-01 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)




FM-01 Site Capacity and Surcharge Summary




Realtime Flow Levels with Rainfall Data over Monitoring Period

FM-01 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 3.91 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.39 <i>mgd</i> 5.41	Peak I/I Rate: Total I/I:	0.33 mgd 121,000 gallons
Peak Level: d/D Ratio:	3.33 in 0.42		

FM-01 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 1.01 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.23 mgd 3.24	Peak I/I Rate: Total I/I:	0.13 mgd 30,000 gallons
Peak Level: d/D Ratio:	2.79 in 0.35		

FM-01 I/I Summary: Event 3




Event 3 Detail Graph 0.400 0.0 0.350 0.2 0.300 0.4 0.250 **Rain (in/hr)** 9.0 0.6 Flow (mgd) 0.200 0.150 0.100 1.2 0.050 1.4 0.000 1.6 04/06 04/08 04/09 04/07 04/05

Storm Event I/I Analysis (Rain = 3.70 inches)


Capacity		Inflow / Infiltration	
Peak Flow: PF:	0.34 mgd 4.71	Peak I/I Rate: Total I/I:	0.23 mgd 103,000 gallons
Peak Level: d/D Ratio:	3.32 in 0.42		

Baseline and Realtime Flows with Rainfall Data over Monitoring Period


FM-01 Weekly Level, Velocity and Flow Hydrographs 2/17/2020 to 2/24/2020



FM-01 Weekly Level, Velocity and Flow Hydrographs 2/24/2020 to 3/2/2020




FM-01 Weekly Level, Velocity and Flow Hydrographs 3/2/2020 to 3/9/2020




V&A | FM-01-15


FM-01 Weekly Level, Velocity and Flow Hydrographs 3/9/2020 to 3/16/2020



FM-01 Weekly Level, Velocity and Flow Hydrographs 3/16/2020 to 3/23/2020




FM-01 Weekly Level, Velocity and Flow Hydrographs 3/23/2020 to 3/30/2020




V&A | FM-01-18

FM-01 Weekly Level, Velocity and Flow Hydrographs 3/30/2020 to 4/6/2020



FM-01 Weekly Level, Velocity and Flow Hydrographs 4/6/2020 to 4/13/2020



V&A | FM-01-20

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-02

City Structure: SSMH01725

Location: Veile Avenue north of West 4th Street

Data Summary Report




Vicinity Map: FM-02

FM-02

Site Information

Location:	Veile Avenue north of West 4th Street
City Manhole:	SSMH01725
Coordinates:	116.9882°W, 33.9281°N
Rim Elevation (Earth):	2554 feet
Pipe Diameter:	24 inches
ADWF:	0.802 mgd






FM-02

Sanitary Map



Street View

Satellite Map



Flow Sketch



Plan View

FM-02

Additional Site Photos



Monitored Influent Pipe




A&**V**


FM-02 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.832 MGal Peak Daily Flow: 1.013 MGal Min Daily Flow: 0.735 MGal


Total Period Rainfall: 14.00 inches




FM-02 Flow Summary: 2/21/2020 to 3/15/2020




FM-02 Flow Summary: 3/16/2020 to 4/8/2020




FM-02 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-02 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)




FM-02 Site Capacity and Surcharge Summary




Realtime Flow Levels with Rainfall Data over Monitoring Period

FM-02 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.20 inches)


Capacity		Inflow / Infiltration	
Peak Flow: PF:	1.97 <i>mgd</i> 2.45	Peak I/I Rate: Total I/I:	1.14 mgd 518,000 gallons
Peak Level: d/D Ratio:	4.05 in 0.17		

FM-02 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 1.11 inches)


Capacity		Inflow / Infiltration	
Peak Flow: PF:	1.33 mgd 1.66	Peak I/I Rate: Total I/I:	0.38 mgd 77,000 gallons
Peak Level: d/D Ratio:	3.30 <i>in</i> 0.14		

FM-02 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period







Storm Event I/I Analysis (Rain = 4.47 inches)

Capacity		Inflow / Infiltration	
Peak Flow: PF:	1.74 mgd 2.18	Peak I/I Rate: Total I/I:	0.63 mgd 542,000 gallons
Peak Level: d/D Ratio:	3.80 in 0.16		

FM-02 Weekly Level, Velocity and Flow Hydrographs 2/17/2020 to 2/24/2020




FM-02 Weekly Level, Velocity and Flow Hydrographs 2/24/2020 to 3/2/2020




V&A | FM-02 - 14

FM-02 Weekly Level, Velocity and Flow Hydrographs 3/2/2020 to 3/9/2020




V&A | FM-02 - 15


FM-02 Weekly Level, Velocity and Flow Hydrographs 3/9/2020 to 3/16/2020



FM-02 Weekly Level, Velocity and Flow Hydrographs 3/16/2020 to 3/23/2020




FM-02 Weekly Level, Velocity and Flow Hydrographs 3/23/2020 to 3/30/2020




V&A | FM-02 - 18

FM-02 Weekly Level, Velocity and Flow Hydrographs 3/30/2020 to 4/6/2020



V&A | FM-02 - 19

FM-02 Weekly Level, Velocity and Flow Hydrographs 4/6/2020 to 4/13/2020



City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-03

City Structure: SSMH00381

Location: California Avenue north of East 1st Street

Data Summary Report




Vicinity Map: FM-03

Site Information

Location:	California Avenue north of East 1st Street
City Manhole:	SSMH00381
Coordinates:	116.9813° W, 33.9228° N
Rim Elevation (Earth):	2576 feet
Pipe Diameter:	31 inches
ADWF:	1.074 mgd
Peak Measured Flow:	3.207 mgd






Sanitary Map




Street View

Satellite Map



Flow Sketch



Plan View

Additional Site Photos

Effluent Pipe



Monitored Influent Pipe



Additional Site Photos


Lateral Pipe




FM-03 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 1.134 MGal Peak Daily Flow: 1.582 MGal Min Daily Flow: 0.888 MGal

Total Period Rainfall: 12.96 inches




FM-03 Flow Summary: 2/21/2020 to 3/15/2020



Total Period Rainfall: 6.37 inches Avg Flow: 1.033 mgd Peak Flow: 3.207 mgd Min Flow: 0.095 mgd

V&A | FM-03 - 6


FM-03 Flow Summary: 3/16/2020 to 4/8/2020




Total Period Rainfall: 6.59 inches Avg Flow: 1.236 mgd Peak Flow: 2.973 mgd Min Flow: 0.141 mgd

TV&A | FM-03 - 7


FM-03 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-03 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)




FM-03 Site Capacity and Surcharge Summary




Realtime Flow Levels with Rainfall Data over Monitoring Period

FM-03 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.01 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow:	3.21 mgd	Peak I/I Rate:	2.13	mgd
PF:	2.99	Total I/I:	646,000	gallons
Peak Level:	18.56 in			
d/D Ratio:	0.60			

FM-03 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period







Storm Event I/I Analysis (Rain = 0.82 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow:	2.26 mgd	Peak I/I Rate:	0.52 mgd
PF:	2.11	Total I/I:	112,000 gallons
Peak Level:	16.04 in		
d/D Ratio:	0.52		

FM-03 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period







1.31 mgd


519,000 gallons


Inflow / Infiltration Peak I/I Rate:


Total I/I:

Capacity		
Peak Flow: PF:	2.97 mgd 2.77	
Pr. Peak Level:		
d/D Ratio:	0.58	


FM-03 Weekly Level, Velocity and Flow Hydrographs 2/17/2020 to 2/24/2020










V&A | FM-03 - 15







V&A | FM-03 - 16







TV&A | FM-03 - 17







V&A | FM-03 - 18







V&A | FM-03 - 19





TV&A | FM-03 - 20





V&A | FM-03-21

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-04

City Structure: SSMH00450

Location: East 6th Street east of Illinois Avenue

Data Summary Report



Vicinity Map: FM-04

Site Information

Location:	East 6th Street east of Illinois Avenue
City Manhole:	SSMH00450
Coordinates:	116.9631° W, 33.9293° N
Rim Elevation (Earth):	2612 feet
Pipe Diameter:	21 inches
ADWF:	0.570 mgd
Peak Measured Flow:	1.572 mgd




TO Feet

Sanitary Map



Street View

Satellite Map



Flow Sketch



Plan View

Additional Site Photos



Monitored Influent Pipe



| FM-04 - 3

Additional Site Photos


Lateral Pipe




FM-04 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.600 MGal Peak Daily Flow: 0.715 MGal Min Daily Flow: 0.466 MGal

Total Period Rainfall: 13.02 inches




Flow Summary: 2/21/2020 to 3/15/2020




Total Period Rainfall: 6.41 inches Avg Flow: 0.548 mgd Peak Flow: 1.572 mgd Min Flow: 0.021 mgd

FM-04 Flow Summary: 3/16/2020 to 4/8/2020




Total Period Rainfall: 6.61 inches Avg Flow: 0.651 mgd Peak Flow: 1.452 mgd Min Flow: 0.061 mgd


FM-04 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-04 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)




FM-04 Site Capacity and Surcharge Summary




Realtime Flow Levels with Rainfall Data over Monitoring Period

FM-04 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.02 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow: PF:	1.16 <i>mgd</i> 2.03	Peak I/I Rate: Total I/I:	0.67 190,000	0
Peak Level: d/D Ratio:	6.10 in 0.29			

FM-04 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 0.77 inches)


Capacity		<u>Inflow / Infiltration</u>	
Peak Flow: PF:	1.08 <i>mgd</i> 1.90	Peak I/I Rate: Total I/I:	0.25 mgd 49,000 gallons
Peak Level: d/D Ratio:	6.02 in 0.29		

FM-04 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period







Storm Event I/I Analysis (Rain = 4.23 inches)

Capacity		Inflow / Infiltration	
Peak Flow: PF:	1.45 mgd 2.55	Peak I/I Rate: Total I/I:	0.48 mgd 185,000 gallons
Peak Level: d/D Ratio:	6.73 in 0.32		


FM-04 Weekly Level, Velocity and Flow Hydrographs 2/17/2020 to 2/24/2020




FM-04 Weekly Level, Velocity and Flow Hydrographs 2/24/2020 to 3/2/2020




Weekly Level, Velocity and Flow Hydrographs 3/2/2020 to 3/9/2020




FM-04 Weekly Level, Velocity and Flow Hydrographs 3/9/2020 to 3/16/2020




Weekly Level, Velocity and Flow Hydrographs 3/16/2020 to 3/23/2020





Weekly Level, Velocity and Flow Hydrographs 3/23/2020 to 3/30/2020



FM-04 Weekly Level, Velocity and Flow Hydrographs 3/30/2020 to 4/6/2020







City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-05

City Structure: Four Seasons LS

Location: Highland Springs, 320 feet south of Breckenridge Ave

Data Summary Report



Vicinity Map: FM-05

Site Information

City Structure: Four Seasons LS Coordinates: 116.9468° W, 33.9064° N Rim Elev: 2480 feet

Location: Highland Springs, 320 feet south of Breckenridge Ave

ADWF: 0.235 mgd Peak Measured Flow: 0.615 mgd



Satellite Map



Sanitary Map




Street View


FM-05 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.244 MGal Peak Daily Flow: 0.287 MGal Min Daily Flow: 0.217 MGal


Total Period Rainfall: 12.09 inches



FM-05 Flow Summary: 2/21/2020 to 3/15/2020




FM-05 Flow Summary: 3/16/2020 to 4/8/2020




TV&A | FM-05 - 5


FM-05 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-05 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-05 I/I Summary: Event 1




Event 1 Detail Graph 0.70 0.0 0.2 0.60 0.4 0.50 **Rain (in/hr)** 9.0 0.6 Flow (mgd) 0.40 0.30 0.20 1.2 0.10 M 1.4 0.00 1.6 03/12 03/13 03/15 03/16 03/14 03/11

Storm Event I/I Analysis (Rain = 3.28 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.62 mgd 2.62	Peak I/I Rate: Total I/I:	0.32 mgd 117,000 gallons
Peak Level:	in		

d/D Ratio:

FM-05 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period






<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.43 mgd 1.82	Peak I/I Rate: Total I/I:	0.09 mgd 32,000 gallons
Peak Level: d/D Ratio:	in		

FM-05 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 3.98 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.40 <i>mgd</i> 1.69	Peak I/I Rate: Total I/I:	0.11 mgd 60,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-06

City Structure: Seneca Springs LS

Location: Potrero Blvd and Seneca Springs Blvd

Data Summary Report



Vicinity Map: FM-06

Site Information

City Structure: Seneca Springs LS Coordinates: 116.9619° W, 33.9185° N Rim Elev: 2564 feet


Location: Potrero Blvd and Seneca Springs Blvd

ADWF: 0.146 mgd

Peak Measured Flow: 0.477 mgd



Satellite Map



Sanitary Map




Street View


FM-06 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.150 MGal Peak Daily Flow: 0.190 MGal Min Daily Flow: 0.124 MGal

Total Period Rainfall: 12.26 inches




FM-06 Flow Summary: 2/21/2020 to 3/15/2020



Total Period Rainfall: 5.86 inches Avg Flow: 0.150 mgd Peak Flow: 0.403 mgd Min Flow: 0.040 mgd

V&A | FM-06 - 4


FM-06 Flow Summary: 3/16/2020 to 4/8/2020




Avg Flow: 0.150 mgd Peak Flow: 0.477 mgd Min Flow: 0.018 mgd **Total Period Rainfall: 6.40 inches**

^{0.10} 1.8 0.00 2.0 Mar 28 Mar 29 Mar 30 Mar 31 Apr 01 Apr 02 Apr 03 Apr 04 Apr 05 Apr 06 Apr 07 Apr 08 (Sat) (Sun) (Wed) (Thu) (Fri) (Sat) (Sun) (Wed) (Mon) (Tue) (Mon) (Tue)


FM-06 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-06 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-06 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 3.39 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.26 <i>mgd</i> 1.80	Peak I/I Rate: Total I/I:	0.15 mgd 27,000 gallons
Peak Level: d/D Ratio:	in		21,000 guilons

FM-06 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 0.83 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.18 mgd 1.22	Peak I/I Rate: Total I/I:	0.05 mgd 6,000 gallons
Peak Level: d/D Ratio:	in		

FM-06 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.04 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.48 mgd 3.27	Peak I/I Rate: Total I/I:	0.32 mgd 98,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-07

City Structure: Marshall Creek LS

Location: Northwest end of Ring Ranch Road

Data Summary Report



Vicinity Map: FM-07

FM-07

Site Information

City Structure: Marshall Creek LS Coordinates: 116.9984° W, 33.9405° N Rim Elev: 2499 feet


Location: Northwest end of Ring Ranch Road

ADWF: 0.424 mgd

Peak Measured Flow: 1.400 mgd



Satellite Map



Sanitary Map




Street View


FM-07 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.438 MGal Peak Daily Flow: 0.549 MGal Min Daily Flow: 0.396 MGal

Total Period Rainfall: 14.49 inches




FM-07 Flow Summary: 2/21/2020 to 3/15/2020




Total Period Rainfall: 6.92 inches Avg Flow: 0.439 mgd Peak Flow: 1.400 mgd Min Flow: 0.070 mgd

V&A | FM-07 - 4


FM-07 Flow Summary: 3/16/2020 to 4/8/2020




FM-07 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-07 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-07 I/I Summary: Event 1



Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 4.26 inches)

<u>Capacity</u>		<u>Inflow / Infiltration</u>	
Peak Flow: PF:	1.08 <i>mgd</i> 2.55	Peak I/I Rate: Total I/I:	0.67 mgd 228,000 gallons
Peak Level:	in		


d/D Ratio:

FM-07 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 1.35 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.90 mgd 2.12	Peak I/I Rate: Total I/I:	0.28 mgd 36,000 gallons
Peak Level: d/D Ratio:	in		

FM-07 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 4.52 inches)

<u>Capacity</u>		Inflow / Infiltration	L
Peak Flow: PF:	0.80 <i>mgd</i> 1.89	Peak I/I Rate: Total I/I:	0.26 mgd 224,000 gallons
Peak Level: d/D Ratio:	in		


City of Beaumont

Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-08

- City Structure: Noble Creek LS
- Location: Northbound I-10 off-ramp to Oak Valley Parkway, 265 feet south of Oak Valley Pkwy

Data Summary Report



Vicinity Map: FM-08

FM-08


Site Information

City Structure: Noble Creek LS Coordinates: 117.0013° W, 33.9449° N Rim Elev: 2485 feet


Location: Northbound I-10 off-ramp to Oak Valley Parkway, 265 feet south of Oak Valley Pkwy

ADWF: 0.240 mgd

Peak Measured Flow: 0.568 mgd



Satellite Map



Sanitary Map




Street View

FM-08 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.246 MGal Peak Daily Flow: 0.301 MGal Min Daily Flow: 0.232 MGal

Total Period Rainfall: 14.60 inches



FM-08 Flow Summary: 2/21/2020 to 3/15/2020

0.10

0.00

Mar 04

(Wed)

Mar 05


(Thu)

Mar 06

(Fri)

Mar 07

(Sat)



Total Period Rainfall: 6.98 inches Avg Flow: 0.249 mgd Peak Flow: 0.568 mgd Min Flow: 0.057 mgd

Mar 08


(Sun)

1.8

2.0

Mar 09 Mar 10 Mar 11 Mar 12 Mar 13 Mar 14 Mar 15 (Mon) (Tue) (Wed) (Thu) (Fri) (Sat) (Sun)


FM-08 Flow Summary: 3/16/2020 to 4/8/2020




Avg Flow: 0.243 mgd Peak Flow: 0.437 mgd Min Flow: 0.059 mgd

> **X**&**A** | FM-08 - 5


FM-08 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-08 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-08 I/I Summary: Event 1



Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 4.29 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.57 <i>mgd</i> 2.36	Peak I/I Rate: Total I/I:	0.32 mgd 85,000 gallons
Peak Level:	in		

d/D Ratio:

FM-08 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 1.37 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.41 mgd 1.71	Peak I/I Rate: Total I/I:	0.10 mgd 14,000 gallons
Peak Level: d/D Ratio:	in		

FM-08 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 4.53 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.40 <i>mgd</i> 1.67	Peak I/I Rate: Total I/I:	0.10 mgd 73,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-09

City Structure: Industrial Park LS

Location: Off road, 540 feet south of end of Risco Circle

Data Summary Report



Vicinity Map: FM-09

FM-09

Site Information

City Structure: Industrial Park LS Coordinates: 116.9948° W, 33.9239° N Rim Elev: 2522 feet


Location: Off road, 540 feet south of end of Risco Circle

ADWF: 0.050 mgd

Peak Measured Flow: 0.246 mgd



Satellite Map



Sanitary Map




Street View


FM-09 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.050 MGal Peak Daily Flow: 0.082 MGal Min Daily Flow: 0.010 MGal

Total Period Rainfall: 13.25 inches



FM-09 Flow Summary: 2/21/2020 to 3/15/2020



V&A | FM-09 - 4

FM-09 Flow Summary: 3/16/2020 to 4/8/2020

(Sat)


(Sun)

(Tue)

(Mon)

(Wed)

(Thu)



(Fri)

(Sat)

(Sun)


(Mon)

(Tue)


TV&A | FM-09-5

(Wed)


FM-09 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-09 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-09 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 3.91 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.24 mgd 4.76	Peak I/I Rate: Total I/I:	0.13 mgd 26,000 gallons
Peak Level: d/D Ratio:	in		

FM-09 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period







Storm Event I/I Analysis (Rain = 1.13 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.14 mgd 2.73	Peak I/I Rate: Total I/I:	0.06 mgd 4,000 gallons
Peak Level: d/D Ratio:	in		

FM-09 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.31 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.24 mgd 4.89	Peak I/I Rate: Total I/I:	0.18 mgd 51,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-10

City Structure: Upper Oak Valley LS

Location: Oak Valley Parkway, 0.48 miles west of Apron Lane

Data Summary Report



Vicinity Map: FM-10

FM-10

Site Information

City Structure: Upper Oak Valley LS Coordinates: 117.0347° W, 33.9434° N Rim Elev: 2301 feet

Location: Oak Valley Parkway, 0.48 miles west of Apron Lane

ADWF: 0.780 mgd Peak Measured Flow: 1.757 mgd



Satellite Map



Sanitary Map




Street View

FM-10 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.794 MGal Peak Daily Flow: 0.936 MGal Min Daily Flow: 0.615 MGal

Total Period Rainfall: 13.05 inches



FM-10 Flow Summary: 2/21/2020 to 3/15/2020

0.00

Mar 04

(Wed)

Mar 05

(Thu)

Mar 06

(Fri)

Mar 07


(Sat)

Mar 08

(Sun)

Mar 09

(Mon)



Mar 10

(Tue)

Mar 11

(Wed)

Mar 12

(Thu)

Mar 13

(Fri)

Mar 14

(Sat)

Total Period Rainfall: 6.34 inches Avg Flow: 0.748 mgd Peak Flow: 1.757 mgd Min Flow: 0.116 mgd

V&A | FM-10 - 4

Mar 15

(Sun)

2.0


FM-10 Flow Summary: 3/16/2020 to 4/8/2020

(Sat)

(Sun)

(Mon)

(Tue)



(Fri)

(Sat)

(Sun)

(Mon)

Total Period Rainfall: 6.71 inchesAvg Flow: 0.838 mgdPeak Flow: 1.643 mgdMin Flow: 0.121 mgd

(Wed)


(Thu)

V&A | FM-10-5


(Wed)

(Tue)


FM-10 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



FM-10 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-10 I/I Summary: Event 1




Event 1 Detail Graph 2.00 0.0 1.80 0.2 1.60 0.4 1.40 0.6 **Rain (in/hr)** 9.0 Flow (mgd) 1.20 1.00 0.80 0.60 1.2 0.40 1.4 0.20 0.00 1.6 03/12 03/13 03/14 03/15 03/16 03/11

Storm Event I/I Analysis (Rain = 3.85 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.61 mgd 2.06	Peak I/I Rate: Total I/I:	0.97 mgd 350,000 gallons
Peak Level: d/D Ratio:	in		


Baseline and Realtime Flows with Rainfall Data over Monitoring Period

FM-10 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 1.22 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.45 mgd 1.86	Peak I/I Rate: Total I/I:	0.80 mgd 111,000 gallons
Peak Level: d/D Ratio:	in		

FM-10 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 4.06 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.60 <i>mgd</i> 2.04	Peak I/I Rate: Total I/I:	0.88 mgd 69,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-11

City Structure: Lower Oak Valley LS

Location: Palmer Avenue, 300 feet west of Morris Street

Data Summary Report



Vicinity Map: FM-11

FM-11

Site Information

City Structure: Lower Oak Valley LS Coordinates: 117.0616° W, 33.9595° N Rim Elev: 2157 feet


Location: Palmer Avenue, 300 feet west of Morris Street

ADWF: 0.417 mgd

Peak Measured Flow: 0.866 mgd



Satellite Map



Sanitary Map




Street View


FM-11 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.423 MGal Peak Daily Flow: 0.503 MGal Min Daily Flow: 0.345 MGal

Total Period Rainfall: 12.73 inches




FM-11 Flow Summary: 2/21/2020 to 3/15/2020



Total Period Rainfall: 6.21 inches Avg Flow: 0.388 mgd Peak Flow: 0.851 mgd Min Flow: 0.081 mgd

V&A | FM-11 - 4


FM-11 Flow Summary: 3/16/2020 to 4/8/2020




Total Period Rainfall: 6.51 inches Avg Flow: 0.456 mgd Peak Flow: 0.866 mgd Min Flow: 0.044 mgd

V&A | FM-11-5


FM-11 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-11 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-11 I/I Summary: Event 1



Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 3.77 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.67 <i>mgd</i> 1.60	Peak I/I Rate: Total I/I:	0.33 mgd 103,000 gallons
Peak Level:	in		


d/D Ratio:

FM-11 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 1.18 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.72 mgd 1.72	Peak I/I Rate: Total I/I:	0.20 mgd 23,000 gallons
Peak Level: d/D Ratio:	in		

FM-11 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 3.96 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.83 <i>mgd</i> 1.99	Peak I/I Rate: Total I/I:	0.33 mgd 149,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-12

City Structure: Beaumont Mesa LS

Location: Potrero Blvd, just south of Costello Way

Data Summary Report



Vicinity Map: FM-12

FM-12

Site Information

City Structure: Beaumont Mesa LS Coordinates: 117.0160° W, 33.9404° N Rim Elev: 2425 feet

Location: Potrero Blvd, just south of Costello Way

ADWF: 0.816 mgd

Peak Measured Flow: 1.943 mgd



Satellite Map



Sanitary Map




Street View

FM-12 Period Flow Summary: Daily Flow Totals


Avg Period Flow: 0.834 MGal Peak Daily Flow: 0.945 MGal Min Daily Flow: 0.641 MGal


Total Period Rainfall: 13.03 inches




FM-12


Flow Summary: 2/21/2020 to 3/15/2020








FM-12 Flow Summary: 3/16/2020 to 4/8/2020




Total Period Rainfall: 6.71 inches Avg Flow: 0.881 mgd Peak Flow: 1.885 mgd Min Flow: 0.131 mgd

V&A | FM-12-5


FM-12 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-12 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-12 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 3.85 inches)


<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.43 mgd 1.75	Peak I/I Rate: Total I/I:	0.69 mgd 367,000 gallons
Peak Level:	in		

FM-12 I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period









<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.16 mgd 1.42	Peak I/I Rate: Total I/I:	0.60 mgd 52,000 gallons
Peak Level: d/D Ratio:	in		

FM-12 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 4.06 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	1.51 mgd 1.85	Peak I/I Rate: Total I/I:	0.57 mgd 86,000 gallons
Peak Level: d/D Ratio:	in		

City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-13

City Structure: Olivewood LS

Location: Northwest end of Olivewood Gated Community, off of Costello Way

Data Summary Report



Vicinity Map: FM-13

FM-13

Site Information

City Structure: Olivewood LS Coordinates: 117.0321° W, 33.9404° N Rim Elev: 2319 feet


Location: Northwest end of Olivewood Gated Community, off of Costello Way

ADWF: 0.015 mgd

Peak Measured Flow: 0.070 mgd



Satellite Map



Sanitary Map




Street View


FM-13 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.027 MGal Peak Daily Flow: 0.037 MGal Min Daily Flow: 0.023 MGal


Total Period Rainfall: 10.42 inches



FM-13 Flow Summary: 2/21/2020 to 3/15/2020




FM-13 Flow Summary: 3/16/2020 to 4/8/2020




Total Period Rainfall: 6.69 inches Avg Flow: 0.026 mgd Peak Flow: 0.070 mgd Min Flow: 0.002 mgd

V&A | FM-13 - 5


FM-13 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-13 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-13 I/I Summary: Event 1



Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 3.84 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow: PF:	0.06 <i>mgd</i> 2.43	Peak I/I Rate: Total I/I:	0.04 mgd 13,000 gallons	
Peak Level:	in			

d/D Ratio:

FM-13 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 1.18 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow: PF:	0.06 mgd 2.43	Peak I/I Rate: Total I/I:	0.02 mgd 8,000 gallons	
Peak Level: d/D Ratio:	in			

FM-13 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 4.08 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.07 <i>mgd</i> 2.91	Peak I/I Rate: Total I/I:	0.03 mgd 15,000 gallons
Peak Level: d/D Ratio:	in		



City of Beaumont


Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: FM-14

City Structure: Fairway Canyon LS

Location: Northwest end of Crenshaw Street

Data Summary Report



Vicinity Map: FM-14

FM-14

Site Information

City Structure: Fairway Canyon LS Coordinates: 117.0707° W, 33.9642° N Rim Elev: 2095 feet


Location: Northwest end of Crenshaw Street

ADWF: 0.063 mgd

Peak Measured Flow: 0.123 mgd



Satellite Map



Sanitary Map




Street View


FM-14 Period Flow Summary: Daily Flow Totals

Avg Period Flow: 0.064 MGal Peak Daily Flow: 0.076 MGal Min Daily Flow: 0.048 MGal

Total Period Rainfall: 12.73 inches




FM-14 Flow Summary: 2/21/2020 to 3/15/2020




Total Period Rainfall: 6.21 inches Avg Flow: 0.064 mgd Peak Flow: 0.123 mgd Min Flow: 0.012 mgd

V&A | FM-14 - 4


FM-14 Flow Summary: 3/16/2020 to 4/8/2020




FM-14 Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)




FM-14 Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)



FM-14 I/I Summary: Event 1




Baseline and Realtime Flows with Rainfall Data over Monitoring Period




Storm Event I/I Analysis (Rain = 3.77 inches)

<u>Capacity</u>		Inflow / Infiltration		
Peak Flow:	0.10 mgd	Peak I/I Rate:	0.03 mgd	
PF:	1.62	Total I/I:	9,000 gallons	
Peak Level: d/D Ratio:	in			

FM-14 I/I Summary: Event 2




Baseline and Realtime Flows with Rainfall Data over Monitoring Period



Storm Event I/I Analysis (Rain = 1.18 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow: PF:	0.09 <i>mgd</i> 1.42	Peak I/I Rate: Total I/I:	0.01 mgd 1,000 gallons	
Peak Level: d/D Ratio:	in			

FM-14 I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 3.96 inches)

<u>Capacity</u>		Inflow / Infiltration	
Peak Flow: PF:	0.11 mgd 1.68	Peak I/I Rate: Total I/I:	0.02 mgd 28,000 gallons
Peak Level: d/D Ratio:	in		


City of Beaumont

Sanitary Sewer Flow Monitoring February 20 - April 09, 2020

Monitoring Site: WWTP

Location: Wastewater Treatment Plant

Data Summary Report




Vicinity Map: WWTP

WWTP Period Flow Summary: Daily Flow Totals

Avg Period Flow: 3.696 MGal Peak Daily Flow: 4.570 MGal Min Daily Flow: 0.000 MGal


Total Period Rainfall: 13.17 inches



V&A | WWTP-2

WWTP

Flow Summary: 2/21/2020 to 3/15/2020




Total Period Rainfall: 6.38 inches Avg Flow: 3.439 mgd Peak Flow: 9.173 mgd Min Flow: 0.000 mgd


V&A | WWTP-3

WWTP


Flow Summary: 3/16/2020 to 4/8/2020




WWTP Average Dry Weather Flow Hydrographs - Pre Shelter-In-Place (< 03/14/20)



WWTP Average Dry Weather Flow Hydrographs - Shelter In Place (> 3/16/20)




WWTP I/I Summary: Event 1



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 3.92 inches)

Capacity		Inflow / Infiltration		
Peak Flow: PF:	9.17 mgd 2.39	Peak I/I Rate: Total I/I:	5.47 mgd 1,385,000 gallons	
Peak Level:	in			


d/D Ratio:

WWTP I/I Summary: Event 2



Baseline and Realtime Flows with Rainfall Data over Monitoring Period






Storm Event I/I Analysis (Rain = 1.01 inches)


<u>Capacity</u>		Inflow / Infiltration		
Peak Flow: PF:	5.63 mgd 1.47	Peak I/I Rate: Total I/I:	0.97 mgd 258,000 gallons	
Peak Level: d/D Ratio:	in			

WWTP I/I Summary: Event 3



Baseline and Realtime Flows with Rainfall Data over Monitoring Period





Storm Event I/I Analysis (Rain = 4.21 inches)


<u>Capacity</u>		<u>Inflow / Infiltrations (Marchaeler (March</u>	Inflow / Infiltration		
Peak Flow: PF:	6.79 mgd 1.77	Peak I/I Rate: Total I/I:	1.66 mgd 1,396,000 gallons		
Peak Level:	in				


d/D Ratio:





APPENDIX B


Hydraulic Model Calibration Exhibits












































APPENDIX C

Beaumont Mesa Lift Station Dry Well Grading Plan – Prepared by Cannon



					Tax,	
					Permit,	
				Engineering	Fees	Contingency
n	Concrete	Equipment	Subtotal	15%	10%	25%
	\$596,246	\$60,000	\$768,136	\$115,220.41	\$76,814	\$192,034
	\$639,857	\$60,000	\$816,895	\$122,534.18	\$81,689	\$204,224
	\$666,403	\$60,000	\$846,541	\$126,981.21	\$84,654	\$211,635
	\$697,144	\$60,000	\$880,846	\$132,126.90	\$88,085	\$220,212
		L=128.50 L.F. S=0.0040		LIGHT	30" INV. IN '5"	0,-0
			30 "- SWR			15" INV 2415.50
67	£5 22.00 45122	D.66%MIN	GRAVEL		30" INV. OUT	0.6
63	279.427			N 228667	2414.00 L=33.75 L.F.	
	E 6329	HOSE VALVE		$\bigvee \qquad \qquad$	1.3487 6" PVC-V	
	<u> </u>	& RACK (TYP)	{, [188 L.F., S=0.0026 INV. IN 2419.50	
			2423.0		FS 2422.75	
	16"-DI 14"Ø - FM DI-FM INV.				 ● 30" INV 2413.50 	
-	2413.79				L=13.25 S=0.008	
					● 15'-0"	
	12"-DI FM INV. 10"ø			DRY PIT	• 72"ø MH	
	2413.80 DI-FM				=0.0036 INV. IN 2	22.75, 9.18'D
					IV. 2419.50 INV. OUT	2413.61
P(T)	UARD C OST S-7 YP.	8 M-1)			°9 	
(1	2 PLCS)					

			Total								Volume	
1. P. 1			Depth of							Volume	of T&B	
	Available		Wet Well	Freeboard	Percentage	Inside	Inside	т&в	Wall	of Walls	Slab 12-	Total
	height	Freeboard	Inside	Volume	of Total	Width	Length	Area	Length	12-inch	inch	Concrete
	(ft)	(ft)	(ft)	(gal.)	Storage	(ft)	(ft)	(sq. ft)	(ft)	(cu.yds)	(cu.yds)	(cu. Yds)
	8	1	9	12,188	16.3%	40.36	40.36	1795	161.45	53.82	132.93	186.75
	7	2	9	27,857	37.1%	43.15	43.15	2038	172.60	57.53	151.00	208.53
	6.5	2.5	9	37,500	50.0%	44.78	44.78	2188	179.11	59.70	162.09	221.79
	6	3	9	48,750	65.0%	46.61	46.61	2363	186.43	62.14	175.01	237.15

UN tS 200) 676-2054	CITY OF BEAUMONT BEAUMONT MESA SEWER LIFT STATION SAN TIMOTEO SEWER SYSTEM PRECISE GRADING AND SITE PIPING PLAN	SHEET NO. 6 C-2 OF <u>36</u> SHTS.
	FOR W.O.	1540-D



APPENDIX D

Beaumont Mesa Force Main Pothole Report – Prepared by C-Below

Utility Locating Radiography Potholing Mapping GPR



Date: Technician: Project Name: Project Address: C Below Project No. October 3, 2020 Jacob Bankston City of Beaumont/Force main Pothole Report Potrero Blvd & Western Knolls Ave. Beaumont, CA 92223 20-2491

www.cbelow.com

1-888-90-BELOW

14280 Euclid Ave. Chino, CA 91710



Date:October 3, 2020Technician:Jacob BankstonProject Name:City of Beaumont/Force main Pothole ReportProject Address:Potrero Blvd & Western Knolls Ave. Beaumont, CA 92223C Below Project No.20-2491

Project Summary

No.	Utility	Size (in)	Material	Top Depth (ft)	Direction	Location	Surface
ST1	Sewer	12	Plastic	7.28	NE-SW	West Bound on Western Knolls Ave., South West of Property 1280	Soil
ST2	Sewer	12	Plastic	6.03	E-W	West of 630 Nicholas Rd. in Field	Soil
ST2.1	Sewer	16	Plastic	5.70	E-W	West of 630 Nicholas Rd. in Field	Soil

Comments: Top depth is measured from ground surface to top of utility. Potholes were performed at locations specified by the client. Utility size and material are based on visual estimates and may vary.






POTHOLING DATA SHEET

14280 EUCLID AVE., CHINO, CA 91710 OFFICE: (888) 902-3569 FAX: (909) 606-6555

Technician Name	1			Date			C Below Project No.
Jacob Bankstor	า			10-03-2020			20-2491
Project Name					Project Add	ress	
City of Beaum	ont Force n	nain Utility	Locating Inves	tigation	Potrero Bl	lvd & V	Nestern Knolls Avenue Beaumont, CA 92223
Client Company					Contact		
Cannon Corp.	Los Angele	S			Eric		
Pothole No.		Locatio					
ST1		West I	Bound on West	tern Knolls Ave., So	uth West o	of Prope	erty 1280
Surface Type:	Soil		Prof	ile View (not to scale	e)		
	3011		Measured	Distance from Finisł	ned Surface	e	
Thickness:	N/A	(feet)				Notes	
						Notes).
Г						Appro	oximate coordiates: 33.933883°N 117.007647°W
Top:	7.28	(feet)					ft. east of the Force main vault lid.
l							
Bottom:	8.28	(feet)					
	0.20	()		ĺ			
e . [(im)					
Size:	12	(in)					
ſ							
Utility:	Sewer						
- , [n N			
Material:				. //			
Material.	Plastic						
- Г		_					
Direction:	NE-SW						
L	-						



No.	Utility	Size (in)	Material	Top Depth (ft)	Direction	Direction Location	
ST1	Sewer	12	Plastic	7.28	NE-SW	West Bound on Western Knolls Ave., South West of Property 1280	Soil



Photo 1

Photo 2





Comments:





POTHOLING DATA SHEET

14280 EUCLID AVE., CHINO, CA 91710 OFFICE: (888) 902-3569 FAX: (909) 606-6555

Technician Name	е			Date		C Below Project No.
Jacob Banksto	n			10-03-2020		20-2491
Project Name					Project Address	
City of Beaum	iont Force n	nain			Potrero Blvd &	Western Knolls Avenue Beaumont, CA 92223
Client Company					Contact	
Cannon Corp.	Los Angele	S			Eric	
Pothole No.		Location				
ST2		West o	f 630 Nicholas	Rd. in Field		
Surface Type:	Soil		Prof	ile View (not to scale	e)	
Surface Type.	3011			Distance from Finish		
Thickness:	N/A	(feet)			Nata	
	,			I	Note	es.
					Appr	roximate Coordinates 33.9300501, -116.9950839
Top:	6.03	(feet)				· · · · · · · · · · · · · · · · · · ·
Bottom:		(feet)				
Dottom.	7.03	(ieer)				
Size:	12	(in)				
Utility:	Couror		 '/			
Othity.	Sewer			′ ¦ ∖)∎		
]]		
Material:	Plastic			//		
	L					
Direction:	E-W					
Direction.	E-VV					

	PHYSICAL SWING TIE INFORMATION													
No.	Distance (ft)	Dir.	From Permanent Existing Fixture	No.	Distance (ft)	Dir.	From Permanent Existing Fixture] [No.	Distance (ft)	Dir.	From Permanent Existing Fixture		
1	8.10	Е	Force Main Breather tube	2	58.10	Ν	Fence		3	N/A	N/A	N/A		
					LC	CAT	ION DETAIL							

No.	Utility	Size (in)	Material	Top Depth (ft)	Direction	Direction Location	
ST2	Sewer	12	Plastic	6.03	E-W	West of 630 Nicholas Rd. in Field	Soil



Photo 1

Photo 2



Photo 3

Photo 4

Comments:





POTHOLING DATA SHEET

14280 EUCLID AVE., CHINO, CA 91710 OFFICE: (888) 902-3569 FAX: (909) 606-6555

Technician Name	e			Date		C Below Project No.
Jacob Banksto	on			10-03-2020		20-2491
Project Name					Project Address	
City of Beaum	nont Force r	nain			Potrero Blvd &	Western Knolls Avenue Beaumont, CA 92223
Client Company					Contact	
Cannon Corp.	Los Angele	S			Eric	
Pothole No.		Location				
ST2.1		West c	of 630 Nicholas	Rd. in Field		
Surface Type:	Soil		Prof	ile View (not to scale	e)	
Surface Type.	3011			Distance from Finish		
Thickness:	N/A	(feet)			Nista	
	•			I	Note	es.
					Appr	roximate Coordinates 33.9300501, -116.9950839
Top:	5.70	(feet)				· · · · · · · · · · · · · · · · · · ·
Bottom:		(feet)				
Dottom.	7.00	(ieer)				
Size:	16	(in)				
Utility:	Courtor		 '/			
Othity.	Sewer			′ ¦ ∖)∎		
]]		
Material:	Plastic			//		
	L					
Direction:	E-W					
Direction.	E-VV					

	PHYSICAL SWING TIE INFORMATION													
No.	Distance (ft)	Dir.	From Permanent Existing Fixture	No.	Distance (ft)	Dir.	From Permanent Existing Fixture] [No.	Distance (ft)	Dir.	From Permanent Existing Fixture		
1	8.00	Е	Force Main Breather tube	2	55.40	Ν	Fence] [3	N/A	N/A	N/A		
					LC	CAT	ION DETAIL							
LE														

No.	Utility	Size (in)	Material	Top Depth (ft)	Direction	Location	Surface
ST2.1	Sewer	16	Plastic	5.70	E-W	West of 630 Nicholas Rd. in Field	Soil



Photo 1

Photo 2



Photo 3

Photo 4

Comments:





APPENDIX E

Fairway Canyon Preliminary Design Report (PDR) Review Memorandum



April 15, 2021

City of Beaumont 550 E. 6th Street Beaumont, CA 92223

Attention: Sue Foxworth Solid Waste & Recycling Manager

Subject: Fairway Canyon Preliminary Design Report (PDR) Review Memorandum

Dear Sue:

We are pleased to submit this letter memorandum for the Fairway Canyon Preliminary Design Report Review. This letter memorandum includes the following sections:

- Study Area
- Flow Comparison
- Capacity Evaluation Review
- Conclusion

The purpose of this Technical Memorandum is to document the review of the Fairway Canyon Preliminary Design Report (PDR) as prepared by Proactive Engineering Consultants West, Inc. The PDR documents development dwelling units, estimation of future average, peak and design flows, design pumping capacity, force main size, and pump selection.

The City requested that Akel Engineering Group review the PDR for consistency with criteria documented in the City's in-progress 2021 Wastewater Master Plan. The remaining sections of the Technical Memorandum document the results of this review.

1.0 STUDY AREA

The Fairway Canyon development is a four-phase residential development in the northwest portion of the City of Beaumont (City), as shown on **Figure 1**. Three of the four planned phases have been completed; the final phase (Phase 4) is currently in the planning process. Phase 4 consists of 1,312 total dwelling units spread over approximately 310 acres. In addition to summarizing the layout of the final phase residential dwelling units, the PDR estimates average and peak design sewer flows that are used to estimate required lift station capacity and force main sizes.

It should be noted that the 2021 WMP evaluated the buildout of the City's general plan and included additional residential development east of San Timoteo Canyon Road between Hogan Drive and the northern boundary of the currently planned Phase 4 Fairway Canyon development. The flows from this additional residential development were also assumed tributary to the currently planned Fairway Canyon lift station. Should these future residential lands develop it is recommended City staff reevaluate the capacity of the planned Fairway Canyon lift station.

2.0 FLOW COMPARISON

The PDR estimated the average sewer flows using per capita sewer flow generation rates based on Eastern Municipal Water District (EMWD) standards. The in-progress City of 2021 Wastewater Master Plan (WMP) prepared an estimate of average sewer flows for the study area that is based on EMWD unit flow factors applied to overall site acreage. A comparison of the flow factors, peaking factors, and estimated flows is shown on Table 1 and summarized below.

2.1 **PDR Flow Estimation**

The PDR estimated average flows on a dwelling unit basis and used peaking factor and additional safety factors based on EMWD standards. The estimated average, peak, and design flows are summarized below.

• Average Flows: According to the PDR, EMWD planning standards specify an average household occupancy of 3.5 persons per dwelling unit and an average per capita sewer flow generation rate of 100 gallons per day. The PDR combines these two factors for a per DU sewer flow generation rate of 350 gpd/DU.

Based on the total of 1,312 total dwelling units and an average sewer flow generation rate of 350 gpd/DU, the total average sewer flow for Phase 4 of the Fairway Canyon Development is 319 gpm.

- **Peak Flows:** Assuming a peaking factor of 2.02, based on EMWD standards, the estimated peak flow from the future development is 644 gpm.
- **Design Flows:** Based on an additional factor of safety 20 percent the design flow is 773 gpm.

2.2 In-Progress 2021 WMP

The in-progress 2021 WMP estimates average flows on a per acres basis and uses daily peaking factors based on historical flow data and hourly peaking factors based on flow monitoring data. The estimated average and peak flows using this methodology are summarized on the following page.

- Average Flows: Based on a total site acreage of 307 acres, and using the WMP Single Family Residential flow factor of 1,396 gpd/acre consistent with EMWD planning standards, the total average sewer flow for planned development is 298 gpm.
- **Peak flows:** Using a peak day peaking factor of 1.33, based on historical flow records, and an hourly peaking factor of 1.54 based on flow monitoring data, the estimated development peak flow is 610 gpm.

The PDR flow estimation methodology results in a more conservative design flow and is an acceptable basis for sewer system planning.

3.0 CAPACITY EVALUATION REVIEW

The PDR documented required lift station pump and force main sizes based on the estimated design flow. The locations of the planned lift station and force mains are summarized on Figure 2. The following sections document the capacity evaluation for the planned lift stations and force mains and review for consistency with the in-progress 2021 WMP criteria.

3.1 Lift Station Capacity

The plans for Phase 4 of the Fairway Canyon development include a temporary lift station to collect and convey flows as the first part of the development phase is completed, with a final lift station planned as the remainder of the Phase 4 units are constructed. The PDR documented the capacity estimation for the permanent lift station, which is reflected in this review.

Based on an estimated design flow of 773 gpm the PDR specifies the future lift station to include two pumps at 803 gpm each. This results in a firm and total lift station design capacity of 803 gpm and 1,606 gpm, respectively, which meets the 2021 WMP criteria.

3.2 Force Main Capacity

The PDR includes two parallel 8-inch force mains, each approximately 6,200 feet in length, to convey flows from the planned permanent lift station to the City's existing gravity system. According to EMWD lift station design standards force main lengths in excess of 6,000 feet require two parallel force mains for reliability purposes. For the purpose of this capacity review, it was assumed that only one force main will be active at any time.

Based on planned lift station pump flow of 803 gpm and assuming a single 8-inch force main in service the maximum force main velocity is approximately 4.9 feet per second (ft/s) (Table 1), which meets the 2021 WMP criteria.

4.0 SUMMARY

Phase 4 of the Fairway Canyon development includes more than 1,300 residential dwelling units distributed over more than 300 acres. The Preliminary Design Report prepared by Proactive

Engineering Consultants West, Inc documents the planned development information, estimates average and peak design flows, and includes recommendations for future lift station pump and force main facilities.


The findings of this review indicate that the flow estimation methodology results in a slightly more conservative design flow than what is reflected in the 2021 WMP for the same area. Based on this flow, the recommended lift station pump and force mains are within the criteria set forth in the 2021 WMP.

We are extending our thanks to you and other City of Beaumont Staff whose courtesy and cooperation were valuable components in completing this study and producing this report.

Sincerely,

AKEL ENGINEERING GROUP, INC.

Tony Akel, P.E. Principal






Table 1 Development Summary and Capacity Evaluation

Fairway Canyon Preliminary Design Report Review City of Beaumont

PRELIMINARY			
Development and Flow Summary Summary			
Development Information ¹			
Land Use Type Single Family Residential			
Total Dwelling Units, DUs	1,312 DU		
Total Area, acres	307	acres	
Sewer Flow Estimation			
Methodology 1 Methodology 2			
	Proactive Engineering	2021 In-progress	
	Consultants West, Inc. ¹	Wastewater Master Plan ²	
Average Flow Factor	350 gpd/DU	1,396 gpd/acre	
Average Flow, gpm	319	298	
Peak Design Sewer Flow, gpm	644	610 ³	
Design flows, gpm	773	610	
Lift Station	Capacity Evaluation		
Peak Design Sewer Flow, gpm	610		
Required Firm Capacity, gpm	773	610	
Minimum Total Capacity	1,546	1,220	
Evaluation Result			
Preliminary design report specifies two 803 gpm pumps for a total station capacity of 1,606 gpm, which meets the minimum capacity requirements.			
Force Main	n Capacity Evaluation		
Force Main Criteria			
Desired Velocity: 2 ft/s to 6.5 f	t/s		
Maximum Velocity: 10 ft/s			
Peak Sewer Flow, gpm	773	610	
Single Force Main Size ⁴ , inch	8	8	
Maximum Velocity, ft/s	4.9	3.9	
Evaluation Result			
The currently planned 8-inch force main will convey the peak devleopment flows within master plan criteria of 10 ft/s.			
AKEL ENGINEERING GROUP, INC. 4/15/2021			

1. Source: Sewer Design Calculation Preliminary Design Report provided by City staff March 17, 2021.

2. Average flow factor based on in-progress 2021 WMP, which is consistent with current EMWD standards.

3. Peak sewer flow reflects the following peaking factors:

Notes:

- Peak Day Flow = 1.33 x Average Annual Flow (Based on Historical Flow Data)

- Peak Hour Flow = 1.54 x Peak Day Flow (Based on 2021 WMP City-Wide Flow Monitoring Data)

4. Current development plans indicate the construction of parallel 8-inch force mains for reliability purposes. For the purposes of the capacity evaluation a single force main is considered operational to convey the full peak flow.



APPENDIX F

Wastewater Hydraulic Analysis for McClure Industrial Building



CITY OF BEAUMONT

WASTEWATER HYDRAULIC ANALYSIS FOR MCCLURE INDUSTRIAL BUILDING

Hydraulic Analysis Package

PRELIMINARY

August 2021








Table 1 Development Summary and Capacity Evaluation


Wastewater Hydraulic Analysis for McClure Industrial Building **City of Beaumont**


		PRELIMINARY	
Development Information and Flow Summary			
Development Information ¹			
Land Use Type Industrial			
Total Area	1.02	acres	
Sewer Flow Estimation ^{2,3}			
Average Flow Factor	1763	gpd/acre	
Average Flow	1.2	gpm	
Peak Design Sewer Flow	2.6	gpm	
Evaluation Results ⁴			
Gravity Main Criteria			
- Dry Weather Flow d/D Crit	eria: Diameter ≥ 15 inche	s < 0.70	
- Wet Weather Flow d/D Crit	teria: < 1.00		
- Minimum Velocity: 2 ft/s			
- Maximum Velocity: 10 ft/s			
Existing Condition ^{5,6}			
	PDWF	PWWF	
d/D	0.33	0.40	
Pipeline Velocity, ft/s	3.09	3.35	
Existing Condition + McClure Industrial Building ^{5,6}			
	PDWF	PWWF	
d/D	0.33	0.40	
Pipeline Velocity, ft/s	3.09	3.35	
Evaluation Result			
The hydraulic analysis indicates that the peak devleopment flows within master			
plan criteria.			
ENGINEERING GROUP, INC.		8/10/2021	
Notes:			

- 1. Source: Development information provided by City staff August 8, 2021.
- 2. Average flow factor based on in-progress 2021 WMP, which is consistent with current EMWD standards.
- 3. Peak sewer flow reflects the following peaking factors:
 - Peak Day Flow = 1.33 x Average Annual Flow (Based on Historical Flow Data)
 - Peak Hour Flow = 1.57 x Peak Day Flow (Based on 2021 WMP City-Wide Flow Monitoring Data)
- 4. Wastewater System Design Criteria extracted from City of Beaumont in-progress 2021 Wastewater Master Plan.
- 5. Depth/Diameter shown reflect the maximum value in the alignment extracted from hydraulic model.
- 6. Pipeline velocity shown reflect the minimum value in the alignment extracted from the hydraulic model.











APPENDIX G

Lift Station Condition Assessment – Prepared by V&A

Technical Memorandum

Akel Engineering Group, Inc. City of Beaumont (Wastewater) LIFT STATION CONDITION ASSESSMENT



Prepared for:	Tony Akel, P.E. Akel Engineering Group 7433 N. First Street, Suite 103 Fresno, CA 93720
Prepared by:	Farshad Malek, P.E.
Reviewed by:	Noy Phannavong, P.E.
Date:	May 2020



V&A Project No. 19-0280

In the promotion of environmental consciousness, this document is designed to be printed double-sided, if at all. V&A strives to do all it can to be a green company. Think twice before printing. Reduce. Reuse. Recycle.



1 INTRODUCTION

V&A Consulting Engineers, Inc. (V&A) was retained by Akel Engineering Group, Inc. (Akel) to support the City of Beaumont (City) with a structural and corrosion assessment of ten sanitary sewer lift stations (LS) located throughout the City's service area. The scope of the assessment included visual evaluation and supplementary non-destructive testing of concrete and metallic components of the major structural and mechanical equipment at each site. The findings will be used to provide input towards the City's Wastewater Master Plan Project. The sanitary sewer lift stations listed below were included in the assessment. Figure 1-1 shows an overview map of the lift station locations.

- 1. Fairway Canyon LS
- 2. Lower Oak Valley LS
- 3. Upper Oak Valley LS
- 4. Olivewood LS
- 5. Beaumont Mesa LS

- 6. Noble Creek LS
- 7. Marshall Creek LS
- 8. Cooper Creek (Industrial Park) LS
- 9. Seneca Springs LS
- 10. Four Seasons LS




Figure 1-1 Lift Station Location Map

2 APPROACH

2.1 VANDA® Concrete Condition Index

V&A created the VANDA Concrete Condition Index (Table 2-1) to provide consistent reporting of corrosion damage based on objective criteria. Concrete condition is rated from Level 1 to Level 5 based upon field observations and measurements, with Level 1 indicating the best case and Level 5 indicating severe damage. The individual criteria are applied based on engineering judgment to arrive at the overall rating.

Condition Rating	Description	Representative Photograph
Level 1	Little or no damage to concrete Hardness	
Level 2	 Minor surface damage Hardness soft surface layer to 1/8-inch depth Surface profile fine aggregate exposed Cracks hairline width, moderate frequency Spalling shallow spalling, minimal frequency Reinforcement not exposed or damaged 	
Level 3	 Moderate surface damage Hardness soft surface layer to 1/4-inch depth Surface profile large aggregate exposed or protruding Cracks up to 1/32-inch width, moderate frequency Spalling shallow spalling, minimal frequency Reinforcement exposed; minor damage, minimal frequency 	
Level 4	 Loss of concrete mortar and damage to reinforcement Hardness soft paste beyond 1/4-inch depth Surface profile large aggregate exposed, loose, or missing Cracks	
Level 5	 Bulk loss of concrete and reinforcement Hardness soft paste beyond 1-inch depth Surface profile large aggregate exposed, loose, or missing Cracks over 1/2-inch width, or narrower and frequent Spalling deep spalling, high frequency Reinforcement consumed; loss of structural integrity 	



2.2 VANDA® Metal Condition Index

V&A created the VANDA Metal Condition Index (Table 2-2) to provide consistent reporting of corrosion damage based on objective criteria. Metal condition is rated from Level 1 to Level 5 based upon field observations and measurements, with Level 1 indicating the best case and Level 5 indicating severe damage. The individual criteria are applied based on engineering judgment to arrive at the overall rating.

Table 2-2. VANDA® Metal Condition Index	Table 2-2.	VANDA®	Metal	Condition	Index
---	------------	---------------	-------	-----------	-------

	ondition ating	Description	Representative Photograph
	Level 1	 Little or no corrosion Wall thickness loss, generalnone Wall thickness loss, pittingnone to minimal Extent (area) of corrosionmay be widespread but superficial 	
	Level 2	 Minor corrosion Wall thickness loss, generalup to 20% Wall thickness loss, pittingup to 20% Extent (area) of corrosionlocalized 	
	Level 3	 Moderate corrosion Wall thickness loss, general20% to 40% Wall thickness loss, pitting20% to 60% Extent (area) of corrosionup to half of surface 	
	Level 4	 Severe corrosion Wall thickness loss, general40% to 60% Wall thickness loss, pitting60% to 100% (pinholes) Extent (area) of corrosionmost of surface 	
	Level 5	 Failure or imminent failure Wall thickness loss, generalgreater than 60% Wall thickness loss, pitting100% (holes) Extent (area) of corrosionmost or all of surface 	
C	0 2020 V&A	Consulting Engineers, Inc. All rights reserved.	

2.3 Concrete Assessment Methods

2.3.1 Concrete Surface Evaluation

Several methods were used to evaluate the condition of the concrete surfaces and its exposure environment. The methods used for these assessments are described in this section.

2.3.1.1 Sounding

Sounding was performed on accessible concrete slabs and walls at the evaluator's discretion to investigate for shallow, subsurface discontinuities. Using a hammer to strike accessible concrete surfaces, the sound can indicate if defects such as voids, delamination, or honeycombing are present. The sound returned from solid concrete without subsurface discontinuities is a sharp "ping" noise. A "hollow" sound generally means that a discontinuity exists beneath the sounding location. A soft "thud" typically results from deteriorated concrete.

2.3.1.2 Penetration Testing

Penetration testing was performed in concrete dry wells to estimate the depth of degradation from the existing surface of concrete. Penetration testing could not be performed in wet wells without conducting a confined space entry. Typically, as concrete deteriorates the cement paste begins to lose alkalinity. A chipping hammer was used to remove loose and degraded material from the concrete surface until highly alkaline concrete is reached where practical, and then the depth of the resulting cavity is measured. Unless the concrete is soft and chalky, V&A will typically not chip away more than 1/2-inch deep. In this case, if the pH in the cavity is not greater than 10, then the extent of degradation has not been reached and concrete coring is recommended. The correlation between penetration measurements and concrete surface hardness is presented in Table 2-3.

Penetration Depth (in.)	Surface Texture	Scaling ⁽¹⁾
< 1/16	Hard surface, no scaling ⁽¹⁾	No scaling
1/16 - 1/8	Softened surface and/or loose cementitious material, light scaling	Light scaling
1/8 - 1/4	Soft surface and/or exposed and loose fine aggregate, medium scaling	Medium scaling
> 1/4	Soft paste and/or exposed and loose coarse aggregate, severe scaling	Severe scaling

Table 2-3 Concrete Surface Hardness Index

⁽¹⁾ Scaling is defined by flaking or peeling away of near surface portion of hardened concrete or mortar, per ACI 201R, Condition Survey Guide.

2.3.1.3 Surface pH Measurements

V&A performed in-situ pH measurements on exposed concrete surfaces in concrete dry wells using a pH sensitive pencil. Surface pH testing could not be performed in wet wells without conducting a confined space entry. The pH of concrete exposed to wastewater is commonly altered by carbonation and hydrogen sulfide induced acid-attack (biogenic corrosion). Concrete carbonation refers to the reaction of atmospheric CO₂ with cement hydrates in concrete, which can lower the pH of the concrete to as low as 8.5. Carbonation is typically a slow process and is harmless until its depth reaches embedded reinforcing steel. Hydrogen sulfide induced corrosion, on the other hand, can be an aggressive mechanism of concrete degradation, where gaseous hydrogen sulfide is oxidized to sulfuric acid on surfaces within the sewer headspace. This process can severely deteriorate concrete and reduce the



surface pH to as low as pH 1.

The surface pH of the concrete can indicate the rate of concrete deterioration due to environment exposure. In general, with conventional concrete mix designs using common Type II and Type V Portland cements, concrete has the ability to withstand moderately low pH surfaces (\approx 6.0) for long periods of time. The generally accepted ranges for corrosion categories and surface pH values are listed below:

- Severe Corrosion. This category of concrete corrosion is characterized by significant measurable concrete loss or active corrosion. There is exposed aggregate and occasional exposed reinforcing steel. The original concrete surface is not distinguishable. The surface is covered with soft, pasty corrosion products where active scouring is not present. There is generally a depressed wall pH (< 3.0) indicating active corrosion.
- Moderate Corrosion. This category of concrete corrosion is characterized by some concrete loss with aggregate slightly exposed, but the original concrete surface is still distinguishable. The surface may have a thin covering of pasty material which is easily penetrated. There is generally a depressed wall pH (< 5.0) indicating moderately corrosive conditions.
- Light Corrosion. This category of concrete corrosion is characterized by a slightly depressed pH (< 6.0) and a concrete surface that can be scratched with a sharp instrument under moderate hand pressure with the removal of some concrete material. The original concrete surface is fully recognizable, and aggregate may or may not be exposed.
- Negligible Corrosion. This category of concrete corrosion is characterized by normal pH ranges (>6.0) and a normal concrete surface which cannot be penetrated or removed by a sharp instrument under moderate hand pressure. The surface of the concrete may have biological growth and moisture, but the concrete is normal, and the aggregate is not exposed.

Concrete pH levels below 10 at the depth of reinforcing steel bars can cause corrosion of the bars.



2.4 Coating Assessment

2.4.1 Dry Film Thickness

Dry film thickness (DFT) is the thickness of a coating after it has cured. A DFT gauge uses electromagnetic induction or eddy current technology to measure the thickness of a wide variety of coatings on metal surfaces. V&A used a gauge that can measure coatings up to 0.2 inches (200 mils) in thickness. Measurements were taken on metallic components in the same manner as described for ultrasonic testing in Section 2.5.1.

2.5 Metal Assessment Methods

2.5.1 Ultrasonic Testing

Ultrasonic testing (UT) is a non-destructive evaluation technique used for the determination of metal wall thickness. High-frequency sound waves are transmitted through one side of a metal wall from a transducer. When the sound waves reach the other side of the metal wall, a fraction of the waves will echo back to the transducer. The metal thickness is determined by recording the time it takes for the sound wave to travel through the metal and return.

Measurements were recorded for various piping. For pipes, measurements were made around the pipe circumference and were referenced to four clock positions (12:00, 3:00, 6:00, and 9:00) viewed in the downstream direction (Figure 2-1). If pitting, or extremely localized corrosion is found, a pit depth gauge will be used since UT may not provide acceptable readings due to the rough surface.




Figure 2-1 Clock Positions on Pipe Looking Downstream



3 CONCLUSIONS/RECOMMENDATIONS

Table 3-1 (below) provides a color-coded summary of the overall VANDA® ratings assigned to the various major components at each respective lift station. Table 3-2 provides a summary of recommendations resulting from V&A's corrosion assessment. Observations are supplemented with photographs and more detailed recommendations in the appendices. The appendices are provided as follows:

- A-1. Fairway Canyon LS
- A-2. Lower Oak Valley LS
- A-3. Upper Oak Valley LS
- A-4. Olivewood LS
- A-5. Beaumont Mesa LS
- A-6. Noble Creek LS
- A-7. Marshall Creek LS
- A-8. Cooper Creek (Industrial Park) LS
- A-9. Seneca Springs LS
- A-10. Four Seasons LS



Table 3-1 VANDA Condition Ratings Summary Table

	VANDA® Ratings (Overall)								
		Conc	rete (Strue	ctural)	-	Metal (Piping)			
Lift Station	CMU Wall	Equipment Pads ⁽¹⁾	Dry Well	Wet Well ⁽²⁾	Bypass MH ⁽²⁾				
1. Fairway Canyon LS	2	2	2	3	_ (3)	-	2	3	
2. Lower Oak Valley LS	2	3	-	2	2	2	-	4	
3. Upper Oak Valley LS	2	2	-	2	3	2	-	4	
4. Olivewood LS	2	2	-	2	-	2	-	2	
5. Beaumont Mesa LS	2	2	2	2	4	2	2	4	
6. Noble Creek LS	-	2	-	2	1	3	-	4	
7. Marshall Creek LS	2	2	-	2	2	3	-	4	
8. Cooper Creek (Industrial Park) LS	-	2	_	2	-	2	-	3	
9. Seneca Springs LS	3	2	_	1	1	2	-	3	
10. Four Seasons LS	3	3	-	2	2	2	-	3	

⁽¹⁾ Includes roof slab of wet well structures.

⁽²⁾ VANDA® ratings for lined structures assume liner is providing adequate protection against deterioration.

⁽³⁾ Not applicable.

Table 3-2 Recommendation Summary Table

	Recommendation							
Lift Station	Mortar (CMU)	Concrete repair	Repair Liner	New Liner	Replace Piping (Wet Well)	Touch up Coating	New Coating	Other
1. Fairway Canyon LS	х		х		х	х		х
2. Lower Oak Valley LS	х	х	х		х	х		
3. Upper Oak Valley LS		х		x	х		х	х
4. Olivewood LS							х	
5. Beaumont Mesa LS		х	х	х		х		х
6. Noble Creek LS					х		х	
7. Marshall Creek LS			Х		х		х	х
8. Cooper Creek (Industrial Park) LS							x	
9. Seneca Springs LS	х					х		х
10. Four Seasons LS			х			х		Х

APPENDICES



A-1





Lift Station

Location:
Looution.
Assessment Date:
Assessed by:
Lift Station Type:
Pumps:
Discharge Piping:

Fairway Canyon LS 33.964192°; -117.070813° 04.27.2020 Farshad Malek Non-submersible Duty: Pump #1, Pump #2 9" DIP



Sanitary Sewer / Location Map

Condition <u>Site</u> Summary:

- CMU perimeter wall, split face on external and shot-blast on the interior (VANDA 2)
 - There is no mortar on the vertical joints
 - Limited efflorescence observed, typically 0"-12" around the perimeter, presumably where there is less direct sunlight (moisture evaporation)
 - Spalling block on lower interior wall, near entrance
- Asphalt cracking throughout the site (0.25" width)
- Equipment concrete pads in good overall condition (VANDA 2)
 - Light exposed aggregate on generator equipment pad

Dry Well

- Steel can structure well lined in overall good condition (VANDA 2)
 - (2x) 6" pump assemblies
 - Minor surface corrosion typical at bolts and flanges throughout piping (VANDA 2)
 - Pump #2: leak from pump/motor onto flange resulting in VANDA 3 level corrosion; leak then continues to bottom of dry well (1/4" to 1/2" deep standing water)
- Pipe supports are in good condition, however the bottom is likely to develop corrosion due to constant submersion (leak from Pump #2)
- Corrosion in northwest wall where liner has failed
- Corrosion where conduit clamps have been fastened into the cone section

Wet Well

- Concrete collar: VANDA 3 rating with spalling concrete showing exposed aggregate (~6" x 3" area)
- PVC liner and concrete structure are in good condition overall
- Moderate grease layer covering interior of wet well
- Stainless steel ladder in good condition





Site Photo 1



Site Photo 2



Missing mortar at vertical CMU joints (typical)




Efflorescence typical along bottom 0"-12"



Spalling block wall near entrance



Spalling block (closeup)







Dry well interior



Dry well interior



Pump #1



Pump #1 corrosion at bolts



Pump #2, leak at pump/motor



Pump #2 corrosion due to leak (closeup)





Degraded liner and coating



Pump #2 corrosion at bolts/flanges



1-1/2" Sump Pump piping



Air blower



Corrosion where lined has failed (NW wall)



Corroded hardware at conduit supports





Exposed aggregate at wet well concrete collar



Exposed conduit outlet body



Wet well interior



Wet well interior (closeup)



Wet well interior (closeup)



Wet well interior (closeup)



UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (%)	Max. Wall Loss (in.)	Maximum Metal Loss (%)
1	Pump 1 (suction)	0.370	0.389	0.376	0.030	8%	0.370
2	Pump 1 (discharge)	0.396	0.437	0.410	0.004	1%	0.396
3	Pump 2 (discharge)	0.391	0.396	0.394	0.009	2%	0.391

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (suction)	6.9	10.4	8.8	8 to 12
2	Pump 1 (discharge)	19.0	35.7	28.1	8 to 12
3	Pump 2 (discharge)	23.5	39.3	29.9	8 to 12

 $^{(1)}$ Piping not exposed to sunlight is recommended to have 8 to 12 mils of epoxy coating

Recommendations

- 1. Repair leak from Pump #2 as soon as possible to prevent further corrosion and ensure longevity of other equipment.
- Touch up pipe coating as needed in dry well with two coats at 4 to 6 mils each of a surface tolerant epoxy. Acceptable products include Carboline Carboguard 891 VOC, PPG Amerlock 400, or Tnemec L69 Hi Build Epoxoline II. The surfaces will have to be prepared per SSPC SP11 Power Tool Cleaning to Bare Metal for proper adhesion and coating longevity.
- 3. Repair liner in dry well at locations identified and replace conduit support hardware; provide proper isolation of dissimilar metals to prevent future corrosion.
- 4. Apply mortar (Sika 223 or equal) to cover exposed aggregate on wet well concrete collar; provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination).

A-2





Lift Station

Lift Station ID: Location: Assessment Date: Assessed by: Lift Station Type: Pumps:

Discharge Piping:

Lower Oak Valley LS 33.959571°; -117.061583° 04.27.2020 Farshad Malek Submersible Pump Duty: Pump #1, Pump #2 Note: Pump #3 will not keep up with flow (50-hp) 6" & 10" DIP



Sanitary Sewer / Location Map

Condition <u>Site</u>

- Summary:
- CMU perimeter wall in good condition (VANDA 2) with minor efflorescence typical throughout
- Pointing in poor condition, either missing or depressed in most vertical joints on exterior, split-face side
- Asphalt in fair condition, minor cracks near entrance
- Concrete pads in overall fair condition (VANDA 3) with multiple cracks observed
 Cracked concrete at Pump 1 discharge header

Aboveground Piping

- Surface corrosion observed throughout piping where coating has failed (VANDA 2)
- Cracking on external rubber seals, presumably from UV damage and differential settlement of pipe supports
- Corrosion typical at threaded connections for ARVs and Air-Vac Valves
- Cracked concrete collar at 4" flange-mounts on top of concrete supports
- Cracked concrete pipe supports (x2) at Pump #3 ARVs; piping appears to have laterally shifted by 1 - 2 inches
- Corrosion at valve handle for 2" Industrial Water line (note: staff has noted this line is not in service, typical throughout District)

Wet Well

- T-lock liner appears to be in good condition with staining; concrete beneath is presumed to be in good condition (VANDA 2)
- Liner appears to have air pockets on inlet side of wall
- Coating is flaking off the safety grating at the opening
- Vent piping moderately corroded throughout (VANDA 3)
- Pump discharge piping is heavily corroded (VANDA 4)

Bypass Manhole

• Corrosion at manhole frame (VANDA 3)



- Liner is disbonding from the concrete at the cone; concrete beneath in good condition (VANDA 2)
- Pinholes in liner (x2) roughly halfway from the bench

Additional findings

• Minor corrosion observed on electrical panels



Site Photo 1



Site Photo 2



Missing mortar at vertical CMU joints (typical)



Efflorescence typical throughout interior CMU





Aboveground piping



Corrosion typical where coating has flaked



Corrosion typical where coating has flaked



Corrosion at ARV threaded connections (typical)



Cracking external rubber seals (typical)



Crack in concrete at Pump 1 discharge header

V&A Project No. 19-0280





Cracked concrete collar at 4-in flange-mounted pipe support (typical)



Cracked concrete pipe supports at Pump #3 ARVs; pipe shifted to left in photo




Wet well exterior



Peeling/flaking coating from grating










Wet well interior



Wet well interior



Heavy corrosion on pump discharge piping (VANDA 4; typical)



Pump discharge piping (closeup)



Pump discharge piping (closeup)





Bypass MH exterior, corrosion at rim



Bypass MH liner disbonding from cone



Bypass MH interior, pinholes in liner



EPDM ladder rungs in good condition

UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.377	0.392	0.383	0.043	10%
2	Pump 2 (spool)	0.365	0.380	0.370	0.015	4%
3	Pump 3 (spool)	0.358	0.399	0.379	0.022	6%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	8.3	15.1	11.8	6 to 9
2	Pump 2 (spool)	7.3	10.6	9.1	6 to 9
3	Pump 3 (spool)	9.9	11.1	10.5	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Monitor the state of degradation of the CMU wall mortar annually; if condition worsens, rake out mortared joints to a ¹/₄-in to a ¹/₂-in depth and pack with new mortar with the finish slightly recessed from the face of the block. Mortar vertical joints as well.
- 2. Touch up above-ground pipe coating as needed with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 3. Coat surfaces of galvanized steel piping and threaded connections
- 4. Repair cracked/broken concrete with Sika 223 or equal; provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination). Concrete repairs include the concrete at the Pump 1 discharge header, the concrete collars at the flange-mounted pipe supports (3 to 4 locations), and the cracked concrete pipe supports for Pump #3.
- 5. Monitor piping and supports for lateral movement and differential settlement.
- 6. Replace submersible pump discharge piping with fusion bonded epoxy-coated and lined steel piping.
- 7. Fully bond liner to the concrete at the cone of the bypass manhole, and repair pinholes. Acceptable products include Sancon 100 or equal.







Lift Station

Lift Station ID:	Upper Oak Valley LS
Location:	33.943414°; -117.0
Assessment Date:	04.28.2020
Assessed by:	Farshad Malek
Lift Station Type:	Submersible Pump
Pumps:	Duty: Pump #1, Pum
	Standby/High Level:
	Futura Dum #0 Du

Discharge Piping:

.034672° mp #5 el: Pump #3 Future: Pump #2, Pump #4 6" split (x2)



Sanitary Sewer / Location Map

Condition Site Summary:

- CMU perimeter wall in good condition (VANDA 2) with minor efflorescence typical
 - Spalling pocket on interior of south wall
 - . Pointing in fair condition
- Asphalt in good overall condition, one large crack (0.2") spanning from the wet well structure to the entrance gate
- Concrete pads in overall good condition (VANDA 2) •

Aboveground Piping

- Moderate surface corrosion typical throughout (VANDA 2) •
- Significant corrosion at Pump #1 ARV tap to 10" discharge (VANDA 4) •
- Corrosion at combination air valves for both discharge lines (VANDA 2) •
- Cracked concrete at the first pipe support for all three assemblies due to spanning • over an expansion joint

Wet Well

- T-lock liner appears to be in good condition with staining; concrete beneath is presumed to be in good condition (VANDA 2)
- Pump discharge piping is heavily corroded (VANDA 4) •
- Vent piping moderately corroded throughout (VANDA 2) •

Bypass Manhole

- Corrosion at manhole frame (VANDA 3) •
- Liner is degraded and disbonding throughout, concrete appears to be moderately • deteriorated (VANDA 3)
- No mortar at cone section, exposed aggregate •





Site Photo 1



Site Photo 2



Spalling pocket on interior of south CMU wall



Efflorescence typical throughout interior CMU



Aboveground piping



Surface corrosion typical throughout piping





Corrosion staining from tap connection



Corrosion at ARV tap connection (Pump 1)



Corrosion at CAVs (typical)



Corrosion at CAVs (typical)



over expansion joint



Cracked concrete base at pipe supports spanning Crack in asphalt spanning from wet well structure towards the entrance gate (0.2")





Wet well exterior



Wet well interior



Wet well interior



Wet well interior



Heavy corrosion on pump discharge piping (VANDA 4; typical)



Pump discharge piping





Pump discharge piping (closeup)



Pump discharge piping (closeup)



Bypass MH exterior, corrosion at rim



Non-mortared joints with exposed aggregate



Bypass MH interior



Liner disbonding from concrete (typical)



UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.291	0.347	0.320	0.059	17%
2	Pump 3 (spool)	0.339	0.352	0.345	0.011	3%
3	Pump 1-2 discharge (spool)	0.437	0.456	0.446	0.023	5%
4	Pump 2-3 discharge (spool)	0.409	0.456	0.429	0.051	11%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	2.7	15.9	10.0	6 to 9
2	Pump 3 (spool)	3.8	18.7	11.4	6 to 9
3	Pump 1-2 discharge (spool)	3.3	12.0	7.7	6 to 9
4	Pump 2-3 discharge (spool)	3.8	15.6	8.9	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Replace the corroded threaded tap connection at Pump 1 ARV while ensuring proper isolation of dissimilar metals.
- 2. Re-coat aboveground piping with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 3. Repair cracked/broken concrete with Sika 223 or equal; provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination). Concrete repairs include the cracked concrete pipe supports for Pump #1-3 spanning over the expansion joint. Consider moving the pipe supports downstream to the opposite end of the spool.
- 4. Replace submersible pump discharge piping with fusion bonded epoxy-coated and lined steel piping.



5. Replace liner in the bypass manhole with a 100% solids epoxy or polyurethane coating. Acceptable products include Endura Flex 1200 and 1988 or Raven 155 and 405.

A-4





Lift Station

Lift Station ID:
Location:
Assessment Date:
Assessed by:
Lift Station Type:
Pumps:

Discharge Piping:

Olivewood LS 33.940344°; -117.032122° 04.28.2020 Farshad Malek Submersible Pump Duty: Pump #1, Pump #2 Future: Pump #3 6" DIP



Sanitary Sewer / Location Map

Condition <u>Site</u>

Summary:

- CMU perimeter wall in good condition (VANDA 2) with minor efflorescence observed at the lower sections
- Pointing in fair condition
- Muddy, dirt ground surface with lots of tall weeds, good hiding spots for snakes.
- Equipment concrete pads in overall good condition (VANDA 2)

Aboveground Piping

- There is only factory coating applied to the piping, with only minimal surface corrosion observed (VANDA 2)
- Pipe supports are in good condition (VANDA 1)

Wet Well

- T-lock liner in good condition, moderate staining below waterline; concrete beneath is presumed to be in good condition (VANDA 2).
- Pump discharge piping in good condition (VANDA 2)





Site Photo 2

V&A Project No. 19-0280





Pointing in fair condition



Concrete pads in good condition



Aboveground piping



Aboveground piping



Only factory coating applied



Minimal surface corrosion typical at flanges





Cracking external rubber seals (typical)



Wet well exterior



Wet well interior



Pump discharge piping, minor corrosion at bolts/flanges



Wet well interior (closeup)



Wet well interior (closeup)



UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.249	0.301	0.275	0.031	11%
2	Pump 2 (spool)	0.311	0.335	0.321	0.029	8%
3	Common discharge	0.293	0.348	0.315	0.047	14%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	5.0	15.3	9.3	6 to 9
2	Pump 2 (spool)	6.8	14.2	9.4	6 to 9
3	Common discharge	2.7	7.8	5.5	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Consider paving the surface of the site and/or providing site maintenance to keep weeds short and reduce risk of snakes and other animals in hiding.
- 2. Apply 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane to the aboveground piping (SST not included). The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.







Lift Station ID:	Bea
Location:	33.
Assessment Date:	04.
Assessed by:	Far
Lift Station Type:	Nor
Pumps:	Dut
	Out

Discharge Piping:

Beaumont Mesa LS 33.940400°; -117.015966° 04.28.2020 Farshad Malek Non-Submersible Pump Duty: Pump #1, Pump #2 Out of Service: Pump #3, Pump #4 10", 14"



Sanitary Sewer / Location Map

Condition <u>Site</u>

- Summary:
- CMU perimeter wall in good condition (VANDA 2) with efflorescence typical throughout
 - Pointing in good condition
- Gravel surface with lots of tall weeds, good hiding spots for snakes.
- Concrete pads in overall good condition (VANDA 2)

Aboveground Piping

- Overall good condition with surface corrosion typical at bolts/flanges (VANDA 2)
- Moderate corrosion throughout all four combination air valves (VANDA 2)
- Cracked concrete pipe supports
 - Pump 1 beneath ARV
 - Pump 2 beneath ARV
 - Pump 2 from bolts going into concrete base
- Aboveground Biofilter with PVC piping and plastic storage tanks, SST hardware in good condition

Dry Well/Belowground Piping

- Cracked/peeling coating with corrosion evident throughout the swinging gate atop the Dry Well structure
- Sounding indicated solid concrete; delamination or shallow subsurface anomalies were not indicated (VANDA 2)
- Piping in overall good condition (VANDA 2). Corrosion at stainless steel flanges and tie rods typical throughout piping due to contact between dissimilar metals
- Corrosion at Flygt Pump/Motor base plates, Pump #1 and Pump #2
- Mild corrosion Pump 3 shaft
- Sump pumps completely submerged and appear heavily corroded (VANDA 4)
- Shallow spalling observed from 0" 16" away from finished floor, east wall
- Efflorescence observed on the ceiling around each of the three large grated openings, presumably resulting from infiltration into small cracks
- pH measurements indicated atmospheric conditions inside of dry well to be negligible with respect to corrosion

1



Wet Well

- T-lock liner is disbonding at the top of the structure at opening
- Heavily corroded conduit (instrumentation) at top of wet well structure (VANDA 5)
- T-lock liner in fair condition, stained in some areas below the waterline; concrete beneath is presumed to be in good condition (VANDA 2)
- Liner is warped in some areas however no punctures or tears were observed
- Influent piping is heavily corroded (VANDA 4)
- Corrosion product from influent piping 3" to 4" bleeding down the southwest wall

Bypass Manholes

- Bypass MH #1 (westernmost, closes to entrance gate)
 - Heavy corrosion on underside of lid (VANDA 4)
 - Aged liner disbonding from the concrete near the rim
 - Exposed aggregate typical throughout unlined bench (VANDA 4)
- Bypass MH #2
 - High H2S alarm from gas meter while standing over opened manhole
 - Liner is disbonding from the concrete
 - Joints are not mortared
- Bypass MH #3
 - Liner in fair condition
 - Exposed aggregate typical throughout unlined bench (VANDA 4)
- Bypass MH #4
 - Liner in fair condition
 - Exposed aggregate typical throughout unlined bench (VANDA 4)



Site Photo 1

Site Photo 2





Efflorescence typical throughout CMU (typical)



Pointing in good condition



Aboveground piping



Aboveground piping



Corrosion typical where there is contact between dissimilar metals



Corrosion typical at bolts/flanges (likely due to dissimilar metals)





Corrosion at CAVs (typical)



Corrosion at CAVs (closeup)



Cracked concrete pipe support (Pump 1)



Cracked concrete pipe support (Pump 2)



Cracking at pipe support concrete bases (typical)



Aboveground Biofilter





Biofilter SST hardware in good condition



Dry well access swing gate corroded throughout



Dry well interior



Dry well interior



Pump Assembly #1

Pump Assembly #2





Pump Assembly #3 & #4




Corrosion typical at SST flanges and tie rods, dissimilar metals



Corrosion at pump/motor base plates (Pumps #1-2)



Corrosion on pump shaft (Pump 4)



Corrosion typical on hardware at flexible couplings




Pipe supports in good condition






Sump pumps submerged, corroded



Steel ladder in good condition



Spalling typical at 0" – 16" AFF, east wall



Efflorescence on ceiling around openings



Liner disbonding at top of the structure



Corroded instrumentation conduit



Wet well interior



Wet well interior



Wet well influent pipe



Influent pipe, heavy corrosion (closeup)



Corrosion staining on southwest wall



Bypass MH #1 location





Heavy corrosion on underside of lid



Aged liner disbonding near the rim



Exposed aggregate typical throughout bench



Bypass MH #2 exterior



Liner disbonding from the concrete



Bypass MH #3 location





Bypass MH #3 interior



Bypass MH #4 location

Bypass MH #4 interior (closeup)



Bypass MH #4 interior

Concrete Penetration Testing Results:

Location	Penetration Depth (in.)	Surface pH	Depth pH	Remarks
Center of West Wall 5.5-ft AFF, Dry Well	1/16	11	12	Atmospheric conditions were negligible with respect to effect on corrosion



UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	South discharge, 10" (spool); aboveground	0.349	0.355	0.352	0.001	0%
2	North discharge, 14" (spool); aboveground	0.434	0.448	0.442	0.016	4%
3	Pump 2 suction, 10" (spool); dry well	0.406	0.440	0.421	0.034	8%
4	Pump 3 suction, 16" (spool); dry well	0.442	0.468	0.450	0.018	4%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	South discharge, 10" (spool); aboveground	13.5	18.9	16.4	6 to 9 ⁽¹⁾
2	North discharge, 14" (spool); aboveground	7.1	13.7	10.8	6 to 9 ⁽¹⁾
3	Pump 2 suction, 10" (spool); dry well	17.3	28.1	22.5	8 to 12 ⁽²⁾
4	Pump 3 suction, 16" (spool); dry well	12.9	13.5	13.2	8 to 12 ⁽²⁾

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

⁽²⁾ Piping not exposed to sunlight is recommended to have 8 to 12 mils of epoxy coating

Recommendations

- 1. Consider paving the surface of the site and/or providing site maintenance to keep weeds short and reduce risk of snakes and other animals in hiding.
- 2. Touch up aboveground pipe coating as needed with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.



- 3. Repair cracked/broken concrete pipe supports with Sika 223 or equal; provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination).
- 4. Touch up pipe coating as needed in dry well with two coats at 4 to 6 mils each of a surface tolerant epoxy. Acceptable products include Carboline Carboguard 891 VOC, PPG Amerlock 400, or Tnemec L69 Hi Build Epoxoline II. The surfaces will have to be prepared per SSPC SP11 Power Tool Cleaning to Bare Metal for proper adhesion and coating longevity.
- 5. Chip away damaged concrete on lower east wall inside of the dry well and patch with Sika 223 or similar cementitious patching material; provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination).
- 6. Repair liner at the top of the wet well with Sancon 100 or similar.
- 7. Replace corroded instrumentation conduit inside of the wet well.
- 8. Coat the wet well inlet pipe with a 100% solids epoxy or polyurethane coating. Acceptable products include Endura Flex 1200 and 1988 or Raven 155 and 405.
- 9. Replace liner in the Bypass MH #1 and MH #2 with a 100% solids epoxy or polyurethane coating. Acceptable products include Endura Flex 1200 and 1988 or Raven 155 and 405.
- 10. Mortar the bench of Bypass MH #3 and MH #4 to cover exposed aggregate and provide a smooth watertight seal to protect the concrete from moisture, Acceptable products include Sika 223 or equal. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination). Apply a 100% solids epoxy or polyurethane coating to the repaired area. Acceptable products include Endura Flex 1200 and 1988 or Raven 155 and 405

City of Beaumont Wastewater Master Plan Lift Station Condition Assessment

A-6





Lift Station ID: Location: Assessment Date: Assessed by: Lift Station Type:	Noble Creek LS 33.944963°; -117.001321° 04.29.2020 Farshad Malek Submersible Pump
Lift Station Type:	Submersible Pump
Pumps:	Duty: Pump #2, Pump #3
	Future: Pump #1

Discharge Piping:

12" DIP



Sanitary Sewer / Location Map

Condition Site

- Summary:
- Fencing in good condition, 3-layer barbed wire with minimal surface corrosion . (VANDA 2)
- Asphalt in overall fair condition, large cracks (0.2") spanning east-west near the ٠ entrance, from the corners of the wet well pad, and from the bypass MH
- Concrete pads in overall good condition (VANDA 2)

Aboveground Piping

- Moderate surface corrosion typical throughout (VANDA 3) •
- Surface corrosion covering surface of flowmeter (VANDA 3)
- Pipe supports are in good condition, well coated

Wet Well

- T-lock liner appears to be in good condition with staining and debris; concrete • beneath is presumed to be in good condition (VANDA 2)
- High density of small patchwork applied to wall, indicative of an aged structure.
- Pump discharge piping is heavily corroded (Pump #1: VANDA 4, Pumps #2-3: • VANDA 3)

Bypass Manhole

- T-lock liner in good condition, no defects noted; concrete beneath is presumed to be in good condition (VANDA 1)
- EPDM ladder rungs





Site Photo 1





Perimeter fencing, barbed wire with minimal corrosion



Cracking in asphalt near entrance



Cracking in asphalt from Wet Well and Bypass MH



Aboveground piping





Surface corrosion typical throughout piping



Surface corrosion typical throughout piping



Surface corrosion (closeup)



Corrosion throughout flowmeter



Pipe supports in good condition



Surface corrosion on transformer





Wet well exterior





Wet well interior



Wet well inlet (closeup)



PVC liner appears to be in good condition



Pump #1 discharge piping (closeup)





Pump #2 discharge piping (closeup)



Pump #3 discharge piping (closeup)



Bypass MH exterior



Manhole rim



Bypass MH interior



Bypass MH interior



UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 2 (spool)	0.308	0.358	0.334	0.062	17%
2	Pump 3 (spool)	0.350	0.365	0.357	0.020	5%
3	Common discharge	0.438	0.472	0.455	0.052	11%
4	Discharge flowmeter ⁽¹⁾	-	-	0.117	-	-

⁽¹⁾ Single point reading taken at crown of flowmeter

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 2 (spool)	7.5	12.0	9.3	6 to 9
2	Pump 3 (spool)	8.1	9.5	8.5	6 to 9
3	Common discharge	6.3	9.5	8.4	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Re-coat aboveground piping with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 2. Replace submersible pump discharge piping with fusion bonded epoxy-coated and lined steel piping.

City of Beaumont Wastewater Master Plan Lift Station Condition Assessment







Lift Station ID: Location: Assessment Date: Assessed by: Lift Station Type: Pumps:	Marshall Creek LS 33.940554°; -116.998411° 04.29.2020 Farshad Malek Submersible Pump Pump #1: Out of service Pump #2: Abandoned
	•
	Pump #3: In service

Discharge Piping:

10" & 12" DIP



Sanitary Sewer / Location Map

Condition Site

Summary:

- Perimeter fencing in good condition (VANDA 2)
- ~3-ft tall retaining wall on east perimeter minor efflorescence (VANDA 2) •
- Asphalt in overall fair condition, large cracks (0.2") typical leading from corners of • structures (wet well pad, generator pad, transformer pad)
- Concrete pads in overall good condition (VANDA 2) •

Aboveground Piping

- Moderate surface corrosion typical throughout (VANDA 3), covering roughly 10% of the surface area
- Minor surface corrosion observed on pipe supports (VANDA 2) •

Wet Well

- T-lock liner appears to be in good condition with staining and debris below • waterline; concrete beneath is presumed to be in good condition (VANDA 2)
- High density of small patchwork applied to wall, indicative of an aged structure.
- Pump discharge piping is heavily corroded (VANDA 4) •

Bypass Manholes

- Bypass MH #1 (south): •
 - Unlined, concrete is in overall good condition (VANDA 2)
 - Exposed circumferential reinforcement in cone section
- Bypass MH #2 (mid) .
 - Liner is in good overall condition, however there appears to be small tears exposed concrete within 3-ft of the bench; concrete beneath is presumed to be in good condition (VANDA 2)
- Bypass MH #3 (north) is welded shut, could not be opened







Site Photo 1



Site Photo 2



Aboveground piping



Aboveground piping



Cracked/peeling coating with corrosion typical throughout piping



Aboveground piping





Surface corrosion typical throughout piping



Surface corrosion (closeup)



Wet well exterior



Wet well interior



Wet well interior (closeup)



Pump discharge piping





Pump discharge piping (closeup)



Pump discharge piping (closeup)



Pump discharge piping (closeup)



Pump discharge piping



Bypass MH #1 (south) location

Manhole rim





Spiral reinforcement breaching concrete



Bypass MH #2 (mid) interior



Bypass MH #2 interior, small tears within 3-ft of the bench



Bypass MH #3 (north) welded shut with corrosion

UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.302	0.329	0.311	0.048	14%
2	Pump 2 (spool)	0.362	0.428	0.404	0.098	21%
3	Common discharge (east)	0.334	0.391	0.358	0.126	27%
4	Common discharge (west)	0.209	0.250	0.226	0.061	23%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	5.9	13.1	8.1	6 to 9
2	Pump 2 (spool)	4.6	10.5	8.7	6 to 9
3	Common discharge (east)	10.7	14.4	12.4	6 to 9
4	Common discharge (west)	2.1	4.1	3.2	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Re-coat aboveground piping with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 2. Replace submersible pump discharge piping with fusion bonded epoxy-coated and lined steel piping.
- 3. Patch-repair liner in Manhole #2 (mid). Acceptable products include Sancon 100 or equal.
- 4. Repair/replace lid and cover frame for Manhole #3 (north) so that it may be safely accessed. The lid would not budge after multiple attempts; the rim was moving with the lid during attempted removal.

City of Beaumont Wastewater Master Plan Lift Station Condition Assessment

A-8





Lift Station ID: Location:	Cooper Creek (Industrial Park) LS Beaumont WWTP 33.923845°; -116.994839°
Assessment Date: Assessed by: Lift Station Type:	04.27.2020 Farshad Malek Submersible Pump
Pumps:	Duty: Pump #2, Pump #3 Future: Pump #1
Discharge Piping:	6" DIP



Sanitary Sewer / Location Map

Condition Aboveground Piping

Summary:

- Coating is thin throughout the piping assemblies with minor surface corrosion (VANDA 2) as well as factory coating visible through peeling/flaking top-coat
- Concrete pad is in good condition (VANDA 1)
- Pipe supports are in good condition

Wet Well

- T-lock liner is in good overall condition, no defects evident; concrete beneath is presumed to be in good condition (VANDA 2)
- Surface corrosion typical throughout pump discharge piping (VANDA 3)



Site Photo 1

Site Photo 2





Aboveground piping



Surface corrosion typical throughout piping



Coating peeling/flaking at riser sections (typical)



Factory coating evident through thinned coating (typical)



Wet well pad in good condition



Wet well interior, topside





Wet well inlet



Pump discharge piping



Pump discharge piping (closeup)



Pump discharge piping (closeup)

UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max Wall Loss (%)
1	Pump 1 (spool)	0.311	0.335	0.323	0.029	9%
2	Pump 2 (spool)	0.309	0.334	0.319	0.031	9%
3	Pump 3 (spool)	0.334	0.343	0.339	0.006	2%
4	Common header	0.333	0.338	0.336	0.007	2%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	3.7	10.9	6.2	6 to 9
2	Pump 2 (spool)	4.5	12.0	7.8	6 to 9
3	Pump 3 (spool)	7.6	10.0	9.1	6 to 9
4	Common header	5.1	9.1	7.7	6 to 9
5	Pump 1 Check Valve, factory coating	2.1	2.5	2.3	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Re-coat aboveground piping with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 2. Monitor state of corrosion of discharge piping and plan to replace with fusion bonded epoxycoated and lined steel piping within the next 5 to 10 years.

City of Beaumont Wastewater Master Plan Lift Station Condition Assessment

A-9





Lift Station ID:	Seneca Springs LS
Location:	33.918558°;-116.962058°
Assessment Date:	04.29.2020
Assessed by:	Farshad Malek
Lift Station Type:	Submersible Pump
Pumps:	Duty: Pump #1, Pump #2, Pump #3
	Standby: Pump #3, Pump #2, Pump #1
Discharge Piping:	8" DIP (x2)



Sanitary Sewer / Location Map

Condition <u>Site</u>

- Summary:
- CMU perimeter wall, overall fair condition (VANDA 3)
 - Pointing in fair to poor condition, cracking typical throughout
 - Minor efflorescence typical throughout
- Asphalt in overall fair condition with cracking (0.2") typical leading from major equipment
- Groundwater is reportedly causing differential settlement throughout the site which is in turn causing strain on equipment including piping, hose connections, a tilting transformer, and a ~3-inch deep pothole west of the wet well pad.
- Concrete pads in overall good condition (VANDA 2)

Aboveground Piping

- Minor surface corrosion at bolts and flanges (VANDA 2)
- 2" brass backflow prevented in good condition (VANDA 2)
- 2" GSP Industrial Water in good condition (VANDA 2)
 - Line is dry, no tie-in to city water system (typical at all lift stations)
- Pipes are sagging heavily due to differential ground settlement
 - Additional supports are needed mid-span on Pump #1 and Pump #3 discharge piping ASAP
- Pipe support concrete bases for Pump #3 discharge piping broken
- Cracking typical at rubber flexible couplings due to stress and UV damage

Wet Well

- T-lock liner is in overall good condition, no significant defects noted; concrete beneath is presumed to be in good condition (VANDA 1)
- Submersible pump discharge piping moderately corroded throughout (VANDA 3)

Bypass Manhole

- Liner is in overall good condition; concrete beneath is presumed to be in good condition (VANDA 1)
- Large joints left un-mortared at the cone

1








Site Photo 1





Cracked/depressed mortar





Cracking in asphalt leading from major equipment



Pothole west of wet well





Aboveground piping, sagging in the center (Pump Assembly #1)



Aboveground piping, sagging in the center (Pump Assembly #3)



Aboveground piping



Minor corrosion at bolts, flanges, plug valves



Cracking in rubber flexible couplings (typical)



Pump discharge piping






Wet well exterior



Wet well interior



Wet well interior



Pump discharge piping



Pump discharge piping



Pump discharge piping (closeup)





Bypass manhole exterior



Bypass MH rim, remnants of plastic film, unmortared joints



Bypass MH interior



Bypass MH interior (closeup)

UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.345	0.350	0.348	0.015	4%
2	Pump 2 (spool)	0.318	0.340	0.328	0.042	12%
3	Pump 3 (spool)	0.317	0.337	0.325	0.043	12%



DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	8.3	14.2	11.2	6 to 9
2	Pump 2 (spool)	12.4	15.7	14.1	6 to 9
3	Pump 3 (spool)	7.8	14.7	11.3	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

Recommendations

- 1. Touch up aboveground piping as needed with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 2. Replace rubber flexible couplings showing cracks/UV damage.
- 3. Monitor state of corrosion of pump discharge piping within the wet well and plan to replace with fusion bonded epoxy-coated and lined steel piping within the next 5 to 10 years.
- 4. Mortar joints at the cone at the rim of the Bypass MH. Acceptable products include Sika 223 or similar. Provide a smooth finish to protect the concrete from moisture. Application shall not exceed the maximum application thickness specified by the manufacturer to prevent feathering (thin layers that will lead to cracking and delamination)
- 5. Investigate the extent and nature of the differential ground settlement. It appears piping is near a breaking point despite the use of flexible couplings; additional supports are needed ASAP. Differential settlement in electrical equipment may cause some connections to break – consult with an electrical engineer.

City of Beaumont Wastewater Master Plan Lift Station Condition Assessment

A-10





Lift Station

Lift Station ID:
Location:
Assessment Date:
Assessed by:
Lift Station Type:
Pumps:

Discharge Piping:

Four Seasons LS 33.906442°; -116.946850° 04.29.2020 Farshad Malek Submersible Pump Duty: Pump #1, Pump #2 Note: Pump #3 does not keep up with flow 14" & 8" DIP



Sanitary Sewer / Location Map

Condition <u>Site</u> Summary:

CMU perimeter wall

- Face of block is in fair condition, pointing is cracked with voids typical throughout (VANDA 3)
- The interior of the first half of the south wall was never grouted, caps for blocks can be easily lifted and inside of the CMU is empty. Due to the missing grout, the south wall shakes when the access gate is closed
- Asphalt in overall fair condition with cracking (0.2") leading from major equipment
- Concrete pads in overall fair condition (VANDA 3), cracking and localized areas with minor surface profile loss observed

Aboveground Piping

- Overall good condition, minor surface corrosion at bolts and flanges (VANDA 2)
- Localized corrosion where there is contact between dissimilar metals, multiple locations including at SST flanges
- Minor cracking at pipe supports
 - Pump #1 under 2nd ARV concrete support
 - Pump #2 under 1st ARV concrete support
 - Concrete base for metallic supports
- Minor wear typical at rubber flexible couplings presumably from UV damage

Wet Well

- T-lock liner stained throughout, particularly below the waterline (VANDA 2); concrete beneath is presumed to be in good condition (VANDA 2)
- Surface corrosion typical throughout pump discharge piping (VANDA 3)
- Vent piping corroded throughout (VANDA 3)

Bypass Manhole

- Liner is in overall good condition; concrete beneath is presumed to be in good condition (VANDA 2)
- Staining on the wall indicates a pinhole in the liner roughly 3 to 5 feet from the bench

1





Site Photo 1



Site Photo 2



Masonry wall cap loose



Missing grout inside of south wall



Mortared joints cracked with voids (typical)



Aboveground piping





Aboveground piping



Corrosion typical at bolts/flanges



Corrosion typical at bolts/flanges due to contact between dissimilar metals (including SST)



Dissimilar metal bolts/nuts used on SST pipe



Minor wear on rubber flexible couplings



Cracking under Pump #1 pipe support





Cracking under Pump #2 pipe support



Concrete base for metallic pipe supports



Wet well exterior



Wet well interior



Wet well interior

Wet well interior (closeup)





Surface corrosion typical throughout pump discharge piping



Surface corrosion typical throughout pump discharge piping



Pump discharge piping (closeup)



Pump discharge piping (closeup)



Bypass Manhole exterior



Pump discharge piping (closeup)





Bypass Manhole rim/cone section



Bypass Manhole bench and invert

UT Data:

Band	Piping	Minimum (inches)	Maximum (inches)	Average (inches)	Max. Wall Loss (in.)	Max. Wall Loss (%)
1	Pump 1 (spool)	0.418	0.448	0.432	0.032	7%
2	Pump 2 (spool)	0.376	0.380	0.378	0.014	4%
3	Pump 3 (spool)	0.307	0.375	0.348	0.053	15%

DFT Data:

Band	Piping	Minimum (mils)	Maximum (mils)	Average (mils)	Recommended thickness (mils)
1	Pump 1 (spool)	10.3	13.8	12.3	6 to 9
2	Pump 2 (spool)	9.5	8.0	8.5	6 to 9
3	Pump 3 (spool)	10.1	8.9	11.9	6 to 9

⁽¹⁾ Piping exposed to sunlight is recommended to have 4 to 6 mils of epoxy coating with an additional 2 to 3 mils of aliphatic polyurethane

6



Recommendations

- 1. Provide proper isolation where dissimilar metals are in contact.
- 2. After isolation has been provided, touch up aboveground piping as needed with with 4 to 6 mils of epoxy coating and 2 to 3 mils of aliphatic polyurethane. The surfaces shall be prepared per SSPC SP11 Power Tool Cleaning to bare metal for proper adhesion and coating longevity.
- 3. Replace rubber flexible couplings showing cracks/UV damage.
- 4. Monitor state of corrosion of pump discharge piping within the wet well and plan to replace with fusion bonded epoxy-coated and lined steel piping within the next 5 to 10 years.
- 5. Patch-repair the pinhole in the liner inside of the bypass manhole. Acceptable products include Sancon 100 or equal.



APPENDIX H

Capital Improvement Program Project Sheets


PROJECT S1



Apron Lane Pipeline Replacement

Project Background

This project includes the replacement of existing 8-inch gravity main with a new 12-inch gravity main along Apron Lane from Stableford Court to San Timoteo Canyon Road. This project is intended to mitigate an existing system deficiency.




PROJECT S2



Oak Valley Parkway/Edgar Avenue Pipeline Replacement

Project Background

This project includes the replacement of an existing 12-inch gravity with new 15-inch gravity mains in Edgar Avenue from Oak Valley Parkway to approximately 575-feet south of Oak Valley Parkway . This project is intended to mitigate an existing system deficiency.






PROJECT S3

Beaumont Mesa Lift Station and Force Main Improvements

Project Background

This project includes the force main and pump design, construction of a new 16-inch force main, replacement of new pumps. The new 16-inch force main, constructed along Potrero Boulevard and Western Knolls Avenue, will connect the Beaumont Mesa Lift Station to a partially completed 16-inch force main. This project is intended to mitigate an existing system deficiency. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021.








Beaumont Mesa Wet Well Improvement

Project Background

This project includes the wet well design, and construction of a new wet well. This project is intended to accommodate for future growth. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021.



City of Beaumont Wastewater Master Plan PROJECT S5 CCTV Program **Project Background** This project reflects performing CCTV review of the City's Wastewater System every three years, which is equivalent to an annual pipeline amount of approximately 59 miles per year. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021. **Project Description** Service Area **Recommended Implementation Project Component(s)** System Wide FY 2023/24, FY 2029/30 Pipeline **Project Trigger** Project Need Condition Project Cost Breakdown (2021 Dollars) Base Construction: Constr. Contingency (20%): Construction Total Engr., CM, Legal/Admin (30%): **Total Project Cost:** 300,000 **City of Beaumont Wastewater Master Plan PROJECT S6 On-going Pipeline Replacement Program Project Background** This project plans for as needed pipeline replacement and reflects a project cost equivalent to replacing one mile of 8-inch pipeline per year. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021. Project Cost Breakdown (2021 Dollars) Service Area **Recommended Implementation Project Component(s)** FY 2023/24 - FY 2030/31 System Wide Pipeline **Project Trigger Project Need** Condition Project Cost Breakdown (2021 Dollars) Base Construction: Constr. Contingency (20%): Construction Total Engr., CM, Legal/Admin (30%): **Total Project Cost:** 4,800,000 PRELIMINARY

City of Beaumont Wastewater Master Plan PROJECT S7 Lift Station Condition Assessment Improvement						
Project Background		ovenient				
<u>I Toject Buckground</u>						
This project reflects performing lift station improvements to include new electrical, new pumps, repairs to wet wells, repairs to components at the lift station, etc. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021.						
Project Description						
<u>Service Area</u> System Wide	Recommended Implementation FY 2022/23 - FY 2030/31	Project Component(s) Lift Station				
Project Trigger		Project Need Condition				
Project Cost Breakdown (2021 Dollars)					
e						
	onstruction:	-				
	Contingency (20%):					
	uction Total	-				
	CM, Legal/Admin (30%): roject Cost:	3,600,000				
		3,000,000				



PROJECT S8



Wastewater Treatment Plant Improvements

Project Background

This project includes the wastewater rate study for FY2024 through FY2028, installation of flow meters at lift stations for I&I project, I&I system repairs, construction of new WWTP office and staff workspace building, replacement of WWTP UV bulb and RO module. This project cost reflects City staff budgetary planning estimate provided by City staff on June 1, 2021.

