



City of Bel Aire, Kansas
7651 E. Central Park Ave
Bel Aire, Kansas 67226



FINAL PUD REVIEW

Address of proposed project: Bristol Hollows Addition PUD-24-03

This report is to document that on 8.30.24 the Zoning Administrator from the City of Bel Aire evaluated the above property plan for compliance of zoning and building requirements:

- | | |
|--|--|
| ☐ SETBACKS | ☐ ELEVATIONS |
| ☐ EFFECTIVE CODE COMPLIANCE | ☒ REQUIRED PLAN SUBMITTALS |
| ☐ EROSION CONTROL | ☐ EASEMENTS |
| ☐ LANDSCAPE | ☐ SCREENING |
| ☐ STORM DRAINAGE | ☒ NEIGHBORHOOD IMPACT |
| ☐ ADA ACCESSIBLE | ☐ UTILITIES TO BUILDING |

The review of the above property plan has been:

- ☒ APPROVED, as noted
- ☐ DELAYED, as noted
- ☐ DENIED, as noted

DATE 8/30/24

Keith Price
REVIEWED BY 

Comments:

Lot splits were completed prior to city approval and filed with the county. City staff has met with stakeholders. Final draft comments below:

- No utility companies were notified, the Townhouse ownership Act can solve any cross-lot concerns to protect property rights.
- The landscape concern is each single-family dwelling is 3 trees interior, two-family is 4 trees interior. Street trees no less than 1 per lot, corner lot no less than 2. The net increase of required trees is based on number of lots created. No increase of corner lots but it shifts the burden.
- Zoning code 18.1.4 indicates that the city building code item- R302, and Table 302.1(1) that still relates to the rating of the wall from both sides. Under number 5 of the proposed PUD submittal the information should be changed to state ...accordance with said Planned Unit Development to a duplex building standard as an exception to all applicable building standards adopted by the city of Bel Aire.
- <http://www.belaireks.citycode.net/> is the link to find the requirements for platting and zoning.