

City of Bel Aire, Kansas

STAFF REPORT

DATE: 7/17/2024

TO: City Manager

FROM: Marty McGee

RE: Denise Park



BACKGROUND: The corrugated 36-inch storm water drainage pipes at Denise Park have been installed for over 25 years and has deteriorated.

DISCUSSION: This 36-inch corrugated pipe allows storm water to drain water off the surrounding neighborhoods and exit under Denise Park. This corrugated pipe will need to be upgraded to reinforced concrete pipe to allow longer stability for our community.

Here are the start and completion time for each contractor:

Apex- 6 to 8 weeks start time, the cheapest but longest lead time, two weeks to complete the job.

UMC- start date on July 29th will take one week to complete the job but quoted CMP pipe, (corrugated metal pipe) not REC (reinforced Concrete Pipe) pipe. This is the same pipe that is currently in the ground. Not what we want to use. I had conversation with UMC this morning and he said the bid would be considerably higher with (RCP) pipe.

Dondlinger- Start date July 31st Two weeks to complete the job possibly sooner.

Contractors	Bid amount
UMC	\$33,800.00
Dondlinger	\$32,812.00
Apex	\$27,370.00

FINANCIAL CONSIDERATIONS: Funding for this project will be taken from the stormwater funds.

RECOMENDATION: Staff recommends the City Council accept the bid
From Dondlinger Construction In the amount of \$ 32,812.00