



TOWN OF BOWLING GREEN TOWN COUNCIL MEETING MONTHLY REPORT / PROJECT UPDATE

AGENDA ITEM: Public Works Department Monthly Report for August 2024

DATE: August 26, 2024

PREPARED BY: Shawn Fortune, Public Works Foreman

MONTHLY REPORT / PROJECT UPDATE:

- Drying Bed shoveling
 1. On August 8, 2024 public works staff shoveled one drying beds.
 2. On August 23, 2024 public works staff shoveled one drying beds.
- Monthly grass cutting has continued.
- The 301 Pump Station was flushed to clean the force main line.
- On August 7, 2024 we had a water main leak at 14330 Fredericksburg Turnpike the connection saddle had rusted apart.
- Bac T samples were collected for August 2024 they passed requirements.
- All the HVAC filters have been changed at all of the Town's buildings.
- All of the Pump Stations have been pumped out and cleaned for grease build up and to clean out wipes.
- The grinder pumps at Maury Heights Pump station had to be pulled on August 10, 2024 and August 15, 2024 because of wipes.
- All of the generators are started weekly manually.
- Hanging Baskets are watered weekly on Main St.
- Replacement Grinder Pump for Oakridge Pump Station is still on order.
- We have completed identifying the public side of our water service lines for the Lead and Copper Rules Revisions.

ATTACHMENTS:

HEADS UP ITEMS: