



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

Central District Office
3319 Maguire Blvd., Suite 232
Orlando, Florida 32803

NOTIFICATION OF ACCEPTANCE OF USE OF A GENERAL PERMIT

PERMITTEE:

Regal Marine Industries, Inc.
2300 Jetport Drive
Orlando, FL 32809
Duane Kuck, President

PERMIT NUMBER:

0428968-001-DWC/CG

ISSUE DATE:

December 21, 2022

EXPIRATION DATE:

December 20, 2027

COUNTY:

Orange

PROJECT NAME:

Regal Marine Boat Production
Expansion

CONNECTED TO:

Orlando CONSER I

FACILITY ID:

FLA010816

Email: pakuck@regalboats.com

Dear Mr. Kuck:

This letter acknowledges receipt of your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System for the subject project. Our office received the Notice on December 8, 2022. This project includes the construction of 1030 LF of 8-inch gravity sewer with laterals and 6 manholes, a lift station and 325 LF of 3-inch force main.

This is to advise you that the Department does not object to your use of such General Permit.

Please note the attached requirements apply to your use of this General Permit for constructing the proposed domestic wastewater collection/transmission system.

You are further advised that the construction activity must conform to the description contained in your Notification/Application for Constructing a Domestic Wastewater Collection/Transmission System and that any deviation will subject the permittee to enforcement action and possible penalties.

Sincerely,

A handwritten signature in black ink, appearing to read "OHM".

Osama Mahmoud
Engineer
Permitting and Waste Cleanup Program

cc: Paul Deuel, Water Reclamation Manager, City of Orlando, paul.deuel@cityoforlando.net
Reinaldo Malave, PE, Dewberry Engineers, rmalave@dewberry.com
Charles LeGros, DEP, Charles.LeGros@dep.state.fl.us
Osama Mahmoud, DEP, osama.mahmoud@dep.state.fl.us
Reggie Phillips, DEP, reggie.phillips@floridadep.gov

REQUIREMENTS FOR USE OF THE GENERAL PERMIT FOR DOMESTIC WASTEWATER COLLECTION/TRANSMISSION SYSTEMS:

1. This general permit is subject to the general permit conditions of Rule 62-4.540, F.A.C., as applicable. This rule is available at the Department's Internet site at:
<https://www.flrules.org/gateway/ChapterHome.asp?Chapter=62-4> [62-4.540]
2. This general permit does not relieve the permittee of the responsibility for obtaining a dredge and fill permit where it is required. [62-604.600(6)(b)1]
3. This general permit cannot be revised, except to transfer the permit. [62-604.600(6)(b)2]
4. This general permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project. [62-4.030]
5. Upon completion of construction of the collection/transmission system project, and before placing the facilities into operation for any purpose other than testing for leaks or testing equipment operation, the permittee shall obtain clearance from the Department. This clearance may be obtained expeditiously using the Department's Business Portal at <http://www.fldepportal.com/go/> (via "Submit" then "Registration/Notification" and "Submit Notifications to FDEP". The submission is for "Division of Water Resource Management Domestic/Industrial Wastewater" and the submittal type is "Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation").

For further clarification contact:
(Osama Mahmoud), (407) 897-4125
osama.mahmoud@dep.state.fl.us
3319 Maguire Blvd, Suite 232
Orlando, Florida 32803-3767

6. New or modified collection/transmission facilities can be placed into operation 3 days after Form 62-604.300(3)(b), (adopted and incorporated by reference in paragraph 62-604.300(3)(b), F.A.C., effective October 4, 2021, <http://www.flrules.org/Gateway/reference.asp?No=Ref-13560>), is submitted and received by the Department or delegated local program, provided no substantial deviations are noted on Form 62-604.300(3)(b) and the Department or delegated local program does not notify the permittee of public health or environmental concerns regarding placing the facilities into operation.

When substantial deviations are noted on Form 62-604.300(3)(b), (adopted and incorporated by reference in paragraph 62-604.300(3)(b), F.A.C., effective October 4, 2021), <http://www.flrules.org/Gateway/reference.asp?No=Ref-13560>, new or modified collection/transmission facilities can be placed into operation 10 days after Form 62-604.300(3)(b) is submitted unless the Department or delegated local program notifies the permittee of public health or environmental concerns regarding placing the facilities into operation.
[62-604.700(3) and (4)]

7. Abnormal events shall be reported to the Department's Central District Office in accordance with Rule 62-604.550, F.A.C. For unauthorized spills of wastewater in excess of 1000 gallons per incident, or where information indicates that public health or the environment may be endangered, oral reports shall be provided to the STATE WATCH OFFICE TOLL FREE NUMBER, (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee or other designee becomes aware of the circumstances. Unauthorized releases or spills less than 1000 gallons per incident are to be reported orally to the Department's Central District Office within 24 hours from the time the permittee, or other designee becomes aware of the circumstances. The written submission may be provided electronically using the Department's Business Portal at <http://www.fldepportal.com/go/> (via "Submit" followed by "Report" or "Registration/Notification"). [62-604.550]