

INSPECTION WORKSHEET (INSP-006371-2024)

Town of Bluffton, SC

20 Bridge Street, Bluffton, SC 29910 843-706-4522 email: inspections@townofbluffton.com

Case Number: RNEW-03-24-0736

Case Module: Permit

Inspection Date: Wed Apr 17, 2024

Inspection Status: Failed

Inspector: Holland, Sidney

Inspection Type: R - Slab

Job Address: 375 HAMPTON PKWY PARKWAY
BLUFFTON, SC, 29910

Parcel Number: R610 029 000 2482 0000

Contact Type

Company Name

Name

Engineer	Southern Consulting, Inc.	Austin, Anthony
Mechanical Contractor	Integrity Air, LLC	
Plumbing Contractor	Chaps Plumbing Services - USE THIS ACCOUNT	Chappelear, David
Electrical Contractor	Earls Electrical Services - USE THIS ACCOUNT	
Primary Contractor	Fields and Company LLC - USE THIS ACCOUNT	Fields, Melvin
Local Contact	Fields and Company LLC - USE THIS ACCOUNT	Fields, Melvin
Owner	Chabad Greater Hilton Head	Hertz, Menachem
Applicant	Fields and Company LLC - USE THIS ACCOUNT	Fields, Melvin

Checklist Item

Status

No Compaction

Failed

No Survey


Failed

4/17/24 SH note to inspection

Checklist Item

Status

Survey and home must be minimum 35' from street lot line and show setbacks on survey. Home must be 1' above street center. Do not pass until verified
Inspection discontinued



Holland, Sidney