

PETRO FLOW, INC

4369 Hwy 77

Chipley, FL 32428

850-271-0120

petroflowinc@gmail.com

Estimate**ADDRESS**

City of Bonifay-WWTP
611 Martin Luther King Jr Blvd
Bonifay, FL 32425

SHIP TO

City of Bonifay-WWTP
611 Martin Luther King Jr Blvd
Bonifay, FL 32425

ESTIMATE #

2775

DATE

06/08/2023

ACTIVITY**QTY****AMOUNT**

Based on your request Petro Flow Inc has composed of the following cost quote for your consideration.

Quote to make the following repairs to fuel systems per FDEP violations report dated (5/8/23)

- Install breakaway device on fuel hose
- Perform annual compliance testing for release detection device for tank #5 & #6
- Clean + repair surface cracks + repaint containment dyke for tank #3
- Clean + sand tank #3 + paint w/ enamel paint + install correct ID decals
- Replace Krueger leak gauge on #5 sub base generator tank
- Submit FDEP notification for repair listed

Service + Equipment:

- (1) Pressure washer use
- (1) Degreaser + cleaning supplies
- (1) FDEP approved containment crack filler
- (1) FDEP approved containment coating
- (1) Sanding + cleaning supplies (Tank #3)
- (1) White enamel paint supplies
- (1) 3.4" breakaway + 3/4" whip hose
- (1) Krueger leak gauge
- 100 Gallons Petroleum contact waste water disposal-containment
- (1) Tank ID decal kit (4) 1993 + (4) No Smoking
- (2) Annual Release Detection device testing (Tank 5 + 6)
- (1) Labor
- (1) Travel

Note: To meet NFPA 30A 2018 set back requirements tank #3 will have to be replaced with a fire resistant double wall tank @ minimum or pump moved 50' minimum from tank. This code is referenced in section 4.3.2.4 + 4.3.2.6

9,900.00

TOTAL**\$9,900.00**

Accepted By

Accepted Date