

July 26, 2023

City of Breckenridge 105 N Rose Breckenridge, Texas 76424 Attn: Cynthia Northrop, City Manager

## Re: Certification of Construction Completion Water Meter Replacement and AMI Project

Dear Ms. Northrop:

To the best of my knowledge, information, and belief, the above referenced project was constructed in accordance with the approved plans, specifications, and contract documents. The functionality of the new water meters and AMI system have been demonstrated to successfully meet the required 98.5% meter read rate and the Contractor has reconciled the final meter installation list with city records.

The contractor has submitted the following close-out documents for approval:

- 1. Final Change Order (CO #4)
- 2. Final Pay Request Release of Retainage (PR #5)
- 3. Affidavit of Bills Paid
- 4. Consent of Surety to Final Payment
- 5. Warranty Statement

These documents have been provided to the city by separate transmittal. Based on the above referenced information and in accordance with Section 15.06 of the Contract General Conditions, eHT recommends acceptance of the project and final payment be made to the contractor. If you have any questions or need any additional information, please contact me at (325) 698-5560.

Sincerely,

Enprotec / Hibbs & Todd, Inc.

Joseph T. Mangrem, P.E.

Project File 8170

JTM/jd

C:

26/2023