

**TO:** CITY COUNCIL  
**FROM:** PUBLIC WORKS SUPERVISOR JOE ZIERDEN  
**MEETING OF:** FEBRUARY 5, 2024  
**SUBJECT:** LIFT STATION 6 AND 7 REHABILITATION

**BACKGROUND:** The 2023 lift station inspections identified the need of new base elbows and guide posts to eliminate pump leaning/associated leakage in station 6 and 7. The lift stations are approximately 20 years old and the wear/tear seen is not unusual. A quote was obtained from Quality Flow Systems to rehabilitate lift station 6 (**\$22,100**) and 7 (**\$18,750**) for a total of **\$40,850**. The rehabilitation was budgeted for 2024.

**REQUESTED ACTION:** A motion to approve rehabilitation of lift station 6 and lift station 7 from Quality Flow Systems for **\$40,850.00** would be appreciated.