



# CITY COUNCIL MEETING

## AGENDA ITEM

---

<b>Prepared By:</b> <i>Joe Zierden, Public Works Supervisor</i>	<b>Meeting Date:</b> <i>1/5/2026</i>	<b>Item Name:</b> <b><i>Proposal for Sanitary Sewer Metering- Mag Meter at Sewer Plant</i></b>
--	---	---

### **BACKGROUND/DISCUSSION**

Currently wastewater influent is measured at the lift station #1 based on pump run times and is within approximately 10% to 15% of actual quantities of effluent received. During the sewer plant study performed earlier this year, this was identified as a liability to data collection and mag meter was suggested in the sewer plant study recommendations as a solution, delivering over 99% percent accuracy.

An estimate of \$60,000 was included in the 2026 budget for the design and installation of mag meters, though final cost would be determined through bidding the project.

### **FINANCIAL IMPACT**

\$6,000 - \$14,000 for bid package from Widseth.

### **STAFF RECOMMENDATION**

Proceed as presented by Widseth in the Proposal for Sanitary Sewer Metering Improvements