

WATER SERVICE CONNECTION WITH METER PIT


NOT TO SCALE

NOTES:

1. TOWN OF BRISTOL WATER DEPARTMENT SHALL SUPPLY METERS FOR INSTALLATION BY CONTRACTOR.
2. TOWN OF BRISTOL WATER DEPARTMENT SHALL SUPPLY ANTENNA ELECTRONIC METER READING TO BE INSTALLED IN METER PIT. ANTENNA SHALL BE ALIGNED WITH HOLE IN MANHOLE LID.
3. HOLE IN MANHOLE LID FOR ELECTRONIC METER READING SHALL BE 1"Ø.

WATER METER PIT COMPONENTS			
ITEM NO.	DESCRIPTION	SIZES (IN.)	
1	PE CTS SDR 9 WATER SERVICE	1	2
2	WATER METER	1	2
3	METER YOKE	1	2
4	SERVICE BOX	1	1
5	CURB STOP	1	2
6	CORPORATION COCK	1	2
7	METER FLANGES - 2 REQ'D	N/A	2
8	SPACE BETWEEN FLANGES	N/A	17.25
9	BY-PASS W/ ISOLATION VALVE	N/A	1.5
10	MANHOLE LID	18	36
11	RIGID PVC MANHOLE STRUCTURE	24	36
12	BALL VALVE	1	2

FIGURE 5.12



INSERT FOR 1 1/2" - 2" METERS
NO METER YOKE USED

WATER SERVICE CONNECTION WITH METER PIT

NOT TO SCALE

NOTES:

1. TOWN OF BRISTOL WATER DEPARTMENT SHALL SUPPLY METERS FOR INSTALLATION BY CONTRACTOR.
2. TOWN OF BRISTOL WATER DEPARTMENT SHALL SUPPLY ANTENNA ELECTRONIC METER READING TO BE INSTALLED IN METER PIT. ANTENNA SHALL BE ALIGNED WITH HOLE IN MANHOLE LID.
3. HOLE IN MANHOLE LID FOR ELECTRONIC METER READING SHALL BE 1"Ø.

WATER METER PIT COMPONENTS			
ITEM NO.	DESCRIPTION	SIZES (IN.)	
1	PE CTS SDR 9 WATER SERVICE	1	2
2	WATER METER	1	2
3	METER YOKE	1	2
4	SERVICE BOX	1	1
5	CURB STOP	1	2
6	CORPORATION COCK	1	2
7	METER FLANGES - 2 REQ'D	N/A	2
8	SPACE BETWEEN FLANGES	N/A	17.25
9	BY-PASS W/ ISOLATION VALVE	N/A	1.5
10	MANHOLE LID	18	36
11	RIGID PVC MANHOLE STRUCTURE	24	36
12	BALL VALVE	1	2

FIGURE 5.13