



Town of Bristol, RI
WATER POLLUTION CONTROL DEPARTMENT
2 PLANT AVENUE
BRISTOL, RI 02809-3015
(401) 253-8877 fax: (401) 253-2910

TOWN HALL
10 COURT STREET
BRISTOL, RI 02809
(401) 253-7000

Jose' J. Da Silva, Superintendent

7/24/2024

To: Melissa Cordeiro
Town Clerk

Re: Agenda Item
Change Order # 4

Requesting authorization to use \$81,256.00 of available funding from SRF 2022 Fund for additional work on the Solids Handling Upgrades (Contract No 984).

1. Portable water leak found to be in parking lot. Repaired prior to paving. (\$14,955.00)
2. Upgrade to Facility SCADA (Supervisory Control and Data Acquisition) system. Computer conflict with aged components and new system. (\$7,503.00)
3. A tank level alarm was installed to prevent localized flooding. (\$3,203.00)
4. Wall repairs discovered during demolition prior to installation of new controls. (\$3,315.00)
5. Dewatering room floor was found to have several voids that needed to be corrected. (\$9,222.00)
6. Two structural columns were found to have rotted sections that needed repairing, steel plates were welded in place. (\$2,671.00)
7. Miscellaneous electrical issues were addressed and corrected on time and material basis. (\$23,458.00)
8. While refurbishing the Gravity Thickener tank the inlet pipe was found to be heavily corroded and needed to be replaced. (\$7,713.00)
9. To accommodate a new transformer, an existing aged, out of date alarm panel had to be removed, relocated and wired. (\$9,221.00)

Sincerely,

Jose' Da Silva
Superintendent
Bristol WPCF