



## TOWN OF BRISTOL

DYE

### DEPARTMENT OF BUILDING INSPECTION

235 High Street, Bristol, Rhode Island 02809

Tel: (401) 253-7000 Fax: (401) 396-5466 www.bristolri.gov

#### Recommendation to the Town Administrator

Date 6/13/23

Re: Petition to the Town Council for Seasonal Outdoor Expansion  
The Nest  
29 State St.

I have reviewed the application and associated drawings and visited The Nest. Currently, the existing layout does not meet the letter of Americans with Disabilities Act requirements. Because of the stipulation in the Bristol Outdoor Dining Design Guidelines and Manual that *Patrons must have access to indoor restrooms*, I cannot recommend that this Petition be approved at this time.

  
Stephen Greenleaf, RA, CBO | Building Official

2023 JUN 14 PM 1:44

TOWN CLERK'S OFFICE  
BRISTOL, RHODE ISLAND

  
STEVEN CONTENTE  
Town Administrator

TOWN COUNCIL  
JUN 21 2023  
MEETING