

Permeable Pavement Operation, Maintenance, and Management Inspection Checklist

Project:

Location:

Site Status:

Date:

Time:

Inspector:

MAINTENANCE ITEM	SATISFACTORY / UNSATISFACTORY	COMMENTS
1. Sediment and Debris Cleanout (3 Months or Manufacturer's Recommendation)		
Contributing area free of sediment and debris		
Contributing area stabilized and mown, with grass clippings removed		
Surface free of sediment and debris (e.g., mulch, leaves, trash, etc.)		
No signs of clogging (e.g., standing water)		
Surface does not require vacuuming		
2. Dewatering (Monthly)		
Permeable pavement dewateres between storms		
3. Underdrain Outfall, if present (Annual)		
No evidence of erosion		

MAINTENANCE ITEM	SATISFACTORY / UNSATISFACTORY	COMMENTS
4. Surface Repairs (Annual)		
Surface has not been sealed		
No evidence of surface deterioration or spalling		
Surface (top and base course) does not need to be replaced		

Comments:

Actions to be Taken:
