



**Town of Bristol, RI**  
**WATER POLLUTION CONTROL DEPARTMENT**  
2 PLANT AVENUE  
BRISTOL, RI 02809-3015  
(401) 253-8877 fax: (401) 253-2910

TOWN HALL  
10 COURT STREET  
BRISTOL, RI 02809  
(401) 253-7000

Jose' J. Da Silva, Superintendent

3/16/2023

Comments on Land Modification at 1200 Hope Street.

1. For common gravity sewer pipe servicing structure 3-4 and 5-6 going out to Knowlton Court, main should be an 8 inch diameter pipe rather than 6 inch. There should also be a man-hole installed on the southern end of the piping for maintenance.
2. Plans to permanently abandon or removing existing buried sanitary sewer needs to be shown. Want to prevent groundwater intrusion.
3. What is the proposed sizing and discharge location of the new low pressure sewer servicing structures of 1-2 and 7-8 and the existing 1200 Hope Street dwelling? Are you proposing all to be low pressure or a combination? Needs better detail. There is also a proposed storm water discharge management system proposed in that general area. Why not connect structure 1-2 and 7-8 to the gravity line proposed to Knowlton Court and leave the original 1200 Hope Street as is.
4. Detail for the sewer force main on plans are very shallow, shown to be 2', would be susceptible to freezing. Pipe material should be specified.
5. Plans need to depict locations for cleanouts, (both for gravity and low pressure sewer), plans show proposed drawing of cleanout for a force line at depth of 4 feet.
6. Will this development be private, like a condo complex, with future maintenance being the responsibilities of the owners or public and that of the Town?
7. There are no profile drawings on plan showing depths of gravity sewer.
8. Page eight of plans does not match other sheets of set.

Respectfully,

Jose' Da Silva  
Superintendent  
Bristol WPCF