

Water Availability Request



Applicant Information

Date: 7/24/2024

Property Owner Signature: [Signature]

Owner (please print): Ana C. Riley

Corporate Title (if not an individual): Bristol Warren Regional School District

Address: 235 High Street, Bristol, RI 02809

Phone: 401-253-4000

Email: ana.riley@bwrsd.org

Contractor: Annelise Boylan

Email: aboylan@parecorp.com

Location

Preliminary request is hereby made for a confirmation that public water is available from BCWA to service this property:

Town: Bristol, RI

Location: 199 Chestnut Street

Address/Plat and Lot: Plat: 117 Lots: 3, 4, 5, 6, & 7

☐

Residential*

☒

Commercial*

Building Footprint: 98,550 sq ft

Occupancy: 948

Estimated Water Use: 23,700 gpd

***Site Plan Must Be Attached to All Applications**

For BCWA Office Use Only

Action by the Bristol County Water Authority

☒

Water Available

☐

Water Not Available

Approximate Static Pressure: 85 psi

Conditions: _____

If connection to BCWA is desired, you must:

☐

Submit Application for Main Extension Form and Engineering Plans for Review

☒

Submit Application for New Water Service Installation and Fee

Date of Review: 8/19/24

BCWA Engineer: Colin Orkun