

Town of Bristol, RI

Inspection Report

Inspection: Commerical Building Inspection

Inspector: Stephen Greenleaf

Inspection Date: Apr 1, 2025

Record: Building Permit #60924

Location: 366 HOPE ST, BRISTOL, RI 02809

Applicant: tom bergenholtz

Commercial-Miscellaneous

Overall Result: Fail

Overall Remarks:

Chimney support is deflecting. Support should be reinforced or the chimney removed. Reinforcement would need to be engineered, the roof structure is not designed for this type of load. I support removing the chimney.