



# Town of Bristol, Rhode Island

*Department of Community Development*

10 Court Street  
Bristol, RI 02809  
[bristolri.gov](http://bristolri.gov)  
401-253-7000

February 20, 2026

TO: Zoning Board

FROM: Diane M. Williamson, Director

RE: **Proposed Fencing around ACCU's for HVAC  
Dimensional Variance  
Former Reynolds School, 235 High Street**

This is to request that the Zoning Board continue the above application until the next Zoning Board meeting.

The proposed fencing needs to include acoustical panels to mitigate the noise from the HVAC units and our mechanical engineers have re-reviewed this and are recommending we need a 10' tall fence with the panels rather than the 8' tall fence that was applied for.

We are working with our engineers and architects to re-submit the revised plans for the Board's consideration.

Thank you.