

**TOWN OF BRISTOL, RI  
APPLICATION FOR SEWER PERMIT**

Date: 11/20/05

Permit: 2839KD

The undersigned licensed Drainlayer requests permission to install a sewer line at:

7 Stanton  
\_\_\_\_\_  
NO. STREET PLAT LOT

ASSESSABLE    YES    NO ACCOUNT NO: \_\_\_\_\_

**GENERAL RULES FOR INSTALLING SEWER LINES:**

1. Pipes from public sewer to property line shall be 6" in diameter.
2. Pipes from property line to building shall be 4" in diameter.
3. Junctions with public sewers shall be made at an angle by installing a wye or a tee.
4. Clean outs are required outside the foundation plus at 75' increments; at all significant changes in direction; and at all 45 degree or greater angles.
5. Pipes shall be imbedded in 6" of sand, processed gravel, or stone no greater than 3/4". Existing gravel is not acceptable.
6. Pipes shall be laid at a minimum of 3' below grade.
7. Inspection manholes shall be installed outside of commercial buildings for purposes of Pretreatment sampling.
8. Plumbing Permit from building Inspector is required for all interior connections.
9. Roadcut Permit from Department of Public Works is required for all roadcuts.
10. All Permits must be on job site.
11. Sewer Permit is good for 4 weeks.
12. Dig Safe must be notified by Drainlayer.
13. **NO INSPECTIONS WILL BE MADE AFTER 3:00PM WEEKDAYS OR ANYTIME WEEKENDS OR HOLIDAYS.**
14. It is the responsibility of the property owner and/or drainlayer to ensure that all Federal, State, and Local permits have been obtained.
15. Easements, Deeds, and all legal documents are the responsibility of the applicant and/or property owner.
16. Backflow Preventer/Check Valves are required on all buildings with basement plumbing.

**NOTE: Roof downspouts, foundation drains, area drains, and/or other sources of surface runoff or ground water to the public sewers are prohibited.**

FEE: \$ 10 CK# CC

\_\_\_\_\_  
Water Pollution Control Facility  
Superintendent

\_\_\_\_\_  
Property Owner  
Rooter Man Plumber  
Licensed Drainlayer  
MP 002380

**TOWN OF BRISTOL, RI  
APPLICATION FOR SEWER PERMIT**

Date: 11/12/25

Permit: 2837KD

The undersigned licensed Drainlayer requests permission to install a sewer line at:

10 Ansonia Ave 45 79  
NO. STREET PLAT LOT

ASSESSABLE  YES  NO ACCOUNT NO: \_\_\_\_\_

**GENERAL RULES FOR INSTALLING SEWER LINES:**

1. Pipes from public sewer to property line shall be 6" in diameter.
2. Pipes from property line to building shall be 4" in diameter.
3. Junctions with public sewers shall be made at an angle by installing a wye or a tee.
4. Clean outs are required outside the foundation plus at 75' increments; at all significant changes in direction; and at all 45 degree or greater angles.
5. Pipes shall be imbedded in 6" of sand, processed gravel, or stone no greater than 3/4". Existing gravel is not acceptable.
6. Pipes shall be laid at a minimum of 3' below grade.
7. Inspection manholes shall be installed outside of commercial buildings for purposes of Pretreatment sampling.
8. Plumbing Permit from building Inspector is required for all interior connections.
9. Roadcut Permit from Department of Public Works is required for all roadcuts.
10. All Permits must be on job site.
11. Sewer Permit is good for 4 weeks.
12. Dig Safe must be notified by Drainlayer.
13. **NO INSPECTIONS WILL BE MADE AFTER 3:00PM WEEKDAYS OR ANYTIME WEEKENDS OR HOLIDAYS.**
14. It is the responsibility of the property owner and/or drainlayer to ensure that all Federal, State, and Local permits have been obtained.
15. Easements, Deeds, and all legal documents are the responsibility of the applicant and/or property owner.
16. Backflow Preventer/Check Valves are required on all buildings with basement plumbing.

**NOTE: Roof downspouts, foundation drains, area drains, and/or other sources of surface runoff or ground water to the public sewers are prohibited.**

FEE: \$ 10 CK# 4789

Brayton/Ftax  
Property Owner

[Signature]  
Water Pollution Control Facility  
Superintendent

JML  
Licensed Drainlayer

14-1  
paid

2835 KD

**TOWN OF BRISTOL, RI  
APPLICATION FOR SEWER PERMIT**

Date: 9-2-25

Permit: 2835KD

The undersigned licensed Drainlayer requests permission to install a sewer line at:

<u>434</u>	<u>Metacum</u>	<u>155</u>	<u>54</u>
NO.	STREET	PLAT	LOT

ASSESSABLE  YES  NO ACCOUNT NO: \_\_\_\_\_

**GENERAL RULES FOR INSTALLING SEWER LINES:**

1. Pipes from public sewer to property line shall be 6" in diameter.
2. Pipes from property line to building shall be 4" in diameter.
3. Junctions with public sewers shall be made at an angle by installing a wye or a tee.
4. Clean outs are required outside the foundation plus at 75' increments; at all significant changes in direction; and at all 45 degree or greater angles.
5. Pipes shall be imbedded in 6" of sand, processed gravel, or stone no greater than 3/4". Existing gravel is not acceptable.
6. Pipes shall be laid at a minimum of 3' below grade.
7. Inspection manholes shall be installed outside of commercial buildings for purposes of Pretreatment sampling.
8. Plumbing Permit from building Inspector is required for all interior connections.
9. Roadcut Permit from Department of Public Works is required for all roadcuts.
10. All Permits must be on job site.
11. Sewer Permit is good for 4 weeks.
12. Dig Safe must be notified by Drainlayer.
13. **NO INSPECTIONS WILL BE MADE AFTER 3:00PM WEEKDAYS OR ANYTIME WEEKENDS OR HOLIDAYS.**
14. It is the responsibility of the property owner and/or drainlayer to ensure that all Federal, State, and Local permits have been obtained.
15. Easements, Deeds, and all legal documents are the responsibility of the applicant and/or property owner.
16. Backflow Preventer/Check Valves are required on all buildings with basement plumbing.

**NOTE: Roof downspouts, foundation drains, area drains, and/or other sources of surface runoff or ground water to the public sewers are prohibited.**

FEE: \$ 25 CK# 1524

[Signature]  
Water Pollution Control Facility  
Superintendent- ~~Secretary~~

Egan Estates  
Property Owner  
GMX Enterprises  
Licensed Drainlayer

White: WPCF      Green: Tax Assessor      Yellow: Town Council      Pink: Drainlayer      Gold: Homeowner

[Circular Stamp]

**TOWN OF BRISTOL, RI  
APPLICATION FOR SEWER PERMIT**

Date: 1/8/26

Permit: \_\_\_\_\_

The undersigned licensed Drainlayer requests permission to install a sewer line at:

400 Thomas

NO. STREET PLAT LOT

ASSESSABLE    YES    NO ACCOUNT NO: \_\_\_\_\_

**GENERAL RULES FOR INSTALLING SEWER LINES:**

1. Pipes from public sewer to property line shall be 6" in diameter.
2. Pipes from property line to building shall be 4" in diameter.
3. Junctions with public sewers shall be made at an angle by installing a wye or a tee.
4. Clean outs are required outside the foundation plus at 75' increments; at all significant changes in direction; and at all 45 degree or greater angles.
5. Pipes shall be imbedded in 6" of sand, processed gravel, or stone no greater than 3/4". Existing gravel is not acceptable.
6. Pipes shall be laid at a minimum of 3' below grade.
7. Inspection manholes shall be installed outside of commercial buildings for purposes of Pretreatment sampling.
8. Plumbing Permit from building Inspector is required for all interior connections.
9. Roadcut Permit from Department of Public Works is required for all roadcuts.
10. All Permits must be on job site.
11. Sewer Permit is good for 4 weeks.
12. Dig Safe must be notified by Drainlayer.
13. **NO INSPECTIONS WILL BE MADE AFTER 3:00PM WEEKDAYS OR ANYTIME WEEKENDS OR HOLIDAYS.**
14. It is the responsibility of the property owner and/or drainlayer to ensure that all Federal, State, and Local permits have been obtained.
15. Easements, Deeds, and all legal documents are the responsibility of the applicant and/or property owner.
16. Backflow Preventer/Check Valves are required on all buildings with basement plumbing.

**NOTE: Roof downspouts, foundation drains, area drains, and/or other sources of surface runoff or ground water to the public sewers are prohibited.**

FEE: \$ 10 CK# \_\_\_\_\_

[Signature]  
Water Pollution Control Facility  
Superintendent

\_\_\_\_\_  
Property Owner  
Scott's  
\_\_\_\_\_  
Licensed Drainlayer

**TOWN OF BRISTOL, RI  
APPLICATION FOR SEWER PERMIT**

Date: 1/8/26

Permit: \_\_\_\_\_

The undersigned licensed Drainlayer requests permission to install a sewer line at:

4 Columbian

NO. STREET PLAT LOT

ASSESSABLE     YES     NO ACCOUNT NO: \_\_\_\_\_

**GENERAL RULES FOR INSTALLING SEWER LINES:**

1. Pipes from public sewer to property line shall be 6" in diameter.
2. Pipes from property line to building shall be 4" in diameter.
3. Junctions with public sewers shall be made at an angle by installing a wye or a tee.
4. Clean outs are required outside the foundation plus at 75' increments; at all significant changes in direction; and at all 45 degree or greater angles.
5. Pipes shall be imbedded in 6" of sand, processed gravel, or stone no greater than 3/4". Existing gravel is not acceptable.
6. Pipes shall be laid at a minimum of 3' below grade.
7. Inspection manholes shall be installed outside of commercial buildings for purposes of Pretreatment sampling.
8. Plumbing Permit from building Inspector is required for all interior connections.
9. Roadcut Permit from Department of Public Works is required for all roadcuts.
10. All Permits must be on job site.
11. Sewer Permit is good for 4 weeks.
12. Dig Safe must be notified by Drainlayer.
13. **NO INSPECTIONS WILL BE MADE AFTER 3:00PM WEEKDAYS OR ANYTIME WEEKENDS OR HOLIDAYS.**
14. It is the responsibility of the property owner and/or drainlayer to ensure that all Federal, State, and Local permits have been obtained.
15. Easements, Deeds, and all legal documents are the responsibility of the applicant and/or property owner.
16. Backflow Preventer/Check Valves are required on all buildings with basement plumbing.

**NOTE: Roof downspouts, foundation drains, area drains, and/or other sources of surface runoff or ground water to the public sewers are prohibited.**

FEE: \$ 10 CK# \_\_\_\_\_

[Signature]  
Water Pollution Control Facility  
Superintendent

\_\_\_\_\_  
Property Owner  
Scotts  
Licensed Drainlayer