

D3E



**TOWN OF BRISTOL**

**DEPARTMENT OF BUILDING INSPECTION**

**235 High Street, Bristol, Rhode Island 02809**  
Tel: (401) 253-7000 Fax: (401) 396-5466 www.bristolri.gov

**Recommendation to the Town Administrator**

Date 7/5/23

Re: Petition to the Town Council for Seasonal Outdoor Expansion  
Bristol House of Pizza  
55 State St.

I have reviewed the application and associated drawings and inspected property exterior. Currently, the existing layout does not meet the letter of Americans with Disabilities Act requirements. Because of the stipulation in the Bristol Outdoor Dining Design Guidelines and Manual that *Patrons must have access to indoor restrooms*, I cannot recommend that this Petition be approved at this time.

Stephen Greenleaf, RA, CBO | Building Official

2023 JUL -5 PM 2:55  
TOWN CLERK'S OFFICE  
BRISTOL, RHODE ISLAND

CONCURRED  
*Steven Contente*  
STEVEN CONTENTE  
Town Administrator

TOWN COUNCIL  
JUL 12 2023  
MEETING