



302 Redbud Trail North
Buchanan, MI 49107
Tel: (269) 695-3844
Fax: (269) 695-4330

December monthly water report

We made it to the end of the year!! This month's water samples were collected, and they all came back good. I completed this month's Bacti report and the November monthly operation report and the chlorine residual report.

All were submitted on time and accepted by EGLE.

Ryan Young took his first round of water operator exams and passed. He is now an S-4 D-4 water operator and now qualifies as our back-up operator that is required by EGLE that the City of Buchanan has one.

There was a water main break on the corner of Main Street and Elizabeth Street. With the help from the DPW it was fixed with a repair band on an 8-inch water main.

We have been working on Meters and MXU that are not reading. We found some had dead MXU or broken wires to the meters. We are continuing to inspect and fix or replace these problems.

With the cold weather we had some hydrants freeze up this month. We were able to get these hydrants working again.

With the sale of the Ross Sanders building we needed to run a new waterline for the fire department. The water was coming through the Ross Sanders BLD. We put a new meter and ran a new water line.

Miss Dig tickets were plenty again this month. We marked water, sewer, and storm lines. Reports were done for all miss digs tickets.

There were also plenty of work orders this month. Most of the water shut offs due to leaks inside of the residents.

Door cards were passed out for non-payment again this month. Due to the cold weather, we did not shut off any residents.

We cleaned and inspected our equipment along with taking inventory and ordering items that we have low stock of.