



February water report.

Monthly requirements for EGLE have been completed and accepted.

Water main breaks were plenty this month with a total of 5 separate breaks. With help from the DPW we were able to put bands on them and stop the leak.

401 W Smith had water flow issues, a new line was installed and replaced the Galvanized line that had a blockage in it.

The Buchanan High School Biology class did a trip to the Wastewater plant and did a tour. I gave a informative speech about the water department and how everything works.

We have been doing Cross Connection inspections and this needs to be completed by the end of March.

We are looking into vacant properties and land to add to the CDSMI program.

I completed the Emergency Response Plan, Lead Service line replacement, and the CCR Distribution report and submitted them to EGLE.

We completed 36 Miss Digs and reports this month.

We are working on fixing meters/MXU that are not working.