



July water report

We spent a lot of time downtown this month. Very busy with water lines getting connected, along with boil orders due to that. This was mostly on Front st.

Ryan did 50 in home inspections this month. This should be about the end of them for a while. Only a few left that are being sorted out.

Plenty of Miss Digs again this month. They were nonstop all summer.

We had our annual well maintenance this month done by Peerless.

Everything was good running order no issues were found.

We were in compliance with EGLE again this month. We did have Well 4A fail the Bacti sample, Peerless came out and shocked the well and I had two clean tests in a row, and the well is back online.

Ryan attended a water class this month. He will be testing this fall for his S-4 D-4.

Completed shut offs for the month.

Fix a few smaller water leaks on service lines.

We are marking all the water service shut offs for the crew to pothole per our grant.

