



The month of June Water Department report

Submitted TTHA 5 water samples to EGLE, they came back good. These are part of my yearly samples I must do. The regular monthly reports and samples were also submitted on time and were accepted.

Had to do a boil order for E Front St. due to the new watermain connecting to the old watermain. Everything went well and both samples passed. Total days of boil order was two days.

Ryan completed 30 in-house inspections this month. We are getting close to being finished with the in-house inspections. Next to do on the list is pot-holing the service lines. We do have money in the grant to get that started. They should be starting mid-July.

We marked and filled out reports for close to 100 Miss-Digs again this month. Mostly due to construction projects.

I worked with a resident who had a plumber test for lead and had very high levels when they tested. I worked with EGLE and did our own test and found no detection of lead in our samples. I had a meeting and took educational pamphlets to them and explained how to limit lead exposure.

Put a new water service line in a house that was previously Galvanized and had broken. They now have a copper line to their house.

We repaired a couple services that were leaking at the shut-off valve. Also added new top soil and grass seed.

Fix a water -main break on the old Clarks property.

Handled 15 service calls to residents.

Worked downtown on the project most of the month.

Did Junes shut off list/handed out door cards