



October Water Department Report

We have completed all the monthly requirements with EGLE to stay in compliance for the month of October.

We have been working on fixing meters that have not been sending readings. Finding some with broken wires or MXU was knocked off.

Replaced a couple of pit meters and repaired the pit structure.

Egle did a visit to inspect the well sites. I will receive a report in a couple weeks of their visit.

Still marking water shut offs for the crew to pot hole for our CDSMI report. They are more than halfway thru the town.

Working on the Lead/Copper sample plan for EGLE. I need 40 houses that must fit the criteria to be eligible for a sample site.

Ryan will be taking his S-4 D-4 water exam November 4th. He has been taking classes, and I have been studying with him.

Marking Miss Digs and reports when they come in.

