

November

Water 7.62 MGD Chlorine 66.4lbs Fluoride 23% 148.8lbs

December

Water 9.38 MGD Chlorine 112.6lbs Fluoride 23% 149.2lbs

Below are my Bacti samples for each month.

November	11/4/2024	502 River Street	0.56	0.60
	11/4/2024	302 Redbud Trail	0.31	0.37
	11/4/2024	Rynearson Booster Station	0.94	1.03
	11/12/2024	502 River Street	0.65	0.69
	11/12/2024	302 Redbud Trail	0.30	0.41
			Monthly Average	0.552

December	12/2/2024	502 River Street	0.77	0.82
	12/2/2024	302 Redbud Trail	0.47	0.52
	12/2/2024	Rynearson Booster Station	0.74	0.81
	12/9/2024	502 River Street	0.73	0.83
	12/9/2024	302 Redbud Trail	0.50	0.53
			Monthly Average	0.642

2024

Gallons

Starting Date	Ending Date	Pumped	Gallons Billed	% Lost
12/27/2023	1/26/2024	8.75	7.292	17%
1/27/2024	2/27/2024	8.66	7.924	8%
2/28/2024	3/26/2024	8.44	6.941	18%
3/27/2024	4/26/2024	8.42	6.949	17%
4/27/2024	5/28/2024	9.24	7.389	20%
5/29/2024	6/27/2024	11.23	7.641	32%
6/28/2024	7/26/2024	10.39	8.505	18%
7/27/2024	8/27/2024	10.41	7.868	24%
8/27/2024	9/25/2024	10.81	9.395	13%
9/26/2024	10/25/2024	8.82	8.768	1%
10/26/2024	11/25/2024	7.62	7.962	-4%
11/26/2024	12/26/2024	9.38	6.659	29%
	Total	112.17	93.293	17%