

## Joint water/sewer meeting

Well its been a busy few months for the water department.

In June we changed out three fire hydrants that were broke. 1 on Main and 3<sup>rd</sup> The other on 4<sup>th</sup> and Cayuga st. and Jordan and Days. Dixon came and inspected both water towers the end of May. Everything looked good no major issues were found. They used a underwater camera to inspect the tower without draining them. We put a new water source at Victory park.

All samples for the EGLE are now done. Including Lead/Copper.

Fixed a leaking valve at firemans park and Clark st and Oak st.

Had a water leak on Carrol street service line going to the little league field was broke. We did 10 new meter change outs. Assisted 3 companies with water/ sewer locate to expand the businesses.

Monthly Bacti samples Well 4A failed twice. Meter at Clark lab is now in!! Was able to pot hole 5 services on Clark st. No Lead found.

Worked on getting new SCADA bid it was approved. Thrill on the Hill.

Miss Digs have been busy . Water Shut-offs are going well.

Working on getting Dylan ready for testing this fall.