

THE CITY OF **BURLESON** TEXAS


Assessment of Water Supply Strategies

Burleson City Council

June 2, 2025


Prepared By:

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526




BHC Firm Introduction

Who are our Clients?



Project Background and Scope

1. Why are we here?
2. How your Water System Works
3. Why is an Alternate Water Supply Needed?
4. How Much Alternate Supply is Needed?
5. Where From?
6. Best Apparent Source
7. At What Cost?
8. Next Steps




Project Background and Scope

1. Why are we here?

Currently, the City of Burleson receives treated drinking water supply from the City of Fort Worth. If practicable and feasible, supplemental water supply sources can work to enhance the resiliency of the City of Burleson's treated water supply in the event of an emergency or other disruption to the usual water supply source; and position the City to be able to diversify its water supply sources on a normal daily operating basis.


This study assesses the City of Burleson's existing and future treated water supply requirements; reviews the City's current water supply sources and limitations; and evaluates and reports on the practical and economic feasibility of securing and developing supplemental water supplies from various sources.



Water Distribution System Overview

1. Service Area Boundary

- Water Certificate of Convenience and Necessity (CCN)




Water Distribution System Overview

1. Service Area Boundary

2. Pressure Planes

• Lower (894)

• Upper (1,000')




Water Distribution System Overview

1. Service Area Boundary

2. Pressure Planes

- Lower (894')
- Upper (1,000')

3. Build-out Maximum Day Demand




Water Distribution System Overview

1. Service Area Boundary
2. Pressure Planes
 - Lower (894')
 - Upper (1,000')
3. Build-out Maximum Day Demand

4. Existing Delivery Points


- Industrial Pump Station
- ~~Alsbury Pump Station~~
- Hulen Pump Station



Water Distribution System Overview


1. Service Area Boundary
2. Pressure Planes
 - Lower (894')
 - Upper (1,000')
3. Build-out Maximum Day Demand
4. Existing Delivery Points
 - Industrial Pump Station
 - Hulen Pump Station

5. Ultimate Delivery Volumes




Water Distribution System Overview

1. Service Area Boundary
2. Pressure Plans
 - Lower (894')
 - Upper (1,000')
3. Build-out Maximum Day Demand
4. Existing Delivery Points
 - Industrial Pump Station
 - Hulen Pump Station
5. Ultimate Delivery Volumes
6. Major Transmission Mains



Why an Alternate Source of Treated Water Supply?

1. System Resiliency and Risk Reduction
2. Options and Flexibility to Serve Growth (Additional Source for future changes in Land Use or Development Types)
3. Possibly off-set Peak Day Restrictions
4. System Operational Flexibility



How Much Alternate Supply is Needed?

1. ~~Enough to Completely Replacement of Ft. Worth Supply (24 MGD)?~~

- ~~• Not Economically or Contractually Feasible~~

2. ~~Enough to Serve Max Day Demand to Buildout (24 MGD)?~~


- ~~• No New Supply from Ft. Worth.~~
- ~~• 13.6 MGD today to 24.0 MGD at Buildout – 10 MGD~~

3. Enough to “Peak Shave” high summertime Demands?

- 12 MGD Ave. Day to 24 Max Day = 12 MGD

4. Enough to Provide “Emergency Supply” Only?


- Average Day Demand $\div 2$ = 6.0 MGD



FROM WHERE?

Treated Water Sources

1. Johnson County Special Utility District
2. City Midlothian
3. City of Cleburne
4. City of Mansfield
5. City of Arlington



FROM WHERE?

Raw Water Sources

1. Tarrant Regional Water District
2. Trinity River Authority
3. Brazos River Authority

Cost Considerations:

Water Treatment Plant Cost:

- \$15-\$20 per gallon
- 6 MGD = **\$90 - \$120 Million**

BRA
Lake Granbury



23.5 mi


BURLESON

16.9 mi

TRA
Joe Pool Lake

19.2 mi

TRWD
Balancing
Reservoir



FROM WHERE?

Ground Water Sources


1. Practical Limitations of Reliable Source

- Expected Source at 2,000-foot depth
- Expected High TDS (Secondary Treatment)
- Water Quality and Blending with Surface Water
- Expected Low Volumes
 - 500 gpm (0.70 mgd) per water well
 - Nine (9) wells required to achieve goal of $\frac{1}{2}$ of the average day demand (6.0 mgd)

2. Prairielands Ground Water Conservation District

3. Cost Considerations

- \$5 - \$6 Million each (no treatment) =
\$45 - \$54 Million
- \$12-\$13 Million each (with treatment) =
over \$100 Million




APPARENT BEST OPTION

Johnson County Special Utility District (JCSUD)

16

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526




Source: JCSUD Water Master Plan Map (Jan. 2023)

THE CITY OF
BURLESON
TEXAS

APPARENT BEST OPTION

IMMEDIATE Connection to JCSUD
Pressure Plane No. 8 at or near
Mountain Valley Pump Station

OR...




APPARENT BEST OPTION

(Conceptual Alignment):

JCSUD - City of Arlington Treated Water Supply Line

Phase 1: 27 mile 42-inch Treated Water Supply Line

Phase 1 Capacity: 15 MGD



APPARENT BEST OPTION


JCSUD – City of Arlington Treated Water Supply Line

Phase 1: 27 mile 42-inch
Treated Water Supply Line


Phase 1 Capacity: 15 MGD

19

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526




APPARENT BEST OPTION




APPARENT BEST OPTION

Potential Connection/Delivery Points

- Air Gap and Ground Storage Tank Necessary
 - High Service Pump Station Necessary
1. Mountain Valley Pump Station and GSR
 2. Hidden Creek Parkway at S. Hurst Rd.







8,000 L.F.
20" Treated Water
Supply Line to the
Mountain Vally 0.30 MG
GSR and 2.45 mgd Pump
Station

1. Mountain Valley Pump Station & Ground Storage Reservoir

1. Mountain Valley Pump Station & Ground Storage Reservoir








2. Hidden Creek Parkway at S. Hurst Rd.



JCSUD Conceptual 42" Water Transmission Main Alignment

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526

THE CITY OF
BURLESON
TEXAS





CONCEPTUAL PROJECT COST

JCSUD Estimates:

Phase	Description	JCSUD	Arlington	Total
1	42" Transmission Main & Pump Station	\$112 M	\$30 M	\$142 M
2	25 MGD Treatment Plant Upgrade		\$167 M	\$167 M
3	40 MGD Treatment Plant Upgrade		\$50 M	\$50 M
Project Total:		\$112 M	\$247 M	\$359 M

Source: JCSUD, Pipeline Route Studies Presentation, April 2025



CONCEPTUAL PROJECT COST

Phase	Description	Total	Total Capacity (MGD)	Burleson Capacity		
				MGD	%	\$
1	42" Transmission Main & Pump Station	\$142 M	15	2	13.3%	\$18.9 M
2	25 MGD Treatment Plant Upgrade	\$167 M	25	4	16.0%	\$26.7 M
3	40 MGD Treatment Plant				15.0%	\$7.5 M
					Subtotal:	\$53.2 M
City of Burleson Conceptual Internal Infrastructure Cost:						
2 EACH - 3 MGD Pump Station with 0.5 MG Ground Storage Reservoir, OR						\$3.9 M
1 EACH -6 MGD Pump Station with 1.0 MG Ground Storage Reservoir						\$7.6 M
City of Burleson Internal Cost Subtotal - USE:						\$8.0 M
Project Total:						\$61.2 M

USE \$65 to \$70M

Potential Funding Source


1. Texas Water Development Board – Region C and Region G Planning Group

- a) 2021 Regional Water Plan
- b) 6th Planning Cycle (2026 Regional Water Plan)

2. Process to Get Funded (Time-sensitive)

(Applications open in January and close in March)


- a) Submit Projection Information Form (PIF)
- b) Submit Financial Assistance Application
- c) If approved, receive Financial Assistance Commitment
- d) Close on funding



COST COMPARISON SUMMARY


	Conceptual Cost (Million \$)		
	Treated Water Supply	Raw Water Supply	Groundwater Supply
Participation in JCSUD Treated Water Supply System	\$53.2		
Supply Water Lines		\$52.8	
Raw Water Intake and Pump Station		\$20.0	
Water Treatment Plant(s)		\$60.0	\$63.0
Groundwater Wells (9 each)			\$27.0
Ground Storage and High Service Pump Station	\$8.0	\$8.0	\$18.0
Internal Water Transmission Mains	\$3.2	\$5.0	
Annual Water Cost (Treated, Raw or Ground)	\$2.6	\$1.5	\$0.2
Annual Operation and Maintenance Cost			
Total:	\$66.9	\$147.3	\$108.2

-

- 

-

-




COUNCIL FEEDBACK SOUGHT

Groundwater Sources

1. Practical Limitations of Reliable Source
2. Prairielands Ground Water Conservation District
3. Cost Considerations

NEXT STEPS:

1. Conduct Hydrological Ground Water Study and Report that verifies:
 - a) Predicted Supply
 - b) Treatment Requirements
 - c) Depth and Cost of Wells
2. Meet with Prairielands Groundwater Conservation District to discuss this approach, District Regulations and Fees




COUNCIL FEEDBACK SOUGHT

Raw Water Sources

1. Tarrant Regional Water District
2. Trinity River Authority
3. Brazos River Authority

NEXT STEPS:

1. Meet with each entity to evaluate:
 - a) Availability of RAW Water Supply
 - b) Treatment Requirements
2. Determine Point of Delivery and Water Treatment Plant (WTP)
3. Prepare Capital Cost Estimates
 - a) Raw Water Pump Intake and Pump Stations
 - b) Raw Water Transmission Main
 - c) Treatment Plant
4. Estimate Annual Operation and Maintenance of WTP



COUNCIL FEEDBACK SOUGHT


Treated Water Sources

1. Johnson County Special Utility District
- ~~2. City Midlothian~~
- ~~3. City of Cleburne~~
- ~~4. City of Mansfield~~
5. City of Arlington??

NEXT STEPS:

1. Continue Discussions with JCSUD
 - a) Available Supply
 - b) Schedule
 - c) Capital Cost Participation
 - d) Treated Water Rates
2. Determine Point of Delivery
3. Prepare Capital Cost Estimates
4. Evaluate Funding Mechanisms

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526




Infrastructure & Development Committee Recommendation

- Abandon efforts related to groundwater (due to reliability) and raw water (cost prohibitive)
- Keep dialogue open with JCSUD anticipating capacity in the Arlington – JCSUD 42” Pipeline, but no commitment of funds at this time
- Assess impact of a \$67m supply project on our water rates for customers
- Further define our risk

	Conceptual Cost (Million \$)		
	Treated Water Supply	Raw Water Supply	Groundwater Supply
Participation in JCSUD Treated Water Supply System	\$53.2		
Supply Water Lines		\$52.8	
Raw Water Intake and Pump Station		\$20.0	
Water Treatment Plant(s)		\$60.0	\$63.0
Groundwater Wells (9 each)			\$27.0
Ground Storage and High Service Pump Station	\$8.0	\$8.0	\$18.0
Internal Water Transmission Mains	\$3.2	\$5.0	
Annual Water Cost (Treated, Raw or Ground)	\$2.6	\$1.5	\$0.2
Annual Operation and Maintenance Cost			
Total:	\$66.9	\$147.3	\$108.2

\$67 Million





Assessment of Water Supply Strategies

Prepared and Presented By:

BIRKHOFF, HENDRICKS & CARTER, LLP
Professional Engineers
TBPELS Firm 526

