City Council Regular Meeting

DEPARTMENT:	Capital Engineering
	ouplial Engineering

FROM: Randall Morrison, PE, Director of Capital Engineering

MEETING: July 21, 2025

SUBJECT:

Consider and take possible action on a Professional Services Agreement with Stantec Consulting Services, Inc., for the design of the Village Creek Basin 12-inch Wastewater Replacement Project in the amount of \$239,842. (*Staff Contact: Randy Morrison, PE, Director of Capital Engineering*)

SUMMARY:

The Village Creek Basin 12-inch Wastewater Replacement Project was identified in the 2023 City of Burleson Water & Wastewater Master Plan Update because the model results indicated that the existing 8-inch wastewater line experiences surcharging under projected peak wet weather flow. The project consists of approximately 3,200 LF of 8-inch wastewater line being upsized to 12-inch in the Village Creek Basin. The extents are from north of Hidden Creek Parkway to the existing 18-inch wastewater line on Dobson Street.

The professional services agreement will include geotechnical investigations, subsurface utility exploration, survey, environmental studies & permitting, full civil design, and construction administration and bid support services.

The total project is anticipated to cost an estimated \$2,772,000

- Design \$239,842 (this item)
- Construction \$2,532,000

This project is within the current Capital Improvement Plan and funded by Water and Wastewater Bonds.

The design is projected to be completed in the Spring of 2026 and construction in the Spring of 2027.

RECOMMENDATION:

Consider and take possible action on a Professional Services Agreement with Stantec Consulting Services, Inc., for the design of the Village Creek Basin 12-inch Wastewater Replacement Project in the amount of \$239,842.

PRIOR ACTION/INPUT (Council, Boards, Citizens):

N/A.

FISCAL IMPACT:

 Project #:
 WW2601

 Account Number(s):
 5203101-72010

 Amount:
 \$240,000

STAFF CONTACT:

Randall Morrison, PE Director of Capital Engineering rmorrison@burlesontx.com 817-426-9295