

Waiver Request – Parking Lot Standards

3808 S. Burleson Blvd.

Location:

- 2.07 acres
- Located south of the intersection of Valley St. and S. Burleson Blvd.

Applicant and Property Owner:

Larry Pool, Pools Land Mart, INC.

Item for approval:

Waiver to Section 5.5.E “Parking Lot/Site Layout Design Criteria” of the Design Standards Manual as amended by Resolution R-1175-10



Waiver Request – Parking Lot Standards

3808 S. Burleson Blvd.

Background:

- City Council approved Resolution amending Design Standards Manual on June 21, 2010 to include parking lot pavement standards
 - 6" Hot-Mix Asphalt Concrete-HMAC
 - 5" Reinforced Portland Cement Concrete
 - 6" Lime or Cement stabilized base
- City Council has approved waivers on recent projects for flexbase in areas where the public does not have access. The following section is the minimum staff has supported
 - 7" of flexbase on 95% compacted base

Waiver Request – Parking Lot Standards

3808 S. Burleson Blvd.

Notification:

- Public notices mailed to property owners within 200 feet of subject property
- Published in newspaper



Waiver Request – Parking Lot Standards

3808 S. Burleson Blvd.

P&Z Summary

Vote

Recommended Approval Unanimously

Discussion

None

Speakers

None

Waiver Request – Parking Lot Standards

3808 S. Burleson Blvd.

Council Action Requested

Questions/Discussion

Staff recommends approval of a waiver to Section 5.5.E “Parking Lot/Site Layout Design Criteria” of the Design Standards Manual as amended by Resolution R-1175-10 for the parking lot located at 3808 S. Burleson Blvd with the following conditions. (Case 22-104)

- A geotechnical engineering report be submitted to the city detailing the pavement section existing for the parking lot and specifying that the section exceeds the structural capabilities of 7” of flexbase on 95% compacted subgrade prior to any Certificate of Occupancy
- The parking lot shall only be utilized for employee parking and vehicle/truck storage and not accessible to the general public