

Current Code			
Fuel Capacity	Square Footage		
	Under 6,500	6,500 to 12,000	Over 12,000
Under 1,600 gallons	N/A	N/A	N/A
1,600 to 7,500 gallons	<u>M,S</u> GI/GII	<u>M,S</u> GI/GII	<u>M,S</u> GI/GII
Over 7,500 gallons	GI/GII	GI/GII	GI/GII

Monitored Fire Alarm - M
Sprinklers - S
Group I or Group II - GI/GII

Staff Proposed Amendment

Fuel Capacity	Square Footage		
	Under 6,500	6,500 to 12,000	Over 12,000
Under 1,600 gallons	N/A	N/A	N/A
1,600 to 7,500 gallons	M	M,S	<u>M,S</u> GI/GII
Over 7,500 gallons	GI/GII	GI/GII	GI/GII

Monitored Fire Alarm - M

Sprinklers - S

Group I or Group II - GI/GII

Current Code			
Fuel Capacity	Square Footage		
	Under 6,500	6,500 to 12,000	Over 12,000
Under 1,600 gallons	N/A	N/A	N/A
1,600 to 7,500 gallons	GI/GII	GI/GII	GI/GII
Over 7,500 gallons	GI/GII	GI/GII	GI/GII

Monitored Fire Alarm - M
Sprinklers - S
Group I or Group II - GI/GII

Current Code			
Fuel Capacity	Square Footage		
	Under 6,500	6,500 to 12,000	Over 12,000
Under 1,600 gallons	N/A	N/A	N/A
1,600 to 7,500 gallons	M,S	M,S	M,S
Over 7,500 gallons	GI/GII	GI/GII	GI/GII

Monitored Fire Alarm - M
Sprinklers - S
Group I or Group II - GI/GII

Staff Proj
Fuel Capacity
Under 1,600 gallons
1,600 to 7,500 gallons
Over 7,500 gallons

Monit
Group

Proposed Amendment

Square Footage		
Under 6,500	6,500 to 12,000	Over 12,000
N/A	N/A	N/A
M	M,S	GI/GII
GI/GII	GI/GII	GI/GII

Monitored Fire Alarm - M

Sprinklers - S

Group I or Group II - GI/GII