



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Southwest Region Office
PO Box 47775, Olympia, WA 98504-7775 • 360-407-6300

January 26, 2023

Robert Maul, Planning Manager
City of Camas
Community Development Department
616 Northeast 4th Avenue
Camas, WA 98607

Dear Robert Maul:

Thank you for the opportunity to comment on the determination of nonsignificance for the Lacamas Counseling Center Project (SEPA22-19) located at 3631 Northeast Everett Street as proposed by Scott Taylor for SGA Engineering. The Department of Ecology (Ecology) reviewed the environmental checklist and has the following comment(s):

SHORELANDS & ENVIRONMENTAL ASSISTANCE: Meghan Tait (360)-210-2783

Thank you for providing Ecology the opportunity to review the proposed Lacamas Counseling Center. The project will require a Conditional Use Permit (CUP) per City of Camas SMP Section 6.3.4(4)(a). All proposed development, including structures, decks and patios, should be located outside of the 150 foot Habitat Buffer, if possible, per the required mitigation sequencing. Any development proposed within the buffer will require a Variance Permit. The proposed trail must meet City of Camas SMP Section 16.51.110(C)(4) for Public and Private Pedestrian Trails. Please contact Shoreline Specialist, Meghan Tait, at meghan.tait@ecy.wa.gov or 360-210-2783 for questions or technical assistance.

SOLID WASTE MANAGEMENT: Derek Rockett (360) 407-6287

All grading and filling of land must utilize only clean fill. All other materials may be considered solid waste and permit approval may be required from your local jurisdictional health department prior to filling. All removed debris resulting from this project must be disposed of at an approved site. Contact the local jurisdictional health department or Department of Ecology for proper management of these materials.

TOXICS CLEANUP: Sam Meng (360) 999-9587

No confirmed or suspected cleanup sites within a quarter of mile from the project area. No comment. For questions contact Sam Meng with the Toxics Cleanup Program at the Southwest Regional Office at (360) 999-9587.

Robert Maul
January 26, 2023
Page 2

**WATER QUALITY/WATERSHED RESOURCES UNIT:
Brian Johnson (360) 624-5741**

Erosion control measures must be in place prior to any clearing, grading, or construction. These control measures must be effective to prevent stormwater runoff from carrying soil and other pollutants into surface water or stormdrains that lead to waters of the state. Sand, silt, clay particles, and soil will damage aquatic habitat and are considered to be pollutants.

Any discharge of sediment-laden runoff or other pollutants to waters of the state is in violation of Chapter 90.48 RCW, Water Pollution Control, and WAC 173-201A, Water Quality Standards for Surface Waters of the State of Washington, and is subject to enforcement action.

Construction Stormwater General Permit:

The following construction activities require coverage under the Construction Stormwater General Permit:

1. Clearing, grading and/or excavation that results in the disturbance of one or more acres **and** discharges stormwater to surface waters of the State; and
2. Clearing, grading and/or excavation on sites smaller than one acre that are part of a larger common plan of development or sale, if the common plan of development or sale will ultimately disturb one acre or more **and** discharge stormwater to surface waters of the State.
 - a) This includes forest practices (including, but not limited to, class IV conversions) that are part of a construction activity that will result in the disturbance of one or more acres, **and** discharge to surface waters of the State; and
3. Any size construction activity discharging stormwater to waters of the State that Ecology:
 - a) Determines to be a significant contributor of pollutants to waters of the State of Washington.
 - b) Reasonably expects to cause a violation of any water quality standard.

If there are known soil/ground water contaminants present on-site, additional information (including, but not limited to: temporary erosion and sediment control plans; stormwater pollution prevention plan; list of known contaminants with concentrations and depths found; a site map depicting the sample location(s); and additional studies/reports regarding contaminant(s)) will be required to be submitted. For additional information on contaminated construction sites, please contact Evan Wood at evan.wood@ecy.wa.gov, or by phone at (360) 706-4599.

Additionally, sites that discharge to segments of waterbodies listed as impaired by the State of Washington under Section 303(d) of the Clean Water Act for turbidity, fine sediment, high pH, or phosphorous, or to waterbodies covered by a TMDL may need to meet additional sampling and record keeping requirements. See condition S8 of the Construction Stormwater General Permit for a description of these requirements. To see if your site discharges to a TMDL or 303(d)-listed waterbody, use Ecology's Water Quality Atlas at: <https://fortress.wa.gov/ecy/waterqualityatlas/StartPage.aspx>.

The applicant may apply online or obtain an application from Ecology's website at: <http://www.ecy.wa.gov/programs/wq/stormwater/construction/> - [Application](#). Construction

Robert Maul
January 26, 2023
Page 3

site operators must apply for a permit at least 60 days prior to discharging stormwater from construction activities and must submit it on or before the date of the first public notice.

Ecology's comments are based upon information provided by the lead agency. As such, they may not constitute an exhaustive list of the various authorizations that must be obtained or legal requirements that must be fulfilled in order to carry out the proposed action.

If you have any questions or would like to respond to these comments, please contact the appropriate reviewing staff listed above.

Department of Ecology
Southwest Regional Office

(GMP:202300175)

cc: Meghan Tait, SEA
Derek Rockett, SWM
Sam Meng, TCP
Brian Johnson, WQ