



STATE OF WASHINGTON  
**DEPARTMENT OF ECOLOGY**

Southwest Region Office  
PO Box 47775, Olympia, WA 98504-7775 • 360-407-6300

April 2, 2025

Robert Maul, Planning Manager  
City of Camas  
Community Development Department  
616 Northeast Fourth Avenue  
Camas, WA 98607

Dear Robert Maul:

Thank you for the opportunity to comment on the mitigated determination of non-significance for the Camas Woods Project (SUB24-1002) located at 920 Southeast Gardner Road as proposed by Michael Andreotti. The Department of Ecology (Ecology) reviewed the environmental checklist and has the following comment(s):

**HAZARDOUS WASTE & TOXICS REDUCTION: Garret Peck (564) 669-0836**

The applicant proposes to demolish an existing structure(s). In addition to any required asbestos abatement procedures, the applicant should ensure that any other potentially dangerous or hazardous materials present, such as PCB-containing lamp ballasts, fluorescent lamps, and wall thermostats containing mercury, are removed prior to demolition. It is important that these materials and wastes are removed and appropriately managed prior to demolition. It is equally important that demolition debris is also safely managed, especially if it contains painted wood or concrete, treated wood, or other possibly dangerous materials.

Please review the "Dangerous Waste Rules for Demolition, Construction, and Renovation Wastes," posted at Ecology's website, <https://ecology.wa.gov/Regulations-Permits/Guidance-technical-assistance/Dangerous-waste-guidance/Common-dangerous-waste/Construction-and-demolition>. The applicant may also contact Katy Harvey of Ecology's Hazardous Waste and Toxics Reduction Program at [katy.harvey@ecy.wa.gov](mailto:katy.harvey@ecy.wa.gov) for more information about safely handling dangerous wastes and demolition debris.

**SOLID WASTE MANAGEMENT: Derek Rockett (360) 995-3176**

All grading and filling of land must utilize only clean fill. All other materials may be considered solid waste and permit approval may be required from your local jurisdictional health department prior to filling. All removed debris resulting from this project must be disposed of at an approved site. Contact the local jurisdictional health department or Department of Ecology for proper management of these materials.

**TOXICS CLEANUP: Sam Meng (360) 999-9587**

Robert Maul

April 2, 2025

Page 2

If contamination is suspected, discovered, or occurs during construction, testing of the potentially contaminated media must be conducted. If contamination of soil or groundwater is readily apparent, or is revealed by sampling, the Department of Ecology must be notified. To notify Ecology, contact the Environmental Report Tracking System Coordinator at the Southwest Regional Office at (360) 407-6300. For assistance and information about subsequent cleanup and to identify the type of testing that will be required, contact Sam Meng with the Toxics Cleanup Program at the Southwest Regional Office at (360) 999-9587.

Ecology's comments are based upon information provided by the lead agency. As such, they may not constitute an exhaustive list of the various authorizations that must be obtained or legal requirements that must be fulfilled in order to carry out the proposed action.

If you have any questions or would like to respond to these comments, please contact the appropriate reviewing staff listed above.

Department of Ecology  
Southwest Regional Office

(JKT:202501094)

cc: Garret Peck, HWTR  
Derek Rockett, SWM  
Sam Meng, TCP