



R.L. REIMERS COMPANY

GENERAL CONTRACTORS

To	Bob Busch / Jack Wallis		NOTIFICATION LETTER NO:	5		
Company	City of Camas		Date	10/14/2020		
Address:	1129 SE Polk St		Job No:			
	Camas, WA 98607		Job Name:	Camas WWTP - Gravity Thickener		
Phone:	(360) 817-7164			Repair		
Email:	bbusch@cityofcamas.com		Regarding:	Added Storage Tank for Sludge to DAF		
Notification of:		Request for Additional Time	X	Cost Proposal		
Description						
The extra cost to supply the 3000 gallon sludge storage tank to feed the DAF is as follows. We see this as a change since there was nothing on the drawings calling out that there was a storage tank needed for the supply from the Hydroclone to the DAF. After initial testing it was found that the screens were unable to gravity feed the DAF without backing up.						
Date of Installation: N/A						
Labor Cost:	Rate	Hours	Workers	Total	Markup	Total
Laborer	\$62.83	8	1	\$ 502.64	29%	\$ 648.41
Millwright/Ironworker	\$87.56			\$ -	29%	\$ -
Pipefitter	\$104.56			\$ -	29%	\$ -
Operator	\$74.41			\$ -	29%	\$ -
Foreman	\$74.75	8	1	\$ 598.00	29%	\$ 771.42
Labor Total:						\$ 1,419.83
Materials:		Quantity	Cost	Markup	Total	
	3000 Gallon HDPE Storage Tank	1	\$ 1,300.00	21%	\$ 1,573.00	
	Misc Pipe & Fittings	1	\$ 175.00	21%	\$ 211.75	
Materials Total:						\$ 1,784.75
Equipment:		Rate	Hours	Total	Markup	Total
	Service Truck	\$ 25.00	8	\$ 200.00	21%	\$ 242.00
				\$ -	21%	\$ -
Equipment Total:						\$ 242.00
Subcontractor:				Total	Markup	Total
					12%	\$ -
					12%	\$ -
Subcontractor Total:						\$ -
Sub-Total:						\$ 3,446.58
	Bond Premium @ 1.55%					\$ 53.42
	Insurance Premium @ 1.25%					\$ 43.08
	Washington Sales Tax @ 8.4%					\$ 297.62
Total:						\$ 3,840.70
Upon acceptance of the noted cost impact, R.L. Reimers Company request that a change order						
be issued to,	X			Increase the contract amount by:		\$3,840.70
R.L. Reimers request that our contract amount be extended by:				0	Working Days	
Copy To			By	Ross Meyer		
				Project Manager		
Attachments			Email	ross@rlreimers.com		