



## Staff Report

June 16, 2025 Council Regular Meeting

Construction Award for Lacamas Meadows Force Main Replacement


Presenter: Rob Charles, Utilities Manager

Time Estimate: 5 minutes

Phone	Email
360.817.7003	rcharles@cityofcamas.us

**BACKGROUND:** The 0.6 mile force main (FM) from Lacamas Meadows Sewer Lift Station to Lake Road has ruptured and leaked 5 times over the last 5 years in several different locations. The city is unable to determine why the breaks keep occurring, but replacement of the pipe appears to be the best option to mitigate this continuing problem. The City has completed a design on 0.3 miles of the pipe where all of the breaks have occurred from the sewer lift station to Leadbetter Drive.

**SUMMARY:** Gradeworks Excavating has been awarded the construction contract. To aid in managing the construction, Consor Engineering is providing submittal review and construction assistance to the city as needed. City staff will be handling daily inspections on the project.



**Figure 1: Lacamas Meadows FM Replacement**

**BENEFITS TO THE COMMUNITY:** Reduced impacts to citizens along the FM route when the force main has had to be repaired.

**BUDGET IMPACT:** The cost for the work will be \$57,124 and there are sufficient funds in sewer to cover this expenditure.

**RECOMMENDATION:** Staff recommends this item be placed on the July 7, 2025 Council Regular Meeting Consent Agenda for Council's consideration.