



Town of Carolina Beach  
 Planning/Inspections Department  
 1121 N. Lake Park Boulevard  
 Carolina Beach, NC 28428  
 Tel (910)458-2978 or Fax (910)458-2997

Permit # \_\_\_\_\_

### FENCE APPLICATION

(Applications must be printed or typewritten and have all information answered. Please include a copy of the property plat illustrating the placement of the structure/fence). This APPLICATION is hereby presented for a Zoning permit to erect a fence/structure in accordance with the Town Ordinance. If you have any questions you can call our Zoning Administrator at (910)-458-2991. After construction, please call (910) 458-2991 for a Final Inspection. There is a \$25 Zoning Fee.

Project Location DRY DOCK MOTEL - 300 LAKE PARK BLVD SOUTH

Property Owner DEE LANNI

Property Owner Address (if other than project location) \_\_\_\_\_

Property Owner Phone# 910.408.8390

Applicant (if other than property owner) Gator Strong Services

Applicant's Address (if other than property owner) 6319-A Carolina Beach Rd Wilmington NC 28412

Applicant's Phone# 910-520-3297

Contact person for project Dylan, Erin Phone # 910.520.3297

Email Address erin@gator-strong.com

**Fill dirt is NOT allowed in order to build up the height of a fence.**

Description of Proposed Construction (please include height and location of fence/structure in the description):

Height of fence/structure 54" Location of fence/structure Front Pool (closest to Lake Park Rd)

Residential \_\_\_\_\_ OR Commercial

Construction Cost \$ 10,346.<sup>00</sup>

I hereby certify that I have examined this complete application and the statements are therein true and correct and meet all Zoning requirements.

Print Name ERIN SCOTT Date Submitted 3/28/22

Signature of owner or authorized agent 

**\*\* Please submit all permit applications, plans, and additional materials to \*\***  
permits@carolinabeach.org

#GatorStrongServices

# GATOR STRONG SERVICES



FENCE

www.Gator-Strong.com

(910) 520-3297

HURRICANE SHUTTERS

Customer: Dec Lanny

Phone: 910-408-8390

Date: 3/3/22

Address: 300 Lake Park

City: CB


Zip: 29428

Subdivision: \_\_\_\_\_

Email: Vienna@reachprop.com

HOA/Mgmt. Company: \_\_\_\_\_

POOL CODE	
VINYL PRIVACY	
Top Style	
Height	
Color	
Gates /	
Total Ft.	
VINYL SEMI PICKET	
Top Style	
Picket Size 1.5" / 3" / 6"	
Spacing <2" / <4"	
Height	
Color	
Gates /	
Total Ft.	
ALUMINUM	
Grade <u>FS or Com.</u>	
Style <u>54" 7 rail</u>	
Spacing <u>Std</u> PP / DP	
Bottom Std <u>Flush</u>	
Height <u>54"</u>	
Color <u>B/K</u>	
Gates <u>(2) 54" x 3'</u>	
Total Ft.	
CHAIN LINK	
Grade	
Height	
Color	
Gates /	
Total Ft.	
WOOD	
Material	
Style	
Posts	
Height	
Gates /	
Total Ft.	



LOCATION	
Stakes	
Plot/Survey	
Steep Grade (Add'l \$)	
INSTALLATION	
Follow Ground	
Level Top	
Clearance Under Fence	
ADDITIONAL COSTS	
Permits	
HOA	
Core Drill	
Blacktop/Concrete	
Deck Mount	
Missile Post	
Fence Removal	
Dirt Removal	
UPGRADES	
Pool Hardware	
Post Caps	
Finials	
Scrolls	
Circles (O-rings)	
Butterflies	
Solar Lights	
UTILITIES	
Water	
Electric	

42" vinyl handrailing w/ & w/o Alum. pickets

ADDITIONAL NOTES:

---



---



---



---



---

PROJECT COST	
Total:	
Deposit:	
Balance*:	
*does not include any additional fees.	

**PLEASE NOTE:** This quote is good for 15 days from date signed and becomes an agreement once executed by the Customer. This agreement is contingent on supplier prices staying the same. **Due to COVID-19 and a low supply – high demand market, our vendors have advised us to let all our customers know that price increases MAY increase weekly. If this occurs, customers will be responsible for the difference in material cost.**





## Comments

Add Comment

Sort ▼

▼ **hmoccia**



03/31/2022 4:59 PM

The height of the fence around the pool can only be 4 ft, not 54", because the pool is located within the front setback of the property. Therefore, I need new plans which show the pool fencing will only be 4 ft.

Additionally, the Gator Strong Services document seems to show 2 pools getting new fencing. If this is the case, then you will need to get a second fence permit for the other Dry Dock Motel pool that is addressed to 201 Fayetteville. Since these pools are technically on 2 separate parcels, we need two permits.

Please email me confirming the height of the fence at 300 Lake Park Blvd. S. - [haley.moccia@carolinabeach.org](mailto:haley.moccia@carolinabeach.org). And if you are doing the second pool off of Fayetteville, please apply for a second fence permit.

Best,

Haley

[haley.moccia@carolinabeach.org](mailto:haley.moccia@carolinabeach.org)

Close