

From: [Marc Couture](#)
To: [Anthony Ward](#)
Subject: Re: Casco Community Center Roofing Bids
Date: Wednesday, August 26, 2026 11:17:52 AM
Attachments: [image.png](#)

Hi Anthony,

Please see my responses below. We are a certified GAF contractor and only provide the highest quality roof systems to our customers. If you would like to speak with a GAF representative, I am happy to provide a contact.

1. **Shingle Type:** GAF Timberline UHDZ Ultra High Definition Shingles - these are top tier architectural, designer shingles
2. **Wind Rating:** Infinite wind speed with GAF roof system
3. **Expected Life:** 50 year non-prorated warranty provided immediately after install
4. **Algae Resistance:** Yes - 30 years
5. **Water Shield:** 6 feet of ice and water coverage on all eaves and valleys
6. **Underlayment:** Yes - we will use GAF Deck-Armour premium breathable synthetic underlayment
7. **Roof Ventilation:** We will ventilate the roof using GAF Cobra ventilation and cap it with GAF TimberTex premium double-layer ridge cap shingles
8. **Schedule:** We can complete the project by the end of September and the job will take approximately one week.

Best Regards,
Marc

Marc Couture
c: 603.948.6070
o: 603.403.1713
marc@apexexteriorsnh.com
ApexExteriorsNH.com



From: Anthony Ward <award@cascomaine.org>

Sent: Wednesday, August 26, 2026 10:46 AM
To: Marc Couture <marc@apexexteriorsnh.com>
Subject: Casco Community Center Roofing Bids

Good morning Marc,

Thank you for submitting a bid for the Town's roof replacement project.

The bids received varied considerably, and prior to making an award, the Selectboard is seeking additional clarification to ensure that they are comparing the proposals on an equal basis. Each bidder is being asked the same questions.

Please provide responses to the following:

1. **Shingle Type:** What tier of shingle are you proposing—top-tier architectural, designer shingle, or basic three-tab?
2. **Wind Rating:** What is the wind rating of the proposed shingles?
3. **Expected Life:** What is the anticipated lifespan of the proposed shingles?
4. **Algae Resistance:** Do the proposed shingles have algae resistance?
5. **Water Shield:** Where do you propose to install Water shield?
6. **Underlayment:** Will you cover the entire roof with underlayment? If so, what type of underlayment are you proposing?
7. **Roof Ventilation:** How will you address roof ventilation as part of the project?
8. **Schedule:** If awarded the project, when would you be able to begin work, and approximately how many days would you anticipate needing to complete the project?

Please provide your responses at your earliest convenience so the Selectboard can complete its review and proceed with the bid award.

Thank you for your time and cooperation.

Tony

Anthony Ward, CMM, ICMA-CM
Town Manager
Town of Casco
207-627-4515 Ext. 1201
www.cascomaine.org

www.facebook.com/townofcascomaine

Freedom of Access Act Disclaimer: Please note that all emails sent from or coming to this address may be considered a public document and are subject to the State of Maine Freedom of Access Laws.