



# *City of Chipley*

**Water Utilities Department  
P. O. Box 1007  
Chipley, Florida 32428  
(850) 638-6347 - Fax: (850) 638-6052**

**March 31, 2025**

## **Water Utilities Department Report for March 2025**

To: City Council and Administrator

**Wastewater Treatment Facility:** The analytical results of the Wastewater Reclamation Facility for the month of February 2025 had no violations. We have not received all the results from March 2025, but what have received show no violations. Continuing to plot sewer lines and cleanouts in diamond maps. Cut grass at WWTF. DEP inspection done in January 2025 is completed and we received an in compliance letter this month.

**Lift Stations:** Jon Teal and Vo-Tech lift station generators have been installed we are awaiting start up. Routine inspections. Removed influent pumps at WWTF cleared debris.

**Water Wells:** The bacteriological samples for the month of March 2025 passed. Check generators weekly. Cut grass at wells.

**Spray Field:** Checked bypass pump at spray field, and generator at reuse pump station weekly. Routine inspection of spray field.

**Collection System:** Sewer stoppage at the housing authority jetted line to clear blockage. We have been working with Mott Mac on permit renewal. Replace sewer lateral at two homes due to line was offset. Jetted (19) mains as a preventive maintenance we do this every (3) months.

**Locates: 51**  
**Work orders: 4**  
**Sewer Stoppages: 5**  
**Abonnement Sewer Lateral: 2**  
**Replace Clean Out Caps: 2**  
**Sewer Taps: 0**  
**Replace/Repair Sewer Lateral: 2**  
**Development Order: 2**  
**Install Clean Out Boxes: 1**  
**Replace Clean Outs: 0**  
**Demolition Order: 1**  
**Rain Guards installed: 0**  
**Recorded Rainfall for the month: 6.08 inches**

Jimmy Cook  
Water Utilities Director